

KHERSON, UkraineWMO: **339020**Lat: **46.7381N**Lon: **32.7089E**Elev: **54**StdP: **100.68**Time Zone: **2.00 (EUE)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.5	-12.5	-19.1	0.7	-14.6	-15.8	0.9	-12.1	11.0	-7.2	10.1	-4.9	3.6	20	0.480

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	34.7	21.2	32.8	20.7	31.1	20.0	22.7	30.6	21.8	29.5	21.1	28.5	3.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.5	15.2	25.0	19.5	14.4	24.4	18.7	13.6	23.9	67.3	30.5	64.1	29.5	61.3	28.5	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.6	8.2	7.1	-18.5	37.0	3.6	2.2	-21.0	38.6	-23.2	39.9	-25.2	41.1	-27.8	42.6		
(5)			-18.7	24.5	3.5	0.9	-21.3	25.1	-23.3	25.6	-25.3	26.1	-27.9	26.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	-1.9	-0.4	4.2	10.8	16.9	21.2	23.8	23.1	17.6	10.8	5.2	0.4
	DBStd	10.01	5.51	5.41	4.09	3.76	3.85	3.25	2.94	3.39	3.88	4.44	4.71	5.39
	HDD10.0	1378	369	292	182	34	2	0	0	0	1	43	156	299
	HDD18.3	3149	628	525	437	227	73	11	1	3	59	235	394	556
	CDD10.0	1756	0	0	2	58	216	336	427	408	228	69	12	1
	CDD18.3	486	0	0	0	1	30	96	168	152	36	2	0	0
	CDH23.3	4984	0	0	0	16	314	921	1757	1639	326	12	0	0
	CDH26.7	2007	0	0	0	3	83	332	761	739	87	1	0	0
Wind	WSAvg	3.1	3.4	3.5	3.7	3.3	2.7	2.8	2.7	2.9	2.8	2.9	3.2	3.4
Precipitation	PrecAvg	430	32	30	30	29	43	52	42	32	39	33	34	35
	PrecMax	668	71	78	70	67	133	96	129	116	117	128	74	83
	PrecMin	277	4	4	2	4	0	14	1	1	5	7	0	2
	PrecStd	102	19	17	18	20	28	20	35	31	31	27	20	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.1	12.2	17.6	25.4	31.5	34.2	36.7	37.6	31.5	24.7	18.3	13.2
		MCWB	8.2	9.0	10.8	15.6	19.3	20.7	21.7	21.8	19.5	16.6	14.3	11.1
	2%	DB	8.0	9.6	14.7	22.1	28.9	32.1	34.4	35.1	29.2	22.2	15.7	11.1
		MCWB	6.8	7.3	9.2	13.7	18.0	20.4	21.4	21.3	18.4	15.8	13.3	9.6
	5%	DB	6.5	7.8	12.4	20.0	26.9	30.3	32.8	33.0	27.0	19.7	13.5	9.1
		MCWB	5.5	6.1	7.6	12.6	17.5	19.8	21.0	20.5	17.6	14.8	11.8	8.1
	10%	DB	4.9	6.1	10.4	17.9	24.6	28.5	31.0	30.8	24.9	17.5	11.8	7.6
		MCWB	4.1	4.8	6.7	11.4	16.5	19.0	20.5	19.7	16.7	13.9	10.2	6.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.6	9.5	11.1	16.4	20.8	22.9	24.0	23.6	21.3	18.7	15.1	11.5
		MCDB	9.7	11.4	16.2	24.0	29.2	30.3	32.0	32.8	27.2	22.4	17.1	12.8
	2%	WB	7.0	7.7	9.6	14.5	19.4	21.7	23.0	22.5	19.9	17.0	13.5	9.7
		MCDB	7.8	9.1	13.8	20.8	26.2	28.8	30.6	31.0	26.1	20.0	15.5	10.8
	5%	WB	5.6	6.3	8.4	13.2	18.2	20.8	22.1	21.6	18.9	15.7	12.0	8.2
		MCDB	6.3	7.5	11.5	18.7	24.9	27.7	29.6	29.8	23.8	18.8	13.4	9.0
	10%	WB	4.1	4.9	7.2	12.0	17.2	19.9	21.2	20.8	17.8	14.3	10.5	6.8
		MCDB	4.8	6.1	9.7	16.7	23.4	26.3	28.4	28.6	23.2	17.2	11.7	7.6
Mean Daily Temperature Range	5% DB	MDBR	5.4	6.3	8.0	10.5	11.4	11.2	11.8	12.3	10.8	8.9	6.3	5.3
		MCDBR	6.5	8.3	11.7	13.8	14.7	14.1	14.1	15.1	13.9	11.6	8.7	6.6
		MCWBR	5.3	6.0	6.9	6.9	6.1	5.1	4.8	5.6	6.0	6.0	6.0	5.2
	5% WB	MCDBR	6.2	7.6	10.6	12.6	13.3	12.2	12.7	13.3	11.9	10.0	7.7	6.4
		MCWBR	5.3	5.8	6.7	6.5	5.9	5.1	5.0	5.6	6.0	5.9	5.7	5.2
Clear-Sky Solar Irradiance	taub		0.337	0.366	0.393	0.440	0.416	0.417	0.442	0.439	0.410	0.374	0.355	0.338
	taud		2.301	2.237	2.208	2.104	2.262	2.288	2.230	2.223	2.273	2.352	2.335	2.323
	Ebn at Noon		731	784	820	813	851	851	822	807	796	769	704	683
	Edh at Noon		78	102	122	148	131	128	134	130	113	90	76	70
All-Sky Solar Radiation	RadAvg		1.04	1.92	3.16	4.82	6.07	6.42	6.43	5.78	4.15	2.56	1.23	0.85
	RadStd		0.18	0.25	0.32	0.41	0.51	0.43	0.38	0.30	0.42	0.30	0.18	0.14