

YALTA, Ukraine

WMO: 339900

Lat: 44.4811N

Lon: 34.1553E

Elev: 236

StdP: 14.57

Time Zone: 3.00 (E03)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	26.1	28.9	9.5	9.0	29.5	13.9	11.2	31.4	22.8	39.5	17.9	40.0	5.8	290	0.366

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	88.9	71.7	86.4	71.3	84.2	70.4	75.5	84.7	73.7	83.0	72.0	81.2	5.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.5	121.4	82.0	70.5	113.4	79.9	68.8	106.6	78.4	39.2	84.9	37.5	83.0	35.9	81.2	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.2	13.5	11.1	DB	22.1	92.8	4.7	4.0	18.7	95.7	15.9	98.0	13.2	100.3	9.8	103.2
			WB	18.9	77.8	3.4	2.1	16.4	79.3	14.4	80.5	12.5	81.7	10.1	83.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	56.8	41.0	40.4	44.2	52.1	61.9	70.0	77.0	76.1	67.1	57.8	49.8	42.6
	DBStd	14.23	5.64	5.97	5.54	6.02	5.61	4.54	4.66	4.78	5.21	6.74	6.07	6.91
	HDD50	1130	282	272	197	43	1	0	0	0	0	14	77	244
	HDD65	4038	745	689	646	389	130	12	0	0	38	238	456	695
	CDD50	3597	1	3	16	106	369	600	838	808	513	258	71	14
	CDD65	1029	0	0	0	2	33	161	373	343	101	16	0	0
	CDH74	6765	0	0	0	8	56	644	3073	2648	311	25	0	0
	CDH80	1765	0	0	0	0	3	78	896	766	21	1	0	0
Wind	WSAvg	4.2	4.3	4.5	4.5	4.2	3.9	3.8	4.1	4.2	4.4	4.3	4.1	4.6
Precipitation	PrecAvg	23.7	3.1	2.4	1.8	1.4	1.4	1.7	1.3	1.5	1.8	1.8	2.6	3.6
	PrecMax	43.7	9.6	5.2	5.0	5.2	4.1	5.1	3.3	6.1	11.6	8.2	9.6	10.5
	PrecMin	12.2	0.6	0.4	0.3	0.0	0.2	0.3	0.0	0.0	0.0	0.0	0.1	0.1
	PrecStd	6.5	2.5	1.4	1.2	1.1	0.9	1.0	0.9	1.3	2.0	1.7	2.1	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.1	57.5	66.6	74.3	79.0	85.1	92.5	93.4	82.3	76.6	65.3	60.0
		MCWB	47.1	49.4	52.5	58.8	63.6	68.7	73.8	73.8	68.1	66.4	58.5	53.8
	2%	DB	52.1	53.5	59.0	67.7	75.1	82.3	89.3	89.2	79.6	73.1	62.3	56.5
		MCWB	46.7	46.8	48.9	56.0	62.5	68.1	72.7	70.8	67.8	65.1	56.7	51.7
	5%	DB	49.7	50.8	55.0	63.8	72.8	80.0	87.0	86.5	77.4	69.8	59.8	53.8
		MCWB	45.7	46.3	47.7	53.6	62.0	67.3	72.1	70.8	66.9	62.4	54.6	49.7
	10%	DB	48.0	48.4	52.1	61.0	70.6	77.7	84.9	84.2	75.4	67.1	57.5	51.7
		MCWB	44.8	44.6	46.2	52.5	60.5	66.4	71.3	70.5	65.9	60.6	52.9	47.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.9	50.6	53.2	60.1	66.7	73.5	79.0	77.1	72.7	68.3	60.7	55.0
		MCDB	53.1	55.1	63.7	71.4	73.3	79.6	86.1	87.6	78.4	73.7	65.2	58.3
	2%	WB	47.8	48.4	50.6	57.4	65.2	71.5	76.5	74.8	70.3	66.2	57.4	52.4
		MCDB	50.1	51.8	57.2	66.0	72.2	78.5	85.6	84.5	76.8	72.0	61.1	55.7
	5%	WB	46.6	46.7	48.9	55.1	63.7	69.7	74.6	73.5	68.6	64.0	55.6	50.5
		MCDB	48.8	49.9	53.4	61.2	70.5	77.1	83.9	83.0	75.7	68.9	59.0	53.3
	10%	WB	45.2	45.1	47.2	53.6	62.1	68.1	72.5	72.0	66.9	61.6	53.7	48.5
		MCDB	47.5	48.3	50.9	59.3	68.8	75.8	82.3	81.7	73.9	66.1	56.6	50.9
Mean Daily Temperature Range	5% DB	MDBR	7.2	8.8	9.4	10.1	11.4	11.5	12.1	12.1	11.2	10.2	8.4	7.6
		MCDBR	9.9	11.2	14.4	15.1	13.9	13.5	13.4	13.8	12.7	11.9	10.3	9.5
		MCWBR	7.8	7.9	8.8	7.9	8.6	9.2	9.6	10.0	9.8	9.6	8.7	7.1
	5% WB	MCDBR	8.7	10.4	12.8	12.0	11.9	11.6	12.3	12.5	11.7	10.8	10.0	8.4
MCWBR		7.3	7.9	8.2	7.2	8.5	9.4	10.2	10.8	10.2	9.8	8.6	6.9	
Clear-Sky Solar Irradiance	taub	0.350	0.377	0.407	0.444	0.418	0.416	0.434	0.436	0.411	0.382	0.362	0.347	
	taud	2.335	2.258	2.204	2.129	2.296	2.344	2.305	2.285	2.324	2.369	2.356	2.347	
	Ebn at Noon	238	251	260	259	271	272	265	259	256	248	231	226	
	Edh at Noon	26	33	40	47	41	39	40	39	35	30	25	23	
All-Sky Solar Radiation	RadAvg	383	640	1064	1596	1983	2173	2195	1931	1420	890	499	338	
	RadStd	46	71	93	161	151	135	95	110	116	81	47	42	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (4 neighbors)	+1.12	N/A	N/A	N/A	+0.77	N/A	-193	-257	+220	+135

Nomenclature: See separate page