

YALTA, Ukraine

WMO: 339900

Lat: 44.4811N

Lon: 34.1553E

Elev: 72

StdP: 100.46

Time Zone: 3.00 (E03)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-3.3	-1.7	-12.5	1.3	-1.4	-10.0	1.6	-0.3	10.2	4.2	8.0	4.5	2.6	290	0.366

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.7	31.6	22.1	30.2	21.8	29.0	21.4	24.2	29.3	23.2	28.3	22.2	27.4	2.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.5	17.3	27.8	21.4	16.2	26.6	20.4	15.2	25.8	73.3	29.4	69.3	28.4	65.7	27.4	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.2	6.0	5.0	-5.5	33.8	2.6	2.2	-7.4	35.4	-8.9	36.7	-10.4	37.9	-12.3	39.5		
(5)			-7.3	25.5	1.9	1.2	-8.7	26.3	-9.8	27.0	-10.8	27.6	-12.2	28.4	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.8	5.0	4.7	6.8	11.2	16.6	21.1	25.0	24.5	19.5	14.4	9.9	5.9	(6)	(7)
	DBStd	7.90	3.13	3.32	3.08	3.34	3.12	2.52	2.59	2.65	2.89	3.74	3.37	3.84	(7)	(8)
	HDD10.0	628	157	151	109	24	1	0	0	0	0	8	43	136	(8)	(9)
	HDD18.3	2243	414	383	359	216	72	7	0	0	21	132	253	386	(9)	(10)
	CDD10.0	1998	1	2	9	59	205	333	466	449	285	143	39	8	(10)	(11)
	CDD18.3	572	0	0	0	1	18	89	207	191	56	9	0	0	(11)	(12)
	CDH23.3	3758	0	0	0	4	31	358	1707	1471	173	14	0	0	(12)	(13)
	CDH26.7	981	0	0	0	0	2	43	498	426	12	1	0	0	(13)	(14)
(14) Wind	WSAvg	1.9	1.9	2.0	2.0	1.9	1.7	1.7	1.9	1.9	1.9	1.9	1.8	2.0	(14)	(15)
(15) Precipitation	PrecAvg	603	79	62	45	35	35	42	34	39	45	45	65	91	(15)	(16)
	PrecMax	1111	243	132	128	133	103	130	84	155	295	209	243	267	(16)	(17)
	PrecMin	309	14	10	7	0	4	7	0	0	0	0	3	2	(17)	(18)
	PrecStd	166	63	35	30	27	24	25	23	34	52	43	53	57	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.4	14.2	19.2	23.5	26.1	29.5	33.6	34.1	27.9	24.8	18.5	15.6	(19)	(20)
		MCWB	8.4	9.7	11.4	14.9	17.5	20.4	23.2	23.2	20.1	19.1	14.7	12.1	(20)	(21)
	2%	DB	11.2	11.9	15.0	19.8	23.9	27.9	31.8	31.8	26.5	22.8	16.8	13.6	(21)	(22)
		MCWB	8.2	8.2	9.4	13.3	16.9	20.0	22.6	21.5	19.9	18.4	13.7	10.9	(22)	(23)
	5%	DB	9.9	10.5	12.8	17.7	22.7	26.7	30.6	30.3	25.2	21.0	15.4	12.1	(23)	(24)
		MCWB	7.6	8.0	8.7	12.0	16.6	19.6	22.3	21.5	19.4	16.9	12.5	9.8	(24)	(25)
	10%	DB	8.9	9.1	11.2	16.1	21.5	25.4	29.4	29.0	24.1	19.5	14.2	10.9	(25)	(26)
		MCWB	7.1	7.0	7.9	11.4	15.8	19.1	21.8	21.4	18.8	15.9	11.6	8.7	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	10.4	11.8	15.6	19.3	23.0	26.1	25.1	22.6	20.2	15.9	12.8	(27)	(28)
		MCDB	11.7	12.8	17.6	21.9	23.0	26.4	30.1	30.9	25.8	23.2	18.5	14.6	(28)	(29)
	2%	WB	8.8	9.1	10.3	14.1	18.4	21.9	24.7	23.8	21.3	19.0	14.1	11.3	(29)	(30)
		MCDB	10.1	11.0	14.0	18.9	22.3	25.8	29.8	29.1	24.9	22.2	16.2	13.1	(30)	(31)
	5%	WB	8.1	8.2	9.4	12.9	17.6	20.9	23.7	23.0	20.3	17.8	13.1	10.3	(31)	(32)
		MCDB	9.3	9.9	11.9	16.2	21.4	25.1	28.9	28.3	24.3	20.5	15.0	11.8	(32)	(33)
	10%	WB	7.3	7.3	8.5	12.0	16.7	20.1	22.5	22.2	19.4	16.4	12.1	9.1	(33)	(34)
		MCDB	8.6	9.0	10.5	15.2	20.4	24.3	27.9	27.6	23.3	18.9	13.7	10.5	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	4.0	4.9	5.2	5.6	6.3	6.4	6.7	6.7	6.2	5.7	4.7	4.2	(35)	(36)
		MCDBR	5.5	6.2	8.0	8.4	7.7	7.5	7.4	7.7	7.1	6.6	5.7	5.3	(36)	(37)
	5% WB	MCWBR	4.3	4.4	4.9	4.4	4.8	5.1	5.3	5.6	5.5	5.4	4.8	3.9	(37)	(38)
		MCWBR	4.9	5.8	7.1	6.7	6.6	6.4	6.8	6.9	6.5	6.0	5.5	4.7	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.350	0.377	0.407	0.444	0.418	0.416	0.434	0.436	0.411	0.382	0.362	0.347	(39)	(40)
		taud	2.335	2.258	2.204	2.129	2.296	2.344	2.305	2.285	2.324	2.369	2.356	2.347	(40)	(41)
	Ebn at Noon		749	792	819	818	854	856	834	818	808	781	727	711	(41)	(42)
		Edh at Noon	81	105	126	147	128	122	126	124	111	93	79	74	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		1.21	2.02	3.35	5.03	6.25	6.85	6.92	6.09	4.47	2.81	1.57	1.07	(43)	(44)
	RadStd		0.14	0.23	0.29	0.51	0.48	0.43	0.30	0.35	0.37	0.26	0.15	0.13	(44)	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)			+0.62	N/A	N/A	N/A	+0.43	N/A	-107	-143	+122	+75

Nomenclature: See separate page