

KURSK, Russian FederationWMO: **340090**Lat: **51.767N**Lon: **36.167E**Elev: **247**StdP: **98.39**Time Zone: **3.00 (E03)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.9	-18.8	-25.2	0.4	-21.4	-22.1	0.5	-18.6	8.3	-3.7	7.4	-3.6	2.1	50	0.499

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	30.9	19.4	28.9	18.6	27.2	18.0	20.7	27.6	19.9	26.6	19.2	25.3	2.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	13.7	23.2	17.7	13.1	22.5	17.0	12.5	21.8	60.9	27.5	58.1	26.6	55.5	25.4	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.7	6.0	-24.1	33.3	3.7	2.3	-26.7	35.0	-28.8	36.4	-30.9	37.6	-33.5	39.3		
(5)			-24.3	22.2	3.6	0.9	-26.9	22.9	-29.0	23.4	-31.0	23.9	-33.7	24.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.3	-6.4	-5.6	-0.5	8.4	15.0	18.4	20.5	19.4	13.6	7.0	0.6	-4.3
	DBStd	10.89	6.01	6.28	4.72	4.75	4.83	3.86	3.43	3.85	4.30	4.67	4.99	5.88
	HDD10.0	2226	507	438	324	86	12	1	0	0	14	116	282	444
	HDD18.3	4276	766	671	582	299	126	48	17	32	151	351	532	703
	CDD10.0	1222	0	0	1	38	167	251	327	293	122	23	1	0
	CDD18.3	231	0	0	0	1	22	48	85	66	9	1	0	0
	CDH23.3	1804	0	0	0	4	163	330	655	582	68	1	0	0
	CDH26.7	507	0	0	0	0	29	68	202	200	8	0	0	0
Wind	WSAvg	2.7	2.9	3.1	3.1	2.9	2.5	2.5	2.2	2.2	2.3	2.6	2.9	3.0
Precipitation	PrecAvg	641	47	41	42	45	54	68	74	55	67	59	46	43
	PrecMax	950	110	67	117	107	106	165	178	150	145	168	93	127
	PrecMin	450	23	20	7	0	21	19	23	4	10	9	6	14
	PrecStd	98	21	15	25	24	24	34	39	35	40	35	25	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.3	5.2	13.9	23.6	29.3	30.8	33.9	34.9	28.0	21.0	13.1	7.8
		MCWB	3.7	3.7	7.4	12.7	17.2	18.5	19.9	19.4	16.3	13.5	11.1	6.9
	2%	DB	2.7	3.4	10.0	20.5	27.2	28.5	30.9	31.2	25.4	18.1	10.2	5.5
		MCWB	2.0	2.4	5.6	11.7	16.3	18.5	19.8	19.3	15.2	13.0	8.9	4.7
	5%	DB	1.6	2.2	7.5	18.3	25.1	26.9	28.9	28.6	22.8	15.4	8.6	3.7
		MCWB	1.0	1.3	4.3	10.7	15.9	18.1	19.4	18.4	14.6	11.8	7.5	3.1
	10%	DB	0.7	1.3	5.4	16.0	23.0	25.2	26.9	26.5	20.4	13.3	6.9	2.0
		MCWB	0.2	0.6	3.0	9.6	15.1	17.4	18.8	17.6	13.9	10.6	6.1	1.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.0	4.0	8.3	14.0	19.4	21.0	22.0	21.8	17.7	15.5	11.2	7.1
		MCDB	4.2	4.9	12.3	20.9	26.8	27.0	29.7	29.8	23.0	18.2	12.8	7.6
	2%	WB	2.1	2.6	6.2	12.5	17.8	19.9	21.0	20.3	16.6	13.6	9.3	4.9
		MCDB	2.5	3.2	9.2	18.1	24.5	26.2	27.8	28.1	21.8	16.9	10.1	5.5
	5%	WB	1.1	1.6	4.6	11.4	16.7	19.1	20.2	19.4	15.7	12.3	7.6	3.2
		MCDB	1.4	2.0	6.9	16.6	22.9	24.9	26.6	26.5	21.0	15.0	8.4	3.6
	10%	WB	0.2	0.8	3.2	10.5	15.7	18.2	19.5	18.5	14.7	10.9	6.1	1.6
		MCDB	0.6	1.2	5.1	15.2	21.4	23.6	25.4	24.8	19.5	13.0	6.8	1.9
Mean Daily Temperature Range	5% DB	MDBR	4.4	5.2	5.9	8.4	9.2	8.8	9.0	9.6	8.3	6.2	4.2	4.2
		MCDBR	3.3	4.2	8.3	11.5	11.2	10.7	11.6	12.3	12.1	9.4	6.1	4.3
		MCWBR	3.3	3.7	5.2	5.6	4.7	4.5	4.2	4.5	5.4	5.5	4.9	4.1
	5% WB	MCDBR	3.2	3.9	7.3	10.0	10.0	9.7	10.2	10.9	10.1	8.3	5.2	4.2
		MCWBR	3.3	3.8	5.2	5.4	4.7	4.6	4.2	4.6	5.3	5.6	4.8	4.1
Clear-Sky Solar Irradiance	taub	0.299	0.332	0.358	0.436	0.395	0.384	0.418	0.425	0.390	0.356	0.334	0.302	
	taud	2.136	2.054	2.118	2.094	2.302	2.352	2.271	2.236	2.301	2.367	2.282	2.187	
	Ebn at Noon	677	756	821	796	858	871	830	800	786	742	641	607	
	Edh at Noon	74	108	124	144	122	118	126	124	103	80	66	61	
All-Sky Solar Radiation	RadAvg	0.93	1.92	3.28	4.17	5.70	6.00	5.72	5.02	3.27	1.73	0.76	0.56	
	RadStd	0.18	0.24	0.51	0.38	0.46	0.53	0.40	0.46	0.41	0.27	0.16	0.14	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.83	N/A	N/A	+0.87	N/A	N/A	-160	-237	+126	+52
Regional (5 neighbors)	+0.75	N/A	N/A	+0.90	N/A	N/A	-147	-221	+115	+46

Nomenclature: See separate page