

ALEKSANDROV-GAJ, Russian Federation

WMO: 343910

Lat: 50.150N

Lon: 48.550E

Elev: 25

StdP: 101.03

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-25.7	-22.8	-29.1	0.3	-25.4	-25.9	0.4	-22.4	10.4	-3.5	9.5	-2.2	2.3	70	0.553

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.5	36.9	20.4	35.0	20.0	33.1	19.5	21.6	33.0	20.9	32.1	20.2	30.6	3.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.4	13.3	24.3	17.5	12.5	24.1	16.6	11.9	24.0	62.8	33.0	60.5	31.9	58.1	30.6	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.8	6.9	-28.8	39.0	3.6	1.7	-31.4	40.2	-33.5	41.1	-35.5	42.1	-38.1	43.3		
(5)			-28.9	22.9	3.6	1.0	-31.5	23.6	-33.6	24.2	-35.6	24.7	-38.2	25.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.8	-9.3	-8.9	-1.4	9.6	16.6	22.2	24.5	22.9	15.9	8.0	-0.3	-6.7		
	DBStd	13.35	6.79	7.26	5.85	5.04	4.78	4.38	3.73	4.34	4.68	4.57	5.69	6.73		
	HDD10.0	2484	599	528	355	68	6	0	0	0	7	95	311	516		
	HDD18.3	4370	857	762	613	265	91	13	2	11	102	320	560	774		
	CDD10.0	1698	0	0	1	54	210	366	450	401	182	34	1	0		
	CDD18.3	541	0	0	0	2	37	129	193	152	28	1	0	0		
	CDH23.3	6737	0	0	0	32	468	1574	2376	1893	386	8	0	0		
	CDH26.7	3242	0	0	0	4	170	767	1218	951	132	1	0	0		
(14) Wind	WSAvg	3.3	3.4	3.8	3.7	3.5	3.3	3.0	2.9	2.9	3.0	3.2	3.4	3.5		
(15) Precipitation	PrecAvg	316	30	25	19	21	23	33	29	27	22	26	33	30		
	PrecMax	436	63	74	47	77	72	132	114	88	63	54	77	65		
	PrecMin	176	7	0	0	0	1	5	0	0	3	6	4	10		
	PrecStd	80	15	17	12	17	17	26	25	21	16	12	23	17		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.8	4.2	16.1	26.8	33.2	38.5	39.2	38.8	32.9	24.3	13.5	6.7		
		MCWB	4.2	2.7	9.5	15.6	18.1	20.5	21.0	21.0	17.7	13.5	10.5	5.8		
	2%	DB	2.5	2.2	11.5	23.7	30.7	35.9	36.9	36.3	30.1	21.4	10.7	4.1		
		MCWB	2.0	1.3	7.4	13.9	17.9	19.8	20.6	20.4	16.6	12.8	8.8	3.2		
	5%	DB	0.9	1.5	8.3	21.0	28.5	33.6	34.9	34.4	27.8	18.2	8.6	2.5		
		MCWB	0.5	0.7	5.4	13.1	17.0	19.5	20.4	19.7	15.9	11.5	7.1	1.9		
	10%	DB	0.0	0.7	5.7	18.2	25.9	31.2	32.9	32.0	25.2	15.5	6.8	1.1		
		MCWB	-0.3	0.1	3.6	11.3	16.0	18.9	19.8	19.0	15.2	10.7	5.8	0.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.3	3.0	10.1	16.9	19.8	22.1	22.7	22.2	19.7	16.6	11.2	6.0		
		MCDB	4.6	4.0	14.3	24.5	29.7	34.2	33.6	33.9	29.2	20.3	12.6	6.6		
	2%	WB	2.1	1.6	7.6	14.9	18.8	21.0	21.7	21.3	18.0	13.9	9.1	3.5		
		MCDB	2.4	2.1	11.0	21.7	28.8	32.1	33.0	33.3	27.1	18.6	10.5	3.9		
	5%	WB	0.6	0.9	5.6	13.5	17.5	20.2	21.2	20.5	16.9	12.5	7.3	2.0		
		MCDB	0.9	1.4	8.0	19.6	26.4	30.9	32.0	31.9	25.7	16.9	8.3	2.4		
	10%	WB	-0.3	0.2	3.7	12.0	16.5	19.4	20.5	19.7	15.7	11.0	5.9	0.7		
		MCDB	0.1	0.7	5.5	17.4	24.7	29.5	30.7	30.1	23.0	14.9	6.8	1.1		
(35) Mean Daily Temperature Range	MDBR		6.5	7.4	7.9	11.3	12.2	12.5	12.5	13.2	13.1	10.1	6.5	6.1		
	5% DB	MCDBR	4.2	5.2	11.4	14.9	15.4	15.4	14.8	15.7	16.8	14.8	8.4	4.8		
		MCWBR	4.2	4.6	7.4	7.2	6.2	5.3	5.0	5.9	7.4	7.9	6.5	4.4		
	5% WB	MCDBR	4.2	4.8	10.7	13.6	13.9	13.7	13.1	14.1	14.7	12.3	7.5	4.7		
		MCWBR	4.3	4.5	7.3	7.1	6.3	5.4	5.0	5.7	7.1	7.5	6.2	4.5		
(40) Clear-Sky Solar Irradiance	taub		0.322	0.346	0.387	0.448	0.423	0.404	0.413	0.430	0.379	0.358	0.337	0.319		
	taud		2.074	2.018	2.083	2.043	2.201	2.316	2.291	2.223	2.332	2.324	2.265	2.135		
	Ebn at Noon		667	755	800	791	835	855	839	802	809	753	665	612		
	Edh at Noon		85	116	131	153	137	123	124	127	102	86	71	70		
(44) All-Sky Solar Radiation	RadAvg		1.09	2.24	3.41	4.62	6.08	6.56	6.37	5.49	3.90	2.23	1.03	0.71		
	RadStd		0.25	0.38	0.49	0.35	0.44	0.55	0.42	0.37	0.38	0.29	0.15	0.15		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days				
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	+1.86	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (3 neighbors)	N/A	N/A	N/A	+1.23	N/A	N/A	N/A	N/A	+166	+109	(47)

Nomenclature: See separate page