

VERKHNIY BASKUNCHAK, Russian Federation

WMO: 345790

Lat: 48.217N

Lon: 46.733E

Elev: 113

StdP: 14.64

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.2	-3.5	-14.9	2.5	-8.8	-9.4	3.3	-3.2	18.7	26.2	16.8	25.5	4.9	270	0.510

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.9	99.3	68.8	96.0	68.0	92.6	66.7	71.3	92.1	69.9	89.9	68.4	87.5	7.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.5	94.6	77.1	63.6	88.4	75.9	61.8	82.9	75.8	35.1	91.7	33.8	89.5	32.7	87.9	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.8	14.8	13.4	DB	-13.9	102.4	9.1	3.6	-20.4	105.0	-25.7	107.1	-30.8	109.1	-37.5	111.7	
			WB	-13.5	74.0	8.7	2.4	-19.7	75.7	-24.8	77.1	-29.7	78.5	-36.0	80.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.5	20.1	21.9	35.0	51.3	64.6	73.7	78.3	76.3	63.0	49.0	34.7	24.7	
	DBStd	22.78	11.75	11.91	8.70	8.49	8.89	7.31	6.40	7.50	8.13	8.96	9.58	10.75	
	HDD50	3652	928	786	469	84	5	0	0	0	6	127	462	785	
	HDD65	6869	1393	1206	931	417	117	11	1	6	129	498	910	1250	
	CDD50	3486	0	0	3	122	459	711	879	815	397	98	2	0	
	CDD65	1228	0	0	0	5	106	272	414	357	71	3	0	0	
	CDH74	14457	0	0	0	66	1193	3104	5023	4299	735	37	0	0	
	CDH80	7000	0	0	0	5	481	1454	2606	2209	241	4	0	0	
Wind	WSAvg	6.7	7.1	7.6	8.0	7.5	6.7	6.2	5.6	5.7	5.9	6.2	6.8	7.3	
Precipitation	PrecAvg	11.1	0.9	0.7	0.8	0.8	1.1	1.2	1.1	0.6	0.9	1.0	0.9	0.9	
	PrecMax	16.0	2.0	1.6	2.2	3.0	5.2	4.5	4.5	1.6	3.3	3.4	2.4	2.8	
	PrecMin	6.8	0.2	0.1	0.0	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.2	
	PrecStd	2.5	0.4	0.4	0.7	0.7	1.1	0.9	0.9	0.5	0.9	0.8	0.6	0.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.7	45.9	62.8	80.9	94.2	100.8	104.1	102.6	92.4	78.2	58.7	46.4	
		MCWB	40.8	40.8	48.9	60.1	66.0	68.6	69.9	69.5	65.0	60.1	51.2	44.2	
	2%	DB	38.9	41.1	56.3	76.1	89.8	96.6	99.4	98.6	86.2	72.8	53.8	42.8	
		MCWB	36.7	37.6	45.9	57.8	63.9	67.2	68.9	68.9	62.8	56.8	49.5	40.8	
	5%	DB	36.1	38.0	51.5	71.1	85.6	92.5	96.0	95.0	82.1	67.3	50.2	39.6	
		MCWB	34.3	35.0	43.5	55.9	62.4	66.5	68.2	67.6	61.1	54.9	46.6	37.9	
	10%	DB	33.7	35.3	47.1	66.4	80.7	88.3	92.6	91.1	77.9	62.4	47.1	36.6	
		MCWB	32.2	33.2	40.8	53.2	60.9	65.1	66.9	66.7	60.0	53.1	44.3	35.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.2	41.4	50.4	61.8	70.9	71.8	73.6	74.3	68.5	62.1	52.8	44.9
			MCDB	43.1	44.4	59.8	75.5	91.0	93.4	94.0	94.0	85.6	72.8	56.9	45.9
2%		WB	37.1	38.1	47.0	59.3	66.0	69.6	71.1	71.4	65.5	58.8	49.9	41.3	
		MCDB	38.5	40.8	55.1	72.6	83.2	89.5	92.6	91.3	79.9	68.6	52.6	42.5	
5%		WB	34.4	35.4	44.0	56.9	63.6	68.1	69.8	69.6	63.4	56.2	47.2	38.0	
		MCDB	35.6	37.4	50.4	68.8	80.1	86.6	90.5	88.7	77.0	64.9	49.7	39.2	
10%		WB	32.4	33.5	41.3	54.3	61.8	66.6	68.5	67.9	61.3	53.8	44.5	35.2	
		MCDB	33.4	35.1	46.3	65.0	77.5	83.7	88.0	86.7	74.4	61.6	47.0	36.2	
Mean Daily Temperature Range	5% DB	MDBR	10.3	12.2	14.6	19.4	20.5	20.5	20.9	22.0	20.9	16.9	11.8	9.4	
		MCDBR	8.5	12.2	22.1	25.1	26.0	25.1	25.0	26.0	26.2	24.1	15.1	9.4	
		MCWBR	7.5	9.3	12.8	11.7	10.2	8.4	8.1	9.6	10.6	12.2	11.0	8.4	
	5% WB	MCDBR	7.8	10.6	19.7	22.7	23.0	22.0	21.9	22.8	21.2	20.7	13.1	8.7	
		MCWBR	7.2	8.5	12.2	11.5	10.4	8.1	8.4	10.1	10.4	11.9	10.5	8.2	
Clear-Sky Solar Irradiance	taub	0.340	0.370	0.399	0.463	0.434	0.416	0.424	0.436	0.399	0.369	0.349	0.342		
	taud	2.123	2.049	2.121	2.003	2.174	2.283	2.263	2.202	2.268	2.296	2.247	2.144		
	Ebn at Noon	217	238	254	249	263	269	265	255	253	240	215	198		
	Edh at Noon	28	38	41	51	45	41	41	42	36	29	25	24		
All-Sky Solar Radiation	RadAvg	315	613	1028	1511	1947	2120	2058	1809	1318	794	385	234		
	RadStd	75	118	114	110	134	182	138	114	95	95	58	38		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	+2.11	N/A	N/A	N/A	N/A	+220	N/A

Nomenclature: See separate page