

VERKHNIY BASKUNCHAK, Russian Federation

WMO: 345790

Lat: 48.217N

Lon: 46.733E

Elev: 35

StdP: 100.91

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.9	-19.7	-26.0	0.4	-22.7	-23.0	0.5	-19.6	8.4	-3.2	7.5	-3.6	2.2	270	0.510

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	37.4	20.4	35.5	20.0	33.7	19.3	21.9	33.4	21.0	32.2	20.2	30.8	3.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	13.5	25.1	17.6	12.6	24.4	16.6	11.8	24.3	63.8	33.1	60.8	32.0	58.2	31.0	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.6	6.0	DB	-25.5	39.1	5.1	2.0	-29.1	40.5	-32.1	41.7	-34.9	42.8	-38.6	44.3	(4)
(5)			WB	-25.3	23.3	4.8	1.3	-28.7	24.3	-31.6	25.1	-34.3	25.8	-37.8	26.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	-6.6	-5.6	1.7	10.7	18.1	23.2	25.7	24.6	17.2	9.5	1.5	-4.1	(6)	
	DBStd	12.65	6.53	6.62	4.83	4.72	4.94	4.06	3.55	4.17	4.52	4.98	5.32	5.97	(7)	
	HDD10.0	2029	516	437	261	47	3	0	0	0	3	71	257	436	(8)	
	HDD18.3	3816	774	670	517	232	65	6	1	3	72	277	506	694	(9)	
	CDD10.0	1937	0	0	2	68	255	395	488	453	221	54	1	0	(10)	
	CDD18.3	682	0	0	0	3	59	151	230	198	39	2	0	0	(11)	
	CDH23.3	8032	0	0	0	37	663	1724	2791	2388	408	21	0	0	(12)	
	CDH26.7	3889	0	0	0	3	267	808	1448	1227	134	2	0	0	(13)	
(14) Wind	WSAvg	3.0	3.2	3.4	3.6	3.4	3.0	2.8	2.5	2.5	2.6	2.8	3.0	3.2	(14)	
(15) Precipitation	PrecAvg	283	23	18	21	21	29	31	28	14	24	25	24	24	(15)	
	PrecMax	407	52	40	57	77	131	115	114	41	83	87	61	70	(16)	
	PrecMin	173	6	2	0	2	4	1	0	0	0	1	2	5	(17)	
	PrecStd	64	11	10	17	17	27	24	23	12	23	20	15	15	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.5	7.7	17.1	27.2	34.6	38.2	40.0	39.2	33.5	25.7	14.8	8.0	(19)	
		MCWB	4.9	4.9	9.4	15.6	18.9	20.3	21.1	20.8	18.3	15.6	10.7	6.8	(20)	
	2%	DB	3.8	5.0	13.5	24.5	32.1	35.9	37.5	37.0	30.1	22.7	12.1	6.0	(21)	
		MCWB	2.6	3.1	7.7	14.3	17.7	19.6	20.5	20.5	17.1	13.8	9.7	4.9	(22)	
	5%	DB	2.3	3.3	10.8	21.7	29.8	33.6	35.6	35.0	27.9	19.6	10.1	4.2	(23)	
		MCWB	1.3	1.7	6.4	13.3	16.9	19.1	20.1	19.8	16.1	12.7	8.1	3.3	(24)	
	10%	DB	0.9	1.9	8.4	19.1	27.1	31.3	33.7	32.8	25.5	16.9	8.4	2.6	(25)	
		MCWB	0.1	0.7	4.9	11.8	16.1	18.4	19.4	19.3	15.5	11.7	6.8	1.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.1	5.2	10.2	16.6	21.6	22.1	23.1	23.5	20.3	16.7	11.6	7.2	(27)	
		MCDB	6.2	6.9	15.4	24.2	32.8	34.1	34.4	34.4	29.8	22.7	13.8	7.7	(28)	
	2%	WB	2.8	3.4	8.3	15.1	18.9	20.9	21.7	21.9	18.6	14.9	10.0	5.2	(29)	
		MCDB	3.6	4.9	12.8	22.6	28.4	32.0	33.6	32.9	26.6	20.4	11.5	5.8	(30)	
	5%	WB	1.3	1.9	6.7	13.9	17.5	20.1	21.0	20.9	17.4	13.4	8.4	3.3	(31)	
		MCDB	2.0	3.0	10.2	20.4	26.7	30.3	32.5	31.5	25.0	18.3	9.8	4.0	(32)	
	10%	WB	0.2	0.8	5.2	12.4	16.5	19.2	20.3	20.0	16.3	12.1	6.9	1.8	(33)	
		MCDB	0.8	1.7	8.0	18.3	25.3	28.7	31.1	30.4	23.6	16.5	8.4	2.3	(34)	
(35) Mean Daily Temperature Range	MDBR		5.7	6.8	8.1	10.8	11.4	11.4	11.6	12.2	11.6	9.4	6.5	5.2	(35)	
	5% DB	MCDBR	4.7	6.8	12.3	13.9	14.4	13.9	13.9	14.4	14.6	13.4	8.4	5.2	(36)	
		MCWBR	4.2	5.2	7.1	6.5	5.7	4.7	4.5	5.3	5.9	6.8	6.1	4.7	(37)	
	5% WB	MCDBR	4.3	5.9	11.0	12.6	12.8	12.2	12.2	12.7	11.8	11.5	7.3	4.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.340	0.370	0.399	0.463	0.434	0.416	0.424	0.436	0.399	0.369	0.349	0.342	(40)	
	taud		2.123	2.049	2.121	2.003	2.174	2.283	2.263	2.202	2.268	2.296	2.247	2.144	(41)	
	Ebn at Noon		684	751	801	785	830	849	834	803	798	757	678	625	(42)	
	Edh at Noon		88	119	130	162	142	128	129	131	112	92	78	77	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.99	1.93	3.24	4.76	6.14	6.68	6.49	5.70	4.16	2.50	1.21	0.74	(44)	
	RadStd		0.24	0.37	0.36	0.35	0.42	0.57	0.43	0.36	0.30	0.30	0.18	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	-1.27	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	+1.17	N/A	N/A	N/A	N/A	+122	N/A

Nomenclature: See separate page