

REMONTNOYE, Russian Federation

WMO: 347590

Lat: 46.567N

Lon: 43.667E

Elev: 349

StdP: 14.51

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.3	3.6	-8.4	3.5	-2.6	-1.5	5.1	4.2	21.6	25.5	19.0	26.7	5.3	130	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.1	95.8	68.8	92.4	67.7	89.2	66.8	72.4	88.4	70.6	85.8	69.0	83.4	8.8	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.5	102.3	77.6	65.7	96.2	76.1	64.2	91.1	75.1	36.3	88.6	34.6	86.1	33.3	83.1	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.5	17.7	15.8	-7.4	99.4	8.5	2.4	-13.5	101.1	-18.5	102.5	-23.3	103.9	-29.5	105.6		
			-7.9	75.2	8.4	3.0	-13.9	77.3	-18.9	79.1	-23.6	80.7	-29.7	82.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.3	25.9	28.0	37.3	50.7	62.4	70.1	76.1	73.8	62.3	49.4	37.1	28.5		
	DBStd	19.66	10.40	10.55	7.43	7.84	7.59	6.40	5.07	6.04	7.29	9.28	9.26	10.09		
	HDD50	3038	747	617	399	83	5	0	0	0	5	124	391	667		
	HDD65	6302	1212	1037	860	430	143	23	0	6	134	489	836	1132		
	CDD50	3130	0	0	4	104	388	604	809	738	373	106	4	0		
	CDD65	921	0	0	0	1	62	177	344	279	52	6	0	0		
	CDH74	10304	0	0	0	30	728	1885	3913	3156	538	54	0	0		
	CDH80	4420	0	0	0	3	199	763	1889	1429	127	10	0	0		
	WSAvg	7.6	8.1	8.2	9.0	8.9	7.3	7.2	6.4	6.2	6.7	6.9	7.9	8.1		
	PrecAvg	16.0	1.1	0.9	1.3	1.1	2.0	2.0	1.4	1.1	1.3	1.3	1.3	1.2		
Precipitation	PrecMax	22.0	1.9	2.1	2.9	4.4	4.8	4.4	3.1	4.8	3.5	4.1	3.1	3.1		
	PrecMin	9.4	0.1	0.4	0.3	0.1	0.6	0.4	0.2	0.1	0.0	0.1	0.2	0.2		
	PrecStd	3.1	0.4	0.5	0.7	0.9	1.2	1.2	0.8	1.1	0.9	0.9	0.8	0.7		
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.6	51.4	63.5	78.3	89.1	96.6	99.6	98.7	87.5	80.3	60.5	49.6		
		MCWB	43.7	46.4	51.7	59.5	63.7	68.7	69.4	70.6	64.5	60.5	52.6	46.6		
	2%	DB	41.8	46.0	56.1	72.1	84.7	92.1	96.9	94.5	83.8	73.5	55.1	45.8		
		MCWB	39.9	41.6	46.7	57.8	63.0	67.0	69.5	68.3	63.3	58.8	50.5	43.4		
	5%	DB	39.1	42.1	52.2	68.6	81.8	88.2	93.4	91.3	80.4	67.8	51.5	43.0		
		MCWB	37.3	39.0	45.4	55.9	62.3	65.9	68.1	67.8	63.2	58.0	48.6	41.0		
	10%	DB	36.8	39.2	48.5	65.2	78.1	84.3	89.6	88.1	76.6	62.7	48.8	40.2		
		MCWB	35.4	37.0	43.0	53.7	61.5	64.7	67.2	67.2	61.4	56.0	46.6	38.7		
	0.4%	WB	43.5	46.9	52.2	62.2	68.2	75.1	75.5	73.8	69.9	64.9	54.0	46.8		
		MCDB	46.0	51.2	60.7	74.4	81.4	90.8	93.9	89.7	81.9	75.8	58.8	48.9		
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	39.9	42.3	48.6	59.7	65.8	71.2	72.3	72.0	66.9	61.5	51.3	43.7		
		MCDB	41.4	45.2	54.8	70.3	78.6	85.5	89.4	87.4	78.4	68.4	54.4	45.6		
	5%	WB	37.6	39.4	45.8	57.0	64.5	68.8	70.2	70.5	65.0	58.8	49.0	41.2		
		MCDB	38.9	41.6	50.8	65.3	77.2	82.3	86.3	85.2	75.2	66.2	51.3	42.7		
	10%	WB	35.4	37.3	43.5	54.7	62.8	66.9	68.7	69.0	63.3	56.4	46.7	38.9		
		MCDB	36.7	39.0	48.0	62.8	74.9	78.9	83.9	82.9	72.4	62.3	48.8	40.3		
Mean Daily Temperature Range	5% DB	MDBR	8.9	11.3	13.8	19.6	20.9	20.7	22.1	22.9	21.8	16.7	11.1	9.1		
		MCDBR	9.9	14.2	20.9	24.3	27.0	27.2	27.8	26.9	27.4	23.9	15.2	10.4		
		MCWBR	8.3	10.5	12.9	12.0	10.3	9.3	8.8	9.3	11.1	12.3	11.1	8.8		
		MCDBR	9.1	12.0	18.4	20.9	23.2	22.2	23.9	23.9	22.7	20.6	14.3	9.9		
	5% WB	MCWBR	7.9	9.4	12.5	10.9	10.6	9.3	9.2	9.8	11.0	12.0	10.6	8.7		
Clear-Sky Solar Irradiance	taub		0.342	0.375	0.410	0.455	0.428	0.426	0.441	0.446	0.421	0.384	0.355	0.349		
	taud		2.190	2.116	2.113	2.034	2.200	2.251	2.216	2.181	2.203	2.267	2.265	2.195		
	Ebn at Noon		226	243	254	253	266	267	261	254	248	239	221	208		
	Edh at Noon		28	36	43	50	44	42	43	43	39	31	26	25		
All-Sky Solar Radiation	RadAvg		304	567	941	1491	1893	2086	2045	1827	1339	800	378	238		
	RadStd		74	96	106	132	171	126	97	114	119	109	58	30		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.79	N/A	N/A	+1.82	-1.33	-1.26	N/A	N/A	+265	+167

Nomenclature: See separate page