

PRIMORSKO-AKHTARSK, Russian Federation

WMO: 348240

Lat: 46.033N

Lon: 38.150E

Elev: 4

StdP: 101.28

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.0	-10.9	-18.2	0.8	-13.3	-14.7	1.0	-10.3	8.3	-1.1	7.5	-3.6	3.2	70	0.419

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.1	34.1	21.7	32.2	21.7	30.5	21.4	24.7	29.9	23.7	29.0	22.7	28.1	3.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.1	17.9	28.0	21.9	16.6	27.1	20.9	15.6	26.1	75.1	30.1	71.0	29.0	67.2	28.1	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.6	6.3	5.4	-16.8	36.7	4.8	2.0	-20.2	38.1	-23.0	39.3	-25.6	40.4	-29.1	41.9
			-17.2	26.5	4.7	1.6	-20.6	27.6	-23.3	28.5	-25.9	29.4	-29.3	30.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.2	-0.7	0.4	5.2	11.7	18.2	22.4	25.3	24.4	18.9	12.2	5.9	1.7	(6)
(7)		DBStd	10.05	5.39	5.25	3.88	3.67	3.97	2.98	2.78	3.23	3.46	4.41	4.52	4.69	(7)
(8)		HDD10.0	1203	332	269	155	23	1	0	0	1	27	136	259		(8)
(9)		HDD18.3	2877	590	502	408	201	53	4	0	1	34	194	373	517	(9)
(10)		CDD10.0	2004	0	1	6	74	254	372	474	447	267	97	12	1	(10)
(11)		CDD18.3	637	0	0	0	2	49	127	216	189	50	5	0	0	(11)
(12)		CDH23.3	5161	0	0	0	12	324	838	2021	1712	236	19	0	0	(12)
(13)		CDH26.7	1791	0	0	0	1	93	234	777	632	51	3	0	0	(13)
(14)	Wind	WSAvg	2.6	2.8	2.9	3.1	2.8	2.4	2.3	2.3	2.3	2.4	2.6	2.7	(14)	
(15)	Precipitation	PrecAvg	565	50	39	35	37	48	49	65	50	43	38	47	64	(15)
(16)		PrecMax	737	144	90	75	93	144	145	268	175	183	112	116	113	(16)
(17)		PrecMin	402	4	4	4	1	9	6	4	9	1	2	4	10	(17)
(18)		PrecStd	102	37	24	20	22	32	33	55	43	43	24	29	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	11.2	14.4	17.7	25.0	31.6	33.4	36.6	37.2	31.1	26.0	19.1	13.0	(19)	
(20)		MCWB	7.4	9.4	10.8	15.9	19.7	21.9	23.0	22.0	21.3	18.5	13.6	9.4	(20)	
(21)		DB	8.8	11.2	14.8	21.8	29.2	31.2	34.4	34.0	27.8	22.8	15.6	10.6	(21)	
(22)		MCWB	6.5	7.9	9.4	14.2	19.1	21.5	21.9	21.2	19.0	16.7	12.3	8.6	(22)	
(23)		DB	6.8	8.7	12.6	19.6	26.9	29.3	32.6	31.9	25.9	20.2	13.6	8.9	(23)	
(24)		MCWB	5.3	6.3	8.4	13.0	18.2	21.0	22.1	21.6	18.7	15.8	11.1	7.3	(24)	
(25)		DB	5.4	6.5	10.7	17.5	24.6	27.5	30.8	29.9	24.2	18.2	11.7	7.4	(25)	
(26)		MCWB	4.3	4.8	7.4	12.2	17.9	20.3	21.8	21.3	18.1	14.6	9.8	6.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	8.2	10.2	11.3	16.7	21.7	24.8	26.9	25.6	23.3	19.7	14.3	10.2	(27)	
(28)		MCDWB	10.3	13.6	16.2	22.9	28.2	30.5	31.9	30.5	28.5	23.9	17.8	11.9	(28)	
(29)		WB	6.6	8.2	10.0	15.1	20.5	23.3	25.2	24.3	21.2	17.7	12.7	8.8	(29)	
(30)		MCDWB	8.4	10.7	14.1	20.3	26.4	28.5	30.3	29.5	25.4	21.3	15.1	10.5	(30)	
(31)		WB	5.5	6.5	8.8	13.8	19.5	22.2	24.0	23.4	20.1	16.3	11.3	7.4	(31)	
(32)		MCDWB	6.9	8.5	11.8	18.1	24.9	27.1	29.3	28.8	23.7	19.5	13.3	8.8	(32)	
(33)		WB	4.3	4.9	7.6	12.8	18.5	21.2	22.9	22.5	19.1	14.9	9.9	6.2	(33)	
(34)		MCDWB	5.4	6.4	10.3	16.7	23.5	26.0	28.2	28.0	22.6	17.5	11.5	7.4	(34)	
(35)	Mean Daily Temperature Range	MDBR	4.9	5.9	6.4	7.6	7.8	7.2	8.1	8.4	8.1	7.1	5.8	4.8	(35)	
(36)		MCDBR	6.5	8.9	10.0	11.2	11.3	10.2	11.1	11.1	10.6	10.1	8.9	7.1	(36)	
(37)		MCWBR	4.9	6.1	5.8	5.4	5.1	4.6	4.7	5.2	5.4	5.6	5.8	5.4	(37)	
(38)		MCDBR	6.2	8.3	9.2	9.0	9.6	8.0	8.9	8.7	8.9	9.0	8.5	6.8	(38)	
(39)		MCWBR	5.0	6.1	5.7	5.0	5.0	4.5	5.2	5.3	5.4	5.7	5.9	5.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.351	0.384	0.420	0.457	0.421	0.426	0.452	0.452	0.422	0.391	0.360	0.352	(40)	
(41)		taud	2.274	2.198	2.142	2.085	2.295	2.321	2.253	2.237	2.288	2.323	2.337	2.278	(41)	
(42)		Ebn at Noon	720	767	795	800	848	844	815	798	788	755	708	671	(42)	
(43)		Edh at Noon	83	108	131	152	127	125	132	129	113	95	78	75	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.08	1.97	3.10	4.79	6.12	6.59	6.55	5.85	4.27	2.62	1.36	0.90	(44)	
(45)		RadStd	0.17	0.28	0.30	0.46	0.53	0.40	0.31	0.39	0.33	0.31	0.19	0.13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	+0.62	N/A	N/A	N/A	N/A	N/A	N/A	-150	+125	+85

Nomenclature: See separate page