

DIVNOYE, Russian Federation

WMO: 348580

Lat: 45.917N

Lon: 43.350E

Elev: 86

StdP: 100.29

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.7	-14.1	-20.5	0.6	-17.2	-17.0	0.9	-13.5	7.8	-0.9	7.0	-0.3	2.1	90	0.459

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	36.7	20.0	35.0	19.6	33.2	19.4	22.3	30.9	21.5	30.1	20.7	29.1	2.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.0	14.8	24.9	19.0	13.9	24.4	18.1	13.1	23.8	65.8	30.9	62.8	30.2	60.3	28.9	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.0	6.1	5.3	DB	-19.6	39.2	5.0	2.0	-23.2	40.6	-26.1	41.8	-28.9	43.0	-32.6	44.4	(4)
(5)			WB	-20.0	24.1	4.9	1.8	-23.5	25.4	-26.4	26.5	-29.1	27.5	-32.7	28.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.4	-2.4	-1.3	4.1	11.2	17.7	22.9	25.6	24.7	18.5	11.4	4.2	-0.3	(6)
(7)		DBStd	10.93	5.75	5.88	4.20	4.07	3.90	3.62	2.96	3.41	4.08	4.87	4.88	5.21	(7)
(8)		HDD10.0	1463	383	318	187	32	1	0	0	0	1	43	179	319	(8)
(9)		HDD18.3	3183	642	551	442	214	59	6	0	2	48	220	423	577	(9)
(10)		CDD10.0	1986	0	0	4	69	241	388	483	456	254	85	6	0	(10)
(11)		CDD18.3	664	0	0	0	2	41	143	224	199	51	4	0	0	(11)
(12)		CDH23.3	7405	0	0	0	27	438	1534	2584	2323	467	32	0	0	(12)
(13)		CDH26.7	3473	0	0	0	4	133	699	1321	1168	141	7	0	0	(13)
(14)	Wind	WSAvg	2.4	2.7	2.8	3.0	2.7	2.3	2.2	2.0	2.1	2.1	2.5	2.7	(14)	
(15)	Precipitation	PrecAvg	444	29	22	35	35	52	57	39	35	37	38	34	31	(15)
(16)		PrecMax	579	53	49	72	122	116	125	97	80	89	102	74	104	(16)
(17)		PrecMin	324	1	5	7	3	7	16	5	1	1	1	7	3	(17)
(18)		PrecStd	73	14	12	20	26	28	28	25	23	24	27	20	20	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.2	12.8	19.1	26.5	32.8	36.7	38.8	39.2	33.4	27.1	17.4	11.2	(19)
(20)			MCWB	6.8	8.1	11.2	15.3	18.2	19.7	20.6	19.9	19.3	16.2	12.5	8.6	(20)
(21)		2%	DB	6.8	9.4	15.0	23.1	29.9	34.9	36.9	36.5	30.1	23.1	14.2	8.8	(21)
(22)			MCWB	5.0	6.3	9.3	14.5	17.3	19.2	20.4	19.8	18.2	15.7	11.0	7.1	(22)
(23)		5%	DB	5.1	6.9	12.5	20.7	27.9	33.0	35.2	34.7	28.1	20.5	12.0	7.1	(23)
(24)			MCWB	4.0	4.9	8.1	13.3	17.2	19.1	19.9	19.6	17.4	15.0	10.0	5.8	(24)
(25)		10%	DB	3.7	5.1	10.2	18.7	25.7	30.8	33.2	32.7	26.0	18.2	10.3	5.7	(25)
(26)			MCWB	2.8	3.7	6.8	12.2	16.7	18.8	19.6	19.3	16.9	13.8	8.8	4.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.3	9.0	12.0	16.5	20.7	23.5	23.4	22.1	17.9	13.0	9.1	(27)	
(28)			MCDWB	9.4	12.0	17.3	24.0	28.7	31.0	31.6	31.2	28.6	23.4	16.2	10.7	(28)
(29)		2%	WB	5.2	6.6	9.9	15.2	19.2	21.7	22.2	22.1	20.1	16.6	11.6	7.2	(29)
(30)			MCDWB	6.5	8.8	13.7	21.9	26.4	30.3	31.1	31.1	26.8	21.2	13.9	8.5	(30)
(31)		5%	WB	4.1	5.0	8.5	14.0	18.2	20.7	21.4	21.3	18.9	15.5	10.1	6.0	(31)
(32)			MCDWB	5.1	6.6	12.0	19.6	25.3	29.0	30.4	29.6	25.1	19.6	11.7	6.8	(32)
(33)		10%	WB	2.8	3.7	7.1	12.8	17.2	19.7	20.7	20.6	17.9	14.3	8.9	4.9	(33)
(34)			MCDWB	3.7	4.9	9.9	17.7	23.7	28.0	29.6	28.8	24.0	17.7	10.2	5.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.9	6.1	7.7	10.3	11.1	11.7	12.2	12.9	11.5	8.8	5.9	4.8	(35)
(36)			MCDBR	6.1	8.4	11.9	13.3	15.1	14.8	15.5	15.9	14.4	12.2	8.4	6.3	(36)
(37)			MCWBR	4.5	5.7	7.0	6.5	5.7	4.8	4.5	4.9	5.4	6.0	5.6	4.8	(37)
(38)		5% WB	MCDWR	5.7	7.7	10.7	11.8	12.4	12.6	12.5	12.8	12.0	10.8	7.6	5.6	(38)
(39)			MCWBR	4.4	5.4	6.8	6.2	5.4	5.1	4.6	4.9	5.2	5.8	5.3	4.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.345	0.379	0.414	0.459	0.429	0.432	0.450	0.454	0.428	0.390	0.358	0.351	(40)	
(41)		taud	2.210	2.139	2.113	2.032	2.209	2.247	2.206	2.176	2.202	2.270	2.283	2.214	(41)	
(42)		Ebn at Noon	722	770	800	798	841	838	817	795	779	754	706	666	(42)	
(43)		Edh at Noon	87	114	135	160	139	134	138	137	123	99	81	79	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.03	1.89	2.95	4.66	5.88	6.51	6.45	5.79	4.22	2.52	1.26	0.83	(44)	
(45)		RadStd	0.26	0.32	0.32	0.43	0.57	0.38	0.34	0.31	0.40	0.33	0.18	0.11	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.44	N/A	N/A	+0.92	-0.70	-0.64	N/A	N/A	+147	+93	(46)
(47)	Regional (8 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+135	N/A	(47)

Nomenclature: See separate page