

TAIPAQ, Kazakhstan

WMO: 354060

Lat: 49.050N

Lon: 51.867E

Elev: 2

StdP: 101.30

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-25.8	-22.6	-28.8	0.3	-25.5	-26.0	0.4	-22.1	12.2	-7.3	9.2	-8.2	1.5	50	0.507

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	37.6	20.3	35.9	19.7	34.2	19.1	21.7	33.9	20.6	33.0	19.8	32.0	2.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	12.9	25.7	16.3	11.6	25.3	15.0	10.7	25.3	63.0	33.8	59.2	33.1	56.6	32.0	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	8.2	6.5	DB	-27.8	39.9	4.6	1.7	-31.1	41.1	-33.8	42.1	-36.4	43.1	-39.7	44.3	(4)
(5)			WB	-27.8	22.9	4.5	1.8	-31.0	24.2	-33.6	25.3	-36.2	26.3	-39.4	27.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	-9.6	-8.5	-0.1	10.7	18.2	23.3	25.8	24.5	17.1	8.4	0.1	-6.0	(6)	
	DBStd	13.72	6.87	7.20	5.88	5.10	4.81	4.36	3.56	4.41	4.63	4.82	5.57	5.99	(7)	
	HDD10.0	2381	608	518	313	52	3	0	0	0	3	89	298	497	(8)	
	HDD18.3	4187	867	751	571	234	63	9	1	6	77	308	547	755	(9)	
	CDD10.0	1927	0	0	2	72	256	399	491	449	216	40	1	0	(10)	
	CDD18.3	689	0	0	0	4	58	158	233	197	39	1	0	0	(11)	
	CDH23.3	8687	0	0	0	62	711	1984	2947	2490	478	14	1	0	(12)	
	CDH26.7	4342	0	0	0	11	288	1004	1548	1315	173	2	0	0	(13)	
(14) Wind	WSAvg	2.4	2.4	2.6	2.8	2.8	2.5	2.3	2.1	2.2	2.1	2.2	2.1	2.6	(14)	
(15) Precipitation	PrecAvg	200	15	14	15	17	14	22	18	20	14	20	23	20	(15)	
	PrecMax	350	30	41	62	73	49	97	120	90	47	72	90	59	(16)	
	PrecMin	107	2	0	0	0	0	0	0	0	0	1	4	1	(17)	
	PrecStd	59	8	12	12	15	12	22	21	21	12	16	17	13	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.4	4.9	17.0	28.5	34.5	38.7	39.4	39.2	34.6	24.9	14.5	6.0	(19)	
		MCWB	2.1	2.3	9.5	16.1	18.7	20.4	20.8	20.8	19.1	14.5	10.0	3.4	(20)	
	2%	DB	1.6	2.6	13.1	25.1	32.2	36.4	37.5	37.5	30.8	22.2	11.3	3.9	(21)	
		MCWB	0.7	0.9	7.7	14.5	17.9	19.7	20.4	20.2	17.3	13.0	8.0	2.9	(22)	
	5%	DB	0.7	1.5	9.9	22.5	30.2	34.4	35.7	35.5	28.3	19.4	9.1	2.4	(23)	
		MCWB	-0.2	0.2	5.7	13.5	17.1	18.8	19.9	19.7	16.1	11.5	6.9	1.1	(24)	
	10%	DB	-0.4	0.6	7.2	19.9	27.6	32.4	33.9	33.5	26.0	16.6	7.0	0.9	(25)	
		MCWB	-1.3	-0.5	4.1	12.0	16.2	18.2	19.2	19.1	15.2	10.1	5.0	-0.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.7	2.7	10.5	17.1	20.2	22.4	23.9	23.8	20.4	16.0	11.1	4.7	(27)	
		MCDB	3.2	4.2	15.4	26.4	31.9	33.8	33.9	32.6	31.3	22.8	14.0	5.4	(28)	
	2%	WB	0.9	1.2	8.0	15.6	18.7	20.6	21.6	21.6	18.1	13.6	8.7	2.9	(29)	
		MCDB	1.6	2.3	12.6	24.1	29.8	33.3	34.1	33.4	29.4	20.4	10.7	3.8	(30)	
	5%	WB	-0.1	0.4	6.1	13.9	17.6	19.7	20.6	20.5	16.6	12.1	7.0	1.2	(31)	
		MCDB	0.7	1.4	9.5	21.2	28.1	32.2	32.9	33.2	26.9	18.3	9.0	2.1	(32)	
	10%	WB	-1.2	-0.4	4.4	12.4	16.6	18.8	19.8	19.6	15.5	10.7	5.2	0.0	(33)	
		MCDB	-0.4	0.6	7.1	19.1	26.5	30.5	31.5	32.0	24.8	15.7	6.9	0.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	7.9	8.2	11.6	12.1	12.4	12.2	13.0	12.7	10.7	7.0	5.8	(35)	
		MCDBR	4.6	6.5	11.8	14.9	15.1	14.9	14.2	15.1	16.2	15.2	9.7	5.5	(36)	
	5% WB	MCWBR	4.2	5.4	7.3	7.7	6.1	5.4	5.1	5.2	7.3	8.5	7.0	4.7	(37)	
		MCWBR	4.3	5.6	10.7	13.7	14.0	13.5	12.9	13.9	15.0	13.7	8.8	4.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.331	0.351	0.407	0.462	0.440	0.422	0.421	0.434	0.387	0.369	0.348	0.333	(40)	
		taud	2.077	2.033	2.066	1.993	2.134	2.253	2.269	2.205	2.293	2.264	2.220	2.130	(41)	
	Ebn at Noon		675	762	786	782	822	841	835	803	806	746	663	618	(42)	
		Edh at Noon	89	118	136	163	147	132	128	130	108	93	78	75	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.16	2.26	3.36	4.74	6.13	6.76	6.55	5.70	4.20	2.47	1.20	0.77	(44)	
	RadStd		0.23	0.37	0.41	0.34	0.47	0.53	0.36	0.31	0.33	0.28	0.15	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+1.32	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page