

MAYKOP, Russian Federation

WMO: 370210

Lat: 44.617N

Lon: 40.083E

Elev: 720

StdP: 14.32

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.0	12.2	0.0	5.6	5.3	6.9	8.0	13.3	23.4	43.6	21.3	44.3	5.5	100	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.7	94.7	72.8	91.0	70.9	87.7	69.5	75.2	88.4	73.5	86.3	71.8	83.3	6.8	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.4	119.1	82.6	69.5	111.3	80.7	67.9	105.2	78.9	39.2	88.9	37.5	85.7	36.0	83.7	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.7	15.8	13.0	-3.5	98.5	6.0	2.9	-7.8	100.5	-11.3	102.2	-14.7	103.9	-19.0	106.0		
			-1.7	77.4	8.8	3.1	-8.0	79.6	-13.2	81.4	-18.1	83.2	-24.5	85.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	54.9	33.7	35.8	43.2	53.2	64.3	71.0	74.9	75.6	66.4	55.6	45.2	38.3
	DBStd	16.84	10.98	11.69	8.13	7.00	6.50	4.94	4.70	5.47	6.18	8.62	9.23	9.19
	HDD50	1810	506	408	238	41	1	0	0	0	1	44	197	374
	HDD65	4710	970	818	676	358	92	7	1	1	54	309	595	829
	CDD50	3590	2	10	28	137	444	630	773	795	492	216	53	10
	CDD65	1014	0	0	0	4	70	187	309	331	96	16	1	0
	CDH74	9400	0	0	5	79	664	1538	2849	3329	817	112	7	0
	CDH80	3649	0	0	1	7	172	513	1151	1550	236	19	0	0
Wind	WSAvg	5.7	5.6	6.1	7.1	6.8	5.6	5.5	5.3	5.4	5.1	5.2	5.6	5.4
Precipitation	PrecAvg	30.5	2.4	1.6	2.0	2.3	2.9	3.7	2.6	2.4	2.4	2.6	2.9	2.6
	PrecMax	42.3	5.7	4.9	5.9	6.8	5.0	11.2	9.5	6.5	5.9	7.7	8.5	5.7
	PrecMin	18.9	0.2	0.0	0.0	0.2	0.8	0.1	0.2	0.1	0.8	0.1	0.6	0.6
	PrecStd	5.6	1.3	1.1	1.1	1.2	1.2	2.3	1.8	1.6	1.3	1.5	1.7	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.6	66.1	72.1	80.7	88.1	93.1	96.9	100.2	91.7	82.6	74.3	64.5
		MCWB	47.4	50.8	53.4	60.8	69.8	70.0	75.3	73.3	67.4	63.0	55.7	51.2
	2%	DB	53.6	60.4	64.8	75.6	84.5	89.3	93.1	96.2	85.6	76.9	67.5	57.9
		MCWB	45.3	48.1	50.3	58.8	66.9	70.6	73.2	72.4	65.1	61.3	53.1	47.5
	5%	DB	49.9	54.2	60.4	70.2	80.9	85.9	89.5	91.6	82.3	71.8	62.2	53.6
		MCWB	43.1	45.8	48.2	56.7	65.5	70.1	71.2	70.6	64.7	59.3	51.1	45.8
	10%	DB	46.2	49.8	55.7	65.8	77.3	82.3	86.1	88.1	78.7	67.7	57.1	49.7
		MCWB	41.0	43.5	46.5	54.7	64.1	68.0	70.3	69.0	63.1	58.2	49.1	43.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.1	52.1	54.7	62.2	73.1	75.1	77.5	78.1	70.3	64.9	57.3	53.0
		MCDB	56.3	62.0	68.5	76.1	84.4	86.9	92.6	92.1	83.1	76.2	70.4	61.6
	2%	WB	45.9	49.0	51.4	59.5	69.6	72.9	75.3	75.4	68.1	63.1	54.7	49.0
		MCDB	51.6	58.1	61.5	72.3	81.9	85.1	88.2	89.9	78.9	73.8	64.8	56.6
	5%	WB	43.6	46.3	49.4	57.6	66.9	71.3	73.7	73.2	66.7	61.1	52.1	46.0
		MCDB	48.5	53.7	57.9	69.1	78.3	82.7	86.1	86.7	77.2	69.8	60.2	51.7
	10%	WB	41.3	43.5	47.3	55.6	64.9	69.6	71.9	71.5	65.2	59.2	49.7	44.0
		MCDB	45.6	49.5	54.6	63.9	75.0	80.0	82.3	83.8	75.0	66.2	55.4	49.0
Mean Daily Temperature Range	5% DB	MDBR	13.2	15.1	16.0	18.1	19.4	18.7	19.8	22.7	20.2	17.1	15.8	13.4
		MCDBR	17.3	21.1	24.4	24.6	24.9	23.3	24.2	27.0	26.1	23.5	23.0	18.8
		MCWBR	10.6	12.3	12.9	12.5	12.0	10.4	9.3	9.4	9.9	11.0	12.1	11.1
	5% WB	MCDBR	16.0	20.2	21.2	21.7	22.4	20.2	21.4	23.1	20.8	20.0	20.6	16.6
		MCWBR	10.5	12.1	12.1	11.8	12.2	10.5	9.6	9.8	9.2	10.2	11.5	10.7
Clear-Sky Solar Irradiance	taub	0.334	0.365	0.414	0.458	0.426	0.431	0.453	0.451	0.410	0.383	0.348	0.333	
	taud	2.317	2.226	2.129	2.049	2.227	2.255	2.212	2.216	2.302	2.337	2.381	2.341	
	Ebn at Noon	243	255	256	255	268	267	259	255	256	246	237	230	
	Edh at Noon	26	34	43	50	43	43	44	42	36	30	24	23	
All-Sky Solar Radiation	RadAvg	449	727	987	1453	1774	1933	1990	1779	1327	857	537	381	
	RadStd	52	98	87	157	209	133	108	115	152	100	62	44	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.92	N/A	N/A	N/A	N/A	N/A	N/A	-220	+212	N/A

Nomenclature: See separate page