

MAYKOP, Russian Federation

WMO: 370210

Lat: 44.617N

Lon: 40.083E

Elev: 219

StdP: 98.72

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.0	-11.0	-17.8	0.8	-14.8	-14.0	1.1	-10.4	10.5	6.4	9.5	6.8	2.5	100	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.6	34.8	22.7	32.8	21.6	30.9	20.8	24.0	31.4	23.0	30.2	22.1	28.5	3.0	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	17.0	28.1	20.8	15.9	27.0	19.9	15.0	26.1	73.3	31.6	69.3	29.8	65.7	28.7	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.8	7.0	5.8	DB	-19.7	36.9	3.3	1.6	-22.1	38.1	-24.1	39.0	-25.9	39.9	-28.4	41.1
			WB	-18.7	25.2	4.9	1.7	-22.2	26.4	-25.1	27.5	-27.8	28.4	-31.4	29.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.7	1.0	2.1	6.2	11.8	17.9	21.7	23.9	24.2	19.1	13.1	7.3	3.5	(6)
(7)		DBStd	9.35	6.10	6.50	4.52	3.89	3.61	2.75	2.61	3.04	3.44	4.79	5.13	5.10	(7)
(8)		HDD10.0	1006	281	227	132	23	1	0	0	1	24	109	208		(8)
(9)		HDD18.3	2617	539	454	376	199	51	4	1	1	30	172	331	461	(9)
(10)		CDD10.0	1994	1	6	16	76	247	350	429	442	273	120	29	6	(10)
(11)		CDD18.3	563	0	0	0	2	39	104	172	184	53	9	1	0	(11)
(12)		CDH23.3	5222	0	0	3	44	369	854	1583	1849	454	62	4	0	(12)
(13)		CDH26.7	2027	0	0	1	4	96	285	639	861	131	11	0	0	(13)
(14)	Wind	WSAvg	2.6	2.5	2.7	3.2	3.1	2.5	2.5	2.4	2.3	2.3	2.5	2.4	(14)	
(15)	Precipitation	PrecAvg	775	60	41	52	59	74	94	66	62	61	66	74	66	(15)
(16)		PrecMax	1074	146	125	149	173	128	285	241	166	150	195	216	146	(16)
(17)		PrecMin	480	5	0	1	4	21	3	6	3	20	3	15	14	(17)
(18)		PrecStd	143	32	29	29	31	31	59	46	41	34	39	44	36	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.8	18.9	22.3	27.1	31.1	33.9	36.1	37.9	33.2	28.1	23.5	18.0	(19)
(20)		MCWB	8.6	10.5	11.9	16.0	21.0	21.1	24.1	23.0	19.6	17.2	13.2	10.7	(20)	
(21)		2%	DB	12.0	15.8	18.2	24.2	29.2	31.8	33.9	35.6	29.8	25.0	19.7	14.4	(21)
(22)		MCWB	7.4	8.9	10.2	14.9	19.4	21.4	22.9	22.5	18.4	16.3	11.7	8.6	(22)	
(23)		5%	DB	9.9	12.3	15.8	21.2	27.2	29.9	32.0	33.1	27.9	22.1	16.8	12.0	(23)
(24)		MCWB	6.2	7.6	9.0	13.7	18.6	21.2	21.8	21.5	18.2	15.2	10.6	7.7	(24)	
(25)		10%	DB	7.9	9.9	13.2	18.8	25.2	28.0	30.1	31.2	26.0	19.8	13.9	9.9	(25)
(26)		MCWB	5.0	6.4	8.0	12.6	17.8	20.0	21.3	20.5	17.3	14.6	9.5	6.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	11.1	12.6	16.8	22.8	23.9	25.3	25.6	21.3	18.3	14.0	11.7	(27)
(28)		MADB	13.5	16.6	20.3	24.5	29.1	30.5	33.7	33.4	28.4	24.6	21.3	16.4	(28)	
(29)		2%	WB	7.7	9.5	10.8	15.3	20.9	22.7	24.1	24.1	20.1	17.3	12.6	9.4	(29)
(30)		MADB	10.9	14.5	16.4	22.4	27.7	29.5	31.2	32.2	26.1	23.2	18.2	13.6	(30)	
(31)		5%	WB	6.5	8.0	9.7	14.2	19.4	21.8	23.2	22.9	19.3	16.2	11.2	7.8	(31)
(32)		MADB	9.1	12.1	14.4	20.6	25.7	28.1	30.0	30.4	25.1	21.0	15.7	11.0	(32)	
(33)		10%	WB	5.2	6.4	8.5	13.1	18.3	20.9	22.2	21.9	18.4	15.1	9.8	6.7	(33)
(34)		MADB	7.6	9.7	12.6	17.7	23.9	26.7	28.0	28.8	23.9	19.0	13.0	9.4	(34)	
(35)	Mean Daily Temperature Range	MDBR	7.3	8.4	8.9	10.1	10.8	10.4	11.0	12.6	11.2	9.5	8.8	7.5	(35)	
(36)		5% DB	MADB	9.6	11.7	13.6	13.7	13.8	13.0	13.4	15.0	14.5	13.1	12.8	10.4	(36)
(37)		MCWBR	5.9	6.8	7.2	7.0	6.6	5.8	5.1	5.2	5.5	6.1	6.7	6.2	(37)	
(38)		5% WB	MADB	8.9	11.2	11.8	12.1	12.5	11.2	11.9	12.8	11.6	11.1	11.4	9.2	(38)
(39)		MCWBR	5.8	6.7	6.7	6.5	6.8	5.8	5.3	5.5	5.1	5.7	6.4	5.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.334	0.365	0.414	0.458	0.426	0.431	0.453	0.451	0.410	0.383	0.348	0.333	(40)	
(41)		taud	2.317	2.226	2.129	2.049	2.227	2.255	2.212	2.216	2.302	2.337	2.381	2.341	(41)	
(42)		Ebn at Noon	765	803	808	804	846	842	817	803	807	776	746	725	(42)	
(43)		Edh at Noon	82	107	135	159	137	134	138	133	113	95	77	73	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.41	2.29	3.11	4.58	5.59	6.09	6.28	5.61	4.18	2.70	1.69	1.20	(44)	
(45)		RadStd	0.17	0.31	0.28	0.49	0.66	0.42	0.34	0.36	0.48	0.32	0.20	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (6 neighbors)	+0.51	N/A	N/A	N/A	N/A	N/A	N/A	-122	+118	N/A

Nomenclature: See separate page