

MOZDOK, Russian Federation

WMO: 371450

Lat: 43.733N

Lon: 44.667E

Elev: 447

StdP: 14.46

Time Zone: 3.00 (E03)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.2	8.3	-0.4	5.5	2.4	5.3	7.3	8.5	17.2	42.2	12.6	30.5	3.0	270	0.434

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.6	94.5	73.3	91.5	73.0	88.0	71.8	76.3	89.5	74.7	87.6	73.1	85.4	5.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.3	121.4	84.0	70.5	114.2	82.2	69.0	108.2	80.3	40.1	89.8	38.5	88.0	37.1	85.8	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.5	11.1	9.5	DB	-1.6	97.1	8.4	4.0	-7.6	100.0	-12.5	102.3	-17.2	104.6	-23.3	107.5	(4)
(5)			WB	-1.3	80.7	8.2	2.0	-7.2	82.2	-12.0	83.3	-16.6	84.4	-22.5	85.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.8	29.6	28.6	39.6	52.7	61.6	70.8	76.5	74.6	64.3	53.2	38.7	29.7	(6)	
	DBStd	18.73	7.62	9.82	6.99	6.36	6.35	5.75	5.05	5.15	6.44	7.47	9.91	8.34	(7)	
	HDD50	2640	633	599	331	41	5	0	0	0	1	53	347	630	(8)	
	HDD65	5773	1098	1019	786	371	141	15	1	2	89	368	788	1095	(9)	
	CDD50	3296	0	0	10	122	365	624	821	762	430	153	9	0	(10)	
	CDD65	953	0	0	0	2	35	189	358	299	67	3	0	0	(11)	
	CDH74	9387	0	0	1	56	382	1801	3811	2776	504	56	0	0	(12)	
	CDH80	3850	0	0	0	12	67	673	1820	1166	104	8	0	0	(13)	
(14) Wind	WSAvg	4.1	3.9	4.1	4.8	4.7	4.6	4.3	4.2	4.0	3.8	3.5	3.7	3.5	(14)	
(15) Precipitation	PrecAvg	26.8	1.1	1.2	1.9	2.7	3.5	4.4	2.9	2.3	2.1	2.0	1.6	1.2	(15)	
	PrecMax	35.5	2.2	2.4	3.2	5.0	6.1	10.5	6.1	5.5	6.3	4.4	4.0	2.3	(16)	
	PrecMin	18.8	0.2	0.6	0.9	1.1	0.6	1.0	0.6	0.3	0.3	0.4	0.1	0.1	(17)	
	PrecStd	5.0	0.5	0.5	0.6	0.9	1.5	1.9	1.5	1.3	1.3	1.1	1.0	0.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.1	57.6	69.9	79.7	85.2	94.2	99.3	97.5	87.4	79.7	63.3	50.7	(19)	
		MCWB	43.6	47.9	55.6	64.6	69.4	73.2	74.7	75.0	72.4	62.9	56.7	46.6	(20)	
	2%	DB	44.0	48.0	62.8	73.9	81.7	90.5	96.0	93.5	83.8	74.0	58.0	45.5	(21)	
		MCWB	40.3	42.9	51.9	60.7	67.4	72.6	73.1	74.1	70.5	63.4	52.9	43.2	(22)	
	5%	DB	40.7	43.1	56.6	69.6	78.4	86.7	92.7	89.7	80.6	69.7	53.8	42.1	(23)	
		MCWB	38.1	39.4	48.8	58.2	65.6	71.1	72.7	73.4	68.3	61.6	50.7	40.5	(24)	
	10%	DB	38.2	39.4	51.5	65.6	74.9	83.7	89.3	86.2	76.9	64.9	50.2	39.8	(25)	
		MCWB	36.5	37.3	46.0	56.0	64.0	69.7	71.7	71.8	66.6	58.9	47.9	38.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.4	48.6	57.0	66.2	72.6	77.3	78.3	78.4	75.1	67.4	57.9	46.9	(27)	
		MCDB	48.4	56.7	68.0	78.0	82.2	88.7	93.4	90.1	84.2	73.1	62.2	49.9	(28)	
	2%	WB	40.7	43.2	52.7	61.8	69.5	74.5	76.1	76.4	71.9	64.4	53.6	43.4	(29)	
		MCDB	43.5	47.6	62.1	72.4	78.7	86.8	91.0	88.7	81.8	72.2	56.9	45.0	(30)	
	5%	WB	38.6	39.9	49.3	59.2	66.9	72.7	74.5	74.7	69.8	61.8	50.9	40.7	(31)	
		MCDB	40.6	42.5	55.9	68.1	76.2	84.2	88.5	87.1	78.8	68.6	53.4	41.8	(32)	
	10%	WB	36.7	37.5	46.0	56.8	64.5	70.8	72.9	72.8	67.4	59.3	48.0	38.4	(33)	
		MCDB	38.1	39.2	51.0	64.1	73.2	81.5	86.1	84.5	74.7	64.4	50.2	39.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.1	11.8	14.0	18.5	19.4	20.0	21.6	19.8	18.8	17.7	11.3	9.4	(35)	
		MCDBR	15.3	18.8	27.1	26.5	25.9	25.9	27.6	25.6	25.2	26.6	19.6	13.8	(36)	
		MCWBR	11.5	13.7	17.0	14.7	13.7	11.4	10.1	10.1	12.9	15.8	14.1	11.0	(37)	
	5% WB	MCDBR	14.1	17.2	25.5	23.9	23.8	24.3	25.4	23.9	22.9	24.6	17.2	12.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.347	0.382	0.426	0.482	0.451	0.454	0.492	0.493	0.448	0.402	0.364	0.350	(40)	
		taud	2.266	2.176	2.096	1.981	2.156	2.202	2.108	2.097	2.183	2.265	2.307	2.257	(41)	
	Ebn at Noon		239	250	254	249	262	261	249	244	245	241	231	224	(42)	
		Edh at Noon	28	36	45	54	47	45	49	48	41	33	27	26	(43)	
(44) All-Sky Solar Radiation	RadAvg		413	672	960	1413	1744	1968	1949	1744	1290	781	471	346	(44)	
	RadStd		82	138	116	172	178	126	123	128	132	110	77	56	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page