

MOZDOK, Russian Federation

WMO: 371450

Lat: 43.733N

Lon: 44.667E

Elev: 136

StdP: 99.70

Time Zone: 3.00 (E03)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-16.6	-13.2	-18.0	0.8	-16.5	-14.8	1.0	-13.1	7.7	5.7	5.7	-0.8	1.3	270	0.434

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	34.7	23.0	33.0	22.8	31.1	22.1	24.6	31.9	23.7	30.9	22.8	29.7	2.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.4	17.3	28.9	21.4	16.3	27.9	20.5	15.5	26.8	75.4	32.1	71.8	31.1	68.3	29.9	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.6	5.0	4.2	-18.7	36.2	4.6	2.2	-22.0	37.8	-24.7	39.1	-27.3	40.3	-30.7	41.9		
(5)			-18.5	27.1	4.6	1.1	-21.8	27.9	-24.4	28.5	-27.0	29.1	-30.3	29.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	-1.4	-1.9	4.2	11.5	16.4	21.6	24.7	23.7	17.9	11.8	3.7	-1.3		
	DBStd	10.40	4.24	5.45	3.88	3.54	3.53	3.19	2.81	2.86	3.58	4.15	5.51	4.63		
	HDD10.0	1467	352	333	184	23	3	0	0	0	1	29	193	350		
	HDD18.3	3207	610	566	437	206	78	8	1	1	49	204	438	608		
	CDD10.0	1831	0	0	6	68	203	347	456	423	239	85	5	0		
	CDD18.3	529	0	0	0	1	19	105	199	166	37	2	0	0		
	CDH23.3	5215	0	0	1	31	212	1001	2117	1542	280	31	0	0		
	CDH26.7	2139	0	0	0	7	37	374	1011	648	58	4	0	0		
(14) Wind	WSAvg	1.8	1.7	1.8	2.2	2.1	2.1	1.9	1.9	1.8	1.7	1.6	1.6	1.6		
(15) Precipitation	PrecAvg	681	28	30	47	68	88	113	73	58	54	52	40	30		
	PrecMax	901	55	61	82	127	155	267	155	139	159	111	101	59		
	PrecMin	478	6	15	24	28	15	25	14	7	8	10	3	3		
	PrecStd	126	13	13	16	23	39	49	38	33	34	27	25	15		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.5	14.2	21.0	26.5	29.6	34.6	37.4	36.4	30.8	26.5	17.4	10.4		
		MCWB	6.4	8.8	13.1	18.1	20.8	22.9	23.7	23.9	22.5	17.2	13.7	8.1		
	2%	DB	6.7	8.9	17.1	23.3	27.6	32.5	35.5	34.2	28.8	23.4	14.5	7.5		
		MCWB	4.6	6.1	11.1	16.0	19.7	22.6	22.9	23.4	21.4	17.4	11.6	6.2		
	5%	DB	4.8	6.2	13.7	20.9	25.8	30.4	33.7	32.1	27.0	20.9	12.1	5.6		
		MCWB	3.4	4.1	9.3	14.5	18.7	21.7	22.6	23.0	20.2	16.4	10.4	4.7		
	10%	DB	3.4	4.1	10.8	18.7	23.8	28.7	31.8	30.1	24.9	18.3	10.1	4.3		
		MCWB	2.5	2.9	7.8	13.3	17.8	20.9	22.0	22.1	19.2	15.0	8.9	3.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.9	9.2	13.9	19.0	22.6	25.1	25.7	25.8	24.0	19.7	14.4	8.3		
		MCDB	9.1	13.7	20.0	25.6	27.9	31.5	34.1	32.3	29.0	22.8	16.8	9.9		
	2%	WB	4.8	6.2	11.5	16.6	20.9	23.6	24.5	24.7	22.2	18.0	12.0	6.3		
		MCDB	6.4	8.7	16.7	22.4	26.0	30.4	32.8	31.5	27.7	22.3	13.8	7.2		
	5%	WB	3.7	4.4	9.6	15.1	19.4	22.6	23.6	23.7	21.0	16.6	10.5	4.8		
		MCDB	4.8	5.8	13.3	20.1	24.6	29.0	31.4	30.6	26.0	20.3	11.9	5.5		
	10%	WB	2.6	3.0	7.8	13.8	18.1	21.5	22.7	22.7	19.7	15.1	8.9	3.5		
		MCDB	3.4	4.0	10.5	17.9	22.9	27.5	30.0	29.2	23.7	18.0	10.1	4.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.6	6.6	7.8	10.3	10.8	11.1	12.0	11.0	10.5	9.8	6.3	5.2		
		MCDBR	8.5	10.4	15.0	14.7	14.4	14.4	15.3	14.2	14.0	14.8	10.9	7.7		
	5% WB	MCWBR	6.4	7.6	9.4	8.2	7.6	6.3	5.6	5.6	7.2	8.8	7.8	6.1		
		MCWBR	7.8	9.6	14.2	13.3	13.2	13.5	14.1	13.3	12.7	13.7	9.6	6.8		
(40) Clear-Sky Solar Irradiance	taub	taub	0.347	0.382	0.426	0.482	0.451	0.454	0.492	0.493	0.448	0.402	0.364	0.350		
		taud	2.266	2.176	2.096	1.981	2.156	2.202	2.108	2.097	2.183	2.265	2.307	2.257		
	Ebn at Noon	Ebn at Noon	754	788	800	784	826	823	785	768	771	759	729	706		
		Edh at Noon	88	114	141	171	148	142	154	151	128	104	84	82		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.30	2.12	3.03	4.46	5.50	6.21	6.14	5.50	4.07	2.46	1.49	1.09		
	RadStd	RadStd	0.26	0.43	0.36	0.54	0.56	0.40	0.39	0.40	0.41	0.35	0.24	0.17		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (8 neighbors)	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page