

AMBROLAURI, Georgia

WMO: 373080

Lat: 42.527N

Lon: 43.139E

Elev: 1785

StdP: 13.77

Time Zone: 4.00 (E04)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.2	21.4	10.0	9.8	28.5	13.1	11.4	29.0	21.4	41.0	19.3	41.2	1.5	90	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	23.3	93.6	68.1	90.2	67.8	87.0	67.4	72.9	85.6	71.1	83.3	69.4	81.0	10.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.1	114.4	79.1	67.4	107.5	76.4	65.9	102.1	74.3	37.8	85.8	36.1	83.2	34.6	81.0	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.0	17.9	15.5	13.6	99.0	6.1	3.3	9.2	101.4	5.6	103.3	2.2	105.1	-2.3	107.5		
(5)			14.3	75.0	3.9	2.1	11.5	76.5	9.3	77.7	7.1	78.9	4.3	80.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.3	34.4	39.6	45.7	54.6	62.4	70.2	74.2	74.8	67.0	57.5	45.5	36.8		
	DBStd	15.27	5.56	6.72	6.87	6.78	5.38	4.79	4.95	5.00	6.37	5.49	6.26	6.87		
	HDD50	1552	482	295	168	31	1	0	0	0	1	6	157	411		
	HDD65	4450	947	712	598	317	112	10	2	3	52	237	586	874		
	CDD50	3492	0	3	35	169	387	606	749	769	511	240	21	2		
	CDD65	916	0	0	0	5	33	166	286	307	113	6	0	0		
	CDH74	7894	0	0	2	97	403	1346	2329	2770	880	67	0	0		
	CDH80	3080	0	0	0	10	97	477	959	1264	267	6	0	0		
(14) Wind	WSAvg	5.4	3.4	5.3	6.2	6.4	6.3	6.5	6.1	6.5	5.7	4.6	3.8	3.4		
(15) Precipitation	PrecAvg	48.9	3.9	2.9	3.9	4.1	4.5	4.3	4.0	3.7	4.2	5.0	4.1	4.1		
	PrecMax	60.2	7.8	4.8	10.5	6.3	7.3	9.0	8.2	7.2	7.6	10.7	9.8	14.5		
	PrecMin	37.8	1.2	1.3	1.1	2.0	1.7	1.3	1.4	1.0	0.4	1.5	1.1	1.0		
	PrecStd	6.0	1.6	1.0	2.1	1.2	1.5	1.6	1.6	1.4	1.8	2.5	2.2	2.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.1	64.2	72.1	81.1	87.2	92.7	97.1	97.9	91.6	79.9	67.3	60.4		
		MCWB	41.7	45.4	51.9	58.1	64.9	68.3	71.0	68.6	64.8	61.6	50.9	47.3		
	2%	DB	48.5	58.3	66.5	76.7	82.6	88.8	92.9	94.4	86.2	75.4	63.0	52.9		
		MCWB	40.4	43.9	49.6	56.0	62.7	67.6	69.5	67.3	64.8	59.7	49.0	43.3		
	5%	DB	45.1	53.7	62.1	72.7	78.5	85.7	89.2	91.2	82.7	71.9	59.2	49.4		
		MCWB	38.7	41.9	47.4	53.7	61.1	66.7	69.2	67.1	63.4	57.9	47.7	42.0		
	10%	DB	42.2	49.4	57.7	68.4	74.5	82.1	85.4	87.2	79.2	68.0	55.2	46.0		
		MCWB	37.3	40.2	45.7	52.4	59.7	65.5	68.1	67.4	62.5	56.2	45.9	40.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.5	47.5	53.5	61.6	67.3	73.3	75.8	74.6	69.6	63.6	52.9	48.0		
		MCDB	49.3	58.5	68.3	75.4	83.8	86.7	89.5	87.9	84.3	75.1	61.4	55.7		
	2%	WB	41.8	45.2	50.5	57.7	64.6	70.2	73.6	72.4	66.9	61.1	50.8	45.1		
		MCDB	46.1	54.7	62.3	71.2	78.3	83.4	85.8	85.5	79.2	71.6	58.8	50.8		
	5%	WB	39.8	43.2	48.5	55.6	62.4	68.5	71.6	70.7	65.5	59.2	49.1	42.9		
		MCDB	44.0	51.4	59.0	67.8	74.8	81.5	83.8	82.9	77.3	68.9	56.1	47.6		
	10%	WB	37.9	41.5	46.7	53.6	60.7	66.7	69.9	68.9	64.1	57.5	47.4	41.2		
		MCDB	41.4	48.0	55.2	66.5	71.4	78.6	80.7	80.9	74.9	65.8	53.6	45.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.1	16.6	17.5	21.5	20.6	21.1	19.8	23.3	21.1	20.9	19.2	14.4		
		MCDBR	18.3	25.6	27.9	30.7	29.2	27.7	27.1	29.9	28.3	27.8	27.0	19.3		
		MCWBR	11.2	13.3	13.3	13.4	12.6	10.8	9.9	9.5	9.5	13.0	14.4	11.2		
	5% WB	MCDBR	15.4	22.2	23.2	27.1	25.6	24.5	23.4	24.6	23.5	25.5	22.4	15.8		
		MCWBR	10.1	12.1	12.2	12.7	12.3	11.5	10.2	9.9	9.1	12.9	12.5	10.0		
(40) Clear-Sky Solar Irradiance	taub		0.311	0.347	0.406	0.461	0.429	0.417	0.447	0.447	0.389	0.377	0.331	0.306		
	taud		2.259	2.144	2.045	2.009	2.201	2.298	2.237	2.235	2.379	2.356	2.412	2.339		
	Ebn at Noon		258	265	261	256	269	272	262	258	267	254	252	250		
	Edh at Noon		29	38	47	53	45	41	43	42	34	30	25	24		
(44) All-Sky Solar Radiation	RadAvg		498	762	1015	1356	1664	1841	1846	1728	1381	933	621	443		
	RadStd		76	107	102	177	175	135	169	132	137	108	81	46		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page