

PASANAURI, Georgia

WMO: 374320

Lat: 42.3558N

Lon: 44.6859E

Elev: 3516

StdP: 12.92

Time Zone: 4.00 (E04)

Period: 86-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.3	12.3	2.7	7.2	10.9	6.1	8.6	14.8	12.1	29.6	10.3	31.4	1.3	340	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.5	84.9	65.2	81.8	64.6	78.8	63.9	68.6	79.4	67.0	77.2	65.4	75.2	2.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.2	106.3	73.4	63.6	100.4	71.8	62.1	94.9	70.1	35.1	79.7	33.6	77.3	32.3	75.3	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.9	9.9	7.7	2.8	90.1	3.3	4.4	0.5	93.2	-1.4	95.8	-3.3	98.2	-5.6	101.4
			2.1	71.5	3.2	3.4	-0.2	74.0	-2.1	76.0	-4.0	77.9	-6.3	80.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.4	26.9	30.6	38.8	48.8	55.5	63.2	67.8	67.5	60.2	50.4	39.3	30.6	(6)
	DBStd	15.38	6.31	6.73	6.58	6.32	5.44	4.78	4.17	4.69	5.60	5.48	6.41	7.02	(7)
	HDD50	2715	716	543	351	95	16	0	0	0	4	62	325	603	(8)
	HDD65	6331	1181	963	813	485	298	89	21	30	160	452	771	1068	(9)
	CDD50	2127	0	0	3	60	185	396	553	541	310	75	4	0	(10)
	CDD65	270	0	0	0	0	3	35	109	106	17	0	0	0	(11)
	CDH74	2071	0	0	0	6	35	296	750	818	165	1	0	0	(12)
	CDH80	481	0	0	0	0	2	42	162	245	30	0	0	0	(13)
(14) Wind	WSAvg	1.9	1.5	2.0	2.3	2.3	2.7	2.1	1.9	1.9	1.9	1.8	1.5	1.3	(14)
(15) Precipitation	PrecAvg	59.3	3.6	3.7	4.4	5.9	7.3	7.0	6.5	4.7	4.2	3.7	3.8	4.1	(15)
	PrecMax	86.3	15.0	9.2	8.3	14.0	13.7	12.9	11.7	10.6	11.1	7.5	10.7	9.2	(16)
	PrecMin	42.8	0.4	0.3	0.5	2.7	2.4	3.2	0.9	0.9	1.2	0.6	0.3	0.8	(17)
	PrecStd	10.8	3.7	2.6	2.0	2.6	3.1	2.2	3.1	2.2	2.2	2.1	2.4	2.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.7	52.1	63.0	73.8	78.2	84.3	87.5	90.3	83.9	70.9	61.9	52.8	(19)
		MCWB	36.2	40.6	48.1	58.2	61.5	62.4	66.5	68.2	64.4	56.2	48.6	43.4	(20)
	2%	DB	40.6	47.6	57.7	68.9	73.3	80.5	84.3	85.8	78.2	67.2	56.0	46.7	(21)
		MCWB	34.2	39.0	45.9	54.8	57.9	63.4	65.7	65.5	61.9	54.5	46.1	40.0	(22)
	5%	DB	38.2	43.8	53.5	65.0	69.8	77.4	81.4	82.1	74.6	63.8	52.3	42.9	(23)
		MCWB	33.1	36.8	43.3	51.6	56.4	62.1	65.3	64.4	60.5	52.9	44.4	37.4	(24)
	10%	DB	35.8	40.2	49.4	61.1	66.4	74.0	78.3	78.2	71.0	60.2	49.0	39.6	(25)
		MCWB	31.9	34.8	41.3	50.0	55.1	61.0	64.8	64.1	58.9	51.6	43.0	35.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.7	42.6	51.1	62.3	64.8	68.3	71.1	71.9	67.0	59.4	51.8	44.9	(27)
		MCDB	41.3	48.7	58.5	71.3	74.7	76.9	82.0	85.3	79.9	66.7	57.6	51.2	(28)
	2%	WB	35.2	39.5	46.4	56.5	60.7	65.6	68.7	68.7	63.8	56.3	48.8	41.0	(29)
		MCDB	39.0	46.3	55.9	65.9	69.6	75.2	79.1	80.4	74.9	63.8	53.3	45.7	(30)
	5%	WB	33.6	37.4	44.0	52.9	58.0	63.8	67.3	66.6	61.8	54.1	46.0	38.0	(31)
		MCDB	37.1	43.3	52.3	62.8	66.5	73.3	77.2	77.2	71.7	60.9	50.9	42.1	(32)
	10%	WB	32.2	35.1	41.9	50.6	56.0	62.2	65.8	65.1	60.2	52.5	43.2	35.7	(33)
		MCDB	35.3	39.4	48.4	59.1	64.4	71.3	75.3	74.9	68.8	58.7	48.4	39.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.6	16.5	17.5	18.3	18.6	20.0	19.5	21.0	20.4	17.3	15.6	14.4	(35)
		MCDBR	16.2	21.0	25.3	25.7	24.6	25.2	25.0	27.6	25.7	23.4	21.2	17.8	(36)
	5% WB	MCWBR	11.6	14.0	14.6	12.9	11.9	10.7	10.6	11.2	11.3	12.3	12.4	11.6	(37)
		MCWBR	14.9	20.3	23.0	24.0	22.2	22.8	22.2	24.1	23.2	20.2	18.6	15.8	(38)
(40) Clear-Sky Solar Irradiance	taub		0.310	0.350	0.414	0.478	0.444	0.438	0.482	0.476	0.408	0.382	0.330	0.305	(40)
		taud	2.212	2.073	1.956	1.893	2.085	2.163	2.061	2.072	2.242	2.248	2.330	2.280	(41)
	Ebn at Noon		258	263	259	251	265	266	252	249	259	250	250	249	(42)
		Edh at Noon	30	41	52	60	50	47	51	49	39	34	27	26	(43)
(44) All-Sky Solar Radiation	RadAvg		586	876	1088	1322	1588	1814	1801	1692	1347	916	645	503	(44)
	RadStd		58	107	125	186	156	128	174	167	134	108	71	61	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)
(47)	Regional (16 neighbors)	N/A	N/A	+2.21	N/A	+1.71	+1.69	N/A	N/A	N/A	(47)

Nomenclature: See separate page