

PASANAURI, Georgia

WMO: 374320

Lat: 42.3558N

Lon: 44.6859E

Elev: 1072

StdP: 89.09

Time Zone: 4.00 (E04)

Period: 86-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.1	-10.9	-16.3	1.0	-11.7	-14.4	1.2	-9.6	5.4	-1.3	4.6	-0.4	0.6	340	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	29.4	18.4	27.7	18.1	26.0	17.7	20.3	26.3	19.4	25.1	18.6	24.0	1.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	15.2	23.0	17.6	14.3	22.1	16.7	13.6	21.2	63.7	26.5	60.4	25.2	57.3	24.1	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.3	4.4	3.4	DB	-16.2	32.3	1.8	2.4	-17.5	34.0	-18.6	35.4	-19.6	36.8	-20.9	38.6	(4)
			WB	-16.6	22.0	1.8	1.9	-17.9	23.3	-19.0	24.4	-20.0	25.5	-21.3	26.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.1	-2.8	-0.8	3.8	9.3	13.0	17.3	19.9	19.7	15.7	10.2	4.1	-0.8	(6)
(7)		DBStd	8.54	3.51	3.74	3.66	3.51	3.02	2.65	2.32	2.60	3.11	3.05	3.56	3.90	(7)
(8)		HDD10.0	1508	398	302	195	53	9	0	0	0	2	34	181	335	(8)
(9)		HDD18.3	3517	656	535	452	269	166	49	12	17	89	251	428	593	(9)
(10)		CDD10.0	1182	0	0	2	33	103	220	307	301	172	42	2	0	(10)
(11)		CDD18.3	150	0	0	0	0	2	19	61	59	9	0	0	0	(11)
(12)		CDH23.3	1151	0	0	0	3	19	164	417	454	92	1	0	0	(12)
(13)		CDH26.7	267	0	0	0	0	1	23	90	136	17	0	0	0	(13)
(14)	Wind	WSAvg	0.9	0.7	0.9	1.0	1.0	1.2	0.9	0.8	0.9	0.8	0.7	0.6	(14)	
(15)	Precipitation	PrecAvg	1507	91	95	111	150	185	178	164	119	106	95	97	104	(15)
(16)		PrecMax	2193	382	233	212	356	348	328	298	269	283	190	273	233	(16)
(17)		PrecMin	1086	11	8	13	69	62	82	23	22	30	14	8	20	(17)
(18)		PrecStd	274	93	65	51	65	78	57	79	56	57	54	60	61	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	6.5	11.1	17.2	23.2	25.7	29.0	30.8	32.4	28.8	21.6	16.6	11.5	(19)	
(20)		MCWB	2.4	4.8	8.9	14.5	16.4	16.9	19.2	20.1	18.0	13.4	9.2	6.3	(20)	
(21)		DB	4.8	8.6	14.3	20.5	22.9	26.9	29.0	29.9	25.7	19.6	13.3	8.2	(21)	
(22)		MCWB	1.2	3.9	7.7	12.7	14.4	17.4	18.7	18.6	16.6	12.5	7.8	4.4	(22)	
(23)		DB	3.4	6.5	12.0	18.3	21.0	25.2	27.4	27.9	23.6	17.7	11.3	6.0	(23)	
(24)		MCWB	0.6	2.7	6.3	10.9	13.6	16.7	18.5	18.0	15.8	11.6	6.9	3.0	(24)	
(25)		DB	2.1	4.6	9.7	16.1	19.1	23.4	25.7	25.7	21.7	15.6	9.4	4.2	(25)	
(26)		MCWB	-0.1	1.5	5.2	10.0	12.8	16.1	18.2	17.9	15.0	10.9	6.1	1.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	3.2	5.9	10.6	16.8	18.2	20.2	21.7	22.2	19.4	15.2	11.0	7.2	(27)	
(28)		MCDWB	5.1	9.3	14.7	21.8	23.7	24.9	27.8	29.6	26.6	19.3	14.2	10.7	(28)	
(29)		WB	1.8	4.2	8.0	13.6	16.0	18.6	20.4	20.4	17.7	13.5	9.3	5.0	(29)	
(30)		MCDWB	3.9	8.0	13.3	18.8	20.9	24.0	26.2	26.9	23.8	17.7	11.8	7.6	(30)	
(31)		WB	0.9	3.0	6.7	11.6	14.5	17.7	19.6	19.2	16.6	12.3	7.8	3.4	(31)	
(32)		MCDWB	2.8	6.3	11.3	17.1	19.2	22.9	25.1	25.1	22.1	16.0	10.5	5.6	(32)	
(33)		WB	0.1	1.7	5.5	10.4	13.3	16.8	18.8	18.4	15.6	11.4	6.2	2.0	(33)	
(34)		MCDWB	1.8	4.1	9.1	15.1	18.0	21.8	24.1	23.8	20.5	14.9	9.1	4.0	(34)	
(35)	Mean Daily Temperature Range	MDBR	8.1	9.2	9.7	10.2	10.4	11.1	10.8	11.7	11.3	9.6	8.6	8.0	(35)	
(36)		5% DB	9.0	11.7	14.0	14.3	13.7	14.0	13.9	15.3	14.3	13.0	11.8	9.9	(36)	
(37)		MCWBR	6.5	7.8	8.1	7.1	6.6	6.0	5.9	6.2	6.3	6.8	6.9	6.4	(37)	
(38)		5% WB	8.3	11.3	12.8	13.4	12.4	12.6	12.3	13.4	12.9	11.2	10.3	8.8	(38)	
(39)		MCWBR	6.3	7.8	8.0	7.7	6.8	6.8	6.1	6.5	6.5	6.7	6.6	6.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.310	0.350	0.414	0.478	0.444	0.438	0.482	0.476	0.408	0.382	0.330	0.305	(40)	
(41)		taud	2.212	2.073	1.956	1.893	2.085	2.163	2.061	2.072	2.242	2.248	2.330	2.280	(41)	
(42)		Ebn at Noon	812	828	815	792	835	839	796	786	818	789	789	786	(42)	
(43)		Edh at Noon	94	128	163	188	159	148	162	155	122	107	84	81	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.85	2.76	3.43	4.17	5.01	5.72	5.68	5.33	4.25	2.89	2.03	1.59	(44)	
(45)		RadStd	0.18	0.34	0.40	0.58	0.49	0.40	0.55	0.53	0.42	0.34	0.23	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (16 neighbors)	N/A	N/A	+1.23	N/A	+0.95	+0.94	N/A	N/A	N/A	N/A

Nomenclature: See separate page