

ZAKATALA, Azerbaijan

WMO: 375750

Lat: 41.6201N

Lon: 46.6486E

Elev: 490

StdP: 95.58

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.3	-2.9	-9.6	1.8	-0.3	-8.1	2.0	0.4	5.3	9.0	4.3	6.7	1.7	20	0.384

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	34.9	21.4	33.5	21.2	32.1	20.8	23.4	30.9	22.6	30.3	21.7	29.6	2.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.3	16.9	26.9	20.1	15.7	26.6	19.1	14.7	26.2	72.5	30.9	69.1	30.3	65.9	29.8	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.6	3.6	3.1	DB	-6.5	37.8	2.5	1.4	-8.4	38.8	-9.8	39.6	-11.2	40.4	-13.0	41.5	
			WB	-7.1	24.7	2.4	1.4	-8.8	25.7	-10.2	26.5	-11.6	27.3	-13.3	28.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.9	3.9	4.6	8.9	13.7	19.4	24.0	26.4	26.2	21.3	15.2	9.2	5.0
	DBStd	8.85	3.35	4.02	3.59	3.96	2.80	2.90	2.73	3.23	3.31	3.76	3.81	3.41
	HDD10.0	646	190	156	64	12	0	0	0	0	0	7	58	159
	HDD18.3	2098	447	386	292	144	20	1	0	1	11	108	274	415
	CDD10.0	2424	1	4	31	123	292	420	508	502	338	168	33	3
	CDD18.3	836	0	0	0	7	53	171	250	244	100	11	0	0
	CDH23.3	7611	0	0	1	31	298	1449	2573	2592	642	26	0	0
	CDH26.7	3016	0	0	0	2	47	512	1113	1164	178	1	0	0
Wind	WSAvg	2.0	2.0	2.0	2.1	2.0	2.1	2.1	2.1	2.1	2.0	1.9	2.0	
Precipitation	PrecAvg	975	39	53	71	101	128	130	81	81	81	98	75	38
	PrecMax	1487	130	106	139	255	306	297	240	300	253	219	168	90
	PrecMin	529	6	6	21	15	36	28	0	0	9	5	10	3
	PrecStd	194	24	26	28	56	66	77	66	80	62	52	43	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.9	16.8	20.8	26.5	30.0	34.6	36.5	36.8	32.5	25.8	20.0	16.1
		MCWB	7.2	8.8	11.2	16.2	18.1	21.0	22.0	20.9	21.7	19.7	13.1	9.1
	2%	DB	12.5	14.2	18.5	24.0	27.9	32.7	34.9	35.1	30.7	23.8	17.7	12.9
		MCWB	6.4	7.9	10.6	15.3	17.7	20.4	21.8	21.0	20.7	17.5	12.1	7.5
	5%	DB	10.5	12.1	16.6	22.2	26.2	31.0	33.4	33.7	28.7	22.1	15.9	11.0
		MCWB	5.2	6.9	9.7	14.4	17.4	20.2	21.5	21.1	19.8	16.9	11.2	6.6
	10%	DB	8.6	10.0	14.7	20.2	24.9	29.7	32.0	32.4	26.8	20.5	14.2	9.4
		MCWB	4.3	5.8	8.8	13.4	17.1	19.7	21.2	20.7	19.0	15.9	10.2	6.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.1	10.1	13.0	17.6	20.2	22.6	24.8	26.1	23.2	21.2	15.9	9.9
		MCDB	13.9	14.1	18.6	24.6	27.2	31.1	32.7	31.0	27.7	22.7	17.1	13.2
	2%	WB	6.7	8.5	11.5	16.1	19.1	21.6	23.5	23.5	21.9	19.1	13.2	8.2
		MCDB	11.5	13.5	16.8	22.9	25.4	29.8	31.6	31.0	28.4	22.7	16.1	11.6
	5%	WB	5.7	7.2	10.4	15.0	18.2	20.8	22.7	22.4	20.9	17.6	11.8	7.2
		MCDB	9.4	11.7	15.3	20.9	24.5	29.2	30.7	30.5	27.7	21.1	14.8	10.1
	10%	WB	4.7	5.9	9.5	13.8	17.4	20.2	21.9	21.5	19.9	16.2	10.7	6.3
		MCDB	7.8	9.2	13.9	18.9	23.6	28.5	29.8	29.8	25.8	19.9	13.8	8.9
Mean Daily Temperature Range	5% DB	MDBR	6.3	6.2	7.9	8.6	8.9	9.4	9.3	9.5	8.8	7.3	6.8	6.4
		MCDBR	9.5	10.1	11.2	11.2	11.0	10.5	10.7	11.2	10.9	9.6	9.8	8.8
		MCWBR	5.7	5.7	5.9	5.8	5.5	4.8	4.6	4.5	4.9	5.6	6.2	5.8
	5% WB	MCDBR	8.5	9.3	9.8	10.2	9.4	9.8	9.5	10.0	9.9	8.7	8.5	7.6
		MCWBR	5.4	5.6	5.5	5.7	5.5	5.1	4.6	5.1	5.3	6.0	5.8	5.1
Clear-Sky Solar Irradiance	taub	0.359	0.410	0.484	0.563	0.531	0.521	0.582	0.563	0.479	0.443	0.385	0.356	
	taud	2.146	1.991	1.860	1.748	1.877	1.951	1.834	1.873	2.048	2.078	2.170	2.185	
	Ebn at Noon	753	764	749	722	762	770	717	715	749	722	717	720	
	Edh at Noon	104	142	182	219	197	183	204	191	149	129	101	92	
All-Sky Solar Radiation	RadAvg	1.74	2.51	3.36	4.40	5.51	6.38	6.21	5.69	4.41	2.89	2.04	1.58	
	RadStd	0.19	0.33	0.31	0.57	0.38	0.43	0.47	0.57	0.39	0.32	0.22	0.19	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page