

QUBA, Azerbaijan

WMO: 376750

Lat: 41.367N

Lon: 48.517E

Elev: 552

StdP: 94.87

Time Zone: 4.00 (E04)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.0	-7.0	-11.7	1.5	-6.8	-9.7	1.8	-4.1	7.9	10.8	6.0	4.4	1.9	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.6	33.0	20.5	31.4	20.2	29.9	19.9	22.8	29.7	21.9	28.5	21.1	27.6	3.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.7	16.4	26.8	19.7	15.4	25.7	18.9	14.7	24.8	70.5	29.6	67.0	28.6	63.9	27.7	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.1	4.6	4.0	DB	-12.1	36.7	3.3	2.0	-14.5	38.1	-16.4	39.3	-18.3	40.4	-20.7	41.8	(4)
(5)			WB	-12.3	25.9	3.2	1.4	-14.7	26.9	-16.6	27.7	-18.4	28.4	-20.7	29.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.1	0.9	0.9	5.0	11.1	17.0	21.7	24.1	23.7	18.5	12.1	6.4	3.0	(6)	
	DBStd	9.21	3.75	4.43	4.06	4.44	3.05	3.24	2.79	3.17	3.50	4.01	4.13	3.59	(7)	
	HDD10.0	1100	284	255	162	38	1	0	0	0	0	24	119	218	(8)	
	HDD18.3	2801	542	487	413	219	62	9	1	2	39	196	357	476	(9)	
	CDD10.0	1871	1	2	7	72	218	351	438	426	254	89	12	1	(10)	
	CDD18.3	531	0	0	0	3	21	109	181	169	43	3	0	0	(11)	
	CDH23.3	4147	0	0	6	25	106	807	1487	1442	253	21	1	0	(12)	
	CDH26.7	1421	0	0	1	2	14	232	551	548	71	2	0	0	(13)	
(14) Wind	WSAvg	2.0	1.7	1.8	2.1	2.1	2.2	2.3	2.3	2.2	2.0	1.8	1.7	1.7	(14)	
(15) Precipitation	PrecAvg	454	28	33	36	38	39	37	29	30	52	56	36	28	(15)	
	PrecMax	622	52	61	83	79	78	71	81	84	117	138	82	81	(16)	
	PrecMin	333	12	6	14	21	10	5	4	4	0	6	0	0	(17)	
	PrecStd	69	9	15	16	16	18	17	18	19	29	34	21	20	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.1	16.6	23.2	26.6	28.5	33.2	35.7	35.2	32.1	26.1	19.7	15.5	(19)	
		MCWB	7.5	8.9	11.7	15.4	16.8	20.9	22.2	20.2	19.7	15.9	12.8	9.1	(20)	
	2%	DB	11.1	11.5	17.0	22.8	25.8	30.9	33.0	33.0	28.6	22.3	16.6	12.2	(21)	
		MCWB	5.7	6.9	9.2	14.2	16.9	19.8	20.5	20.5	18.8	15.7	11.5	7.3	(22)	
	5%	DB	7.8	8.7	14.1	20.5	24.1	29.2	31.2	31.4	26.1	19.8	14.1	9.6	(23)	
		MCWB	3.9	5.4	8.2	13.2	16.8	19.2	20.5	20.2	18.6	15.2	10.3	6.2	(24)	
	10%	DB	5.3	6.2	11.5	17.9	22.5	27.7	29.7	29.8	24.2	18.1	12.0	7.7	(25)	
		MCWB	2.9	3.8	7.1	12.5	16.2	18.9	20.2	20.0	17.9	14.3	9.2	5.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.5	9.9	12.1	16.6	19.9	23.2	24.2	24.4	22.5	18.6	14.8	11.0	(27)	
		MCDB	13.9	14.9	19.7	23.3	24.7	29.9	32.3	30.5	27.4	22.0	19.0	13.0	(28)	
	2%	WB	5.8	7.3	10.0	14.9	18.6	21.7	22.9	22.7	20.8	17.0	12.5	8.1	(29)	
		MCDB	9.9	10.5	15.4	20.5	23.4	28.1	30.1	29.3	26.0	20.5	15.5	10.4	(30)	
	5%	WB	4.4	5.6	8.7	13.8	17.6	20.7	22.0	21.8	19.7	15.7	10.6	6.9	(31)	
		MCDB	7.2	8.3	13.3	18.9	22.3	26.9	29.0	28.2	24.2	18.8	13.0	9.1	(32)	
	10%	WB	3.3	4.0	7.4	12.7	16.7	19.8	21.1	20.9	18.6	14.6	9.6	5.5	(33)	
		MCDB	5.1	5.9	11.0	17.4	21.5	25.7	27.7	27.6	23.0	17.4	11.6	7.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.9	6.1	7.3	8.1	8.0	8.8	8.6	8.9	8.0	6.8	6.3	6.2	(35)	
		MCDBR	11.1	11.1	13.1	11.8	10.7	11.0	11.4	11.4	11.2	10.3	10.6	10.2	(36)	
	5% WB	MCWBR	7.3	7.4	7.9	6.8	6.1	5.3	5.0	5.5	6.0	6.3	7.9	7.1	(37)	
		MCWBR	9.7	10.2	11.6	10.4	9.5	10.0	9.7	10.0	10.2	9.1	9.2	9.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.360	0.404	0.462	0.535	0.513	0.509	0.561	0.545	0.488	0.433	0.380	0.360	(40)	
		taud	2.194	2.059	1.951	1.823	1.927	1.980	1.879	1.910	2.020	2.121	2.200	2.198	(41)	
	Ebn at Noon		759	776	774	746	777	780	734	730	742	737	727	720	(42)	
		Edh at Noon	100	133	166	203	187	178	195	184	154	124	99	92	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.51	2.17	3.12	4.35	5.43	6.15	6.04	5.46	4.05	2.60	1.81	1.40	(44)	
	RadStd		0.19	0.34	0.35	0.53	0.42	0.44	0.45	0.56	0.47	0.38	0.22	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+115

Nomenclature: See separate page