

AMASIA, Armenia

WMO: 376820

Lat: 40.950N

Lon: 43.784E

Elev: 1876

StdP: 80.73

Time Zone: 4.00 (E04)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.0	-16.7	-21.0	0.7	-18.4	-18.9	0.9	-16.2	5.2	-10.6	4.4	-10.1	1.7	340	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.5	27.0	19.6	25.3	18.9	23.8	18.2	21.0	24.9	19.8	23.9	18.7	22.8	1.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.9	18.4	23.7	18.5	16.8	22.4	17.3	15.6	21.3	71.4	25.2	66.1	24.0	61.8	22.9	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.1	3.4	3.2		-22.0	30.1	2.9	2.2	-24.1	31.6	-25.8	32.9	-27.4	34.2	-29.6	35.8	
			DB	-22.2	22.3	2.9	1.8	-24.3	23.6	-26.0	24.7	-27.6	25.7	-29.6	27.1	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.5	-8.1	-6.2	-1.2	4.8	9.8	14.1	17.4	18.0	13.5	7.8	0.8	-5.1
	DBStd	9.63	4.16	4.63	4.30	3.75	2.65	2.60	2.53	2.66	3.41	3.17	3.94	4.49
	HDD10.0	2393	560	453	347	160	36	2	0	0	9	82	276	469
	HDD18.3	4726	818	687	605	406	266	128	48	38	149	328	526	727
	CDD10.0	759	0	0	0	4	28	125	228	248	113	13	0	0
	CDD18.3	51	0	0	0	0	0	2	18	28	3	0	0	0
	CDH23.3	437	0	0	0	0	0	16	149	234	39	0	0	0
	CDH26.7	66	0	0	0	0	0	0	19	43	3	0	0	0
Wind	WSAvg	1.6	1.4	1.4	1.7	1.7	1.6	1.7	1.8	1.8	1.8	1.5	1.4	1.2
Precipitation	PrecAvg	596	35	28	38	74	107	85	54	47	38	49	31	31
	PrecMax	878	139	73	87	134	183	158	120	125	114	117	89	86
	PrecMin	411	0	0	4	27	49	32	14	13	1	6	0	0
	PrecStd	106	27	20	21	28	31	34	26	25	30	30	25	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.5	5.6	12.2	18.2	20.3	25.2	28.9	30.0	26.6	19.6	12.5	7.8
		MCWB	0.6	3.5	8.0	11.7	15.0	18.1	20.5	19.9	17.9	13.9	8.0	4.2
	2%	DB	0.0	3.4	8.9	15.1	18.3	23.3	26.6	27.8	24.2	17.6	10.2	4.2
		MCWB	-0.8	1.9	6.0	10.4	13.5	17.9	20.3	19.5	16.9	12.6	6.7	2.0
	5%	DB	-1.1	1.7	6.7	13.0	16.8	21.7	25.0	25.8	22.2	15.7	8.2	2.0
		MCWB	-1.8	0.6	4.5	9.3	12.7	17.1	19.6	18.8	15.9	11.4	5.9	0.7
	10%	DB	-2.2	-0.1	4.9	11.0	15.4	20.2	23.3	24.1	20.3	13.9	6.6	0.6
		MCWB	-2.8	-1.0	3.3	8.0	11.9	16.2	18.6	18.3	15.0	10.5	4.8	-0.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.0	3.8	9.0	12.2	15.9	21.3	23.3	22.2	19.2	14.9	8.7	4.8
		MCDB	1.3	5.4	11.1	16.4	19.2	23.4	25.8	27.2	24.7	18.2	11.2	7.1
	2%	WB	-0.6	2.2	6.2	10.8	14.3	18.9	21.4	20.8	17.8	13.2	7.2	2.3
		MCDB	-0.2	3.0	8.3	14.3	17.2	21.8	24.7	25.5	22.6	16.6	9.5	3.7
	5%	WB	-1.7	0.7	4.6	9.7	13.2	17.6	20.1	19.6	16.6	11.7	6.1	1.0
		MCDB	-1.2	1.5	6.3	12.8	16.1	20.6	24.1	24.2	21.1	15.0	8.0	1.8
	10%	WB	-2.8	-1.0	3.4	8.3	12.1	16.3	18.9	18.5	15.4	10.7	4.9	-0.3
		MCDB	-2.3	-0.2	4.8	10.6	14.9	19.7	22.7	23.3	19.5	13.5	6.5	0.6
Mean Daily Temperature Range	5% DB	MDBR	7.5	8.5	8.0	8.8	9.2	10.3	10.7	11.5	11.7	10.0	8.4	7.3
		MCDBR	6.8	9.3	10.0	11.8	11.7	12.5	13.0	13.9	14.0	13.0	11.4	8.9
		MCWBR	6.1	7.6	7.2	7.7	7.6	7.8	7.6	7.2	7.4	8.2	8.2	7.2
	5% WB	MCDBR	6.0	8.8	9.0	11.0	10.9	11.3	12.1	12.7	13.0	12.1	10.7	8.2
		MCWBR	5.5	7.5	6.9	7.7	7.7	8.1	7.9	7.5	7.6	8.2	8.0	6.8
Clear-Sky Solar Irradiance	taub	0.257	0.286	0.332	0.384	0.362	0.347	0.379	0.374	0.325	0.321	0.276	0.255	
	taud	2.348	2.270	2.248	2.178	2.330	2.404	2.334	2.343	2.465	2.430	2.498	2.435	
	Ebn at Noon	911	926	915	886	914	924	891	886	916	878	886	889	
	Edh at Noon	83	106	123	142	125	116	124	119	98	90	72	71	
All-Sky Solar Radiation	RadAvg	2.25	3.38	4.16	4.69	5.47	6.53	6.60	6.06	4.89	3.22	2.18	1.73	
	RadStd	0.20	0.36	0.45	0.48	0.39	0.43	0.40	0.37	0.35	0.28	0.28	0.22	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (18 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page