

SEVAN OZERO, Armenia

WMO: 377170

Lat: 40.5653N

Lon: 45.0083E

Elev: 6290

StdP: 11.65

Time Zone: 4.00 (E04)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.6	10.9	-1.5	6.4	9.2	1.5	7.5	13.7	22.3	24.5	20.1	29.9	4.0	220	0.535

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.4	77.0	62.6	74.1	61.7	71.9	60.8	64.8	73.0	63.4	71.4	62.1	69.7	4.0	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.0	105.3	69.9	60.6	100.0	68.5	59.2	95.2	67.0	33.7	73.2	32.4	71.6	31.3	69.9	73.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	14.1	11.7	4.4	83.1	5.8	3.9	0.2	85.9	-3.2	88.2	-6.5	90.4	-10.8	93.2
			3.3	68.3	5.2	2.2	-0.5	69.9	-3.5	71.1	-6.4	72.3	-10.1	73.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.5	24.0	25.9	32.7	41.4	50.6	58.4	63.7	64.4	57.7	49.0	37.2	28.2	(6)
	DBStd	15.42	6.34	7.45	7.25	6.60	4.66	4.62	4.39	4.58	5.57	5.90	6.93	7.13	(7)
	HDD50	3485	805	674	536	267	49	2	0	0	7	88	383	674	(8)
	HDD65	7561	1270	1094	1000	709	447	203	76	67	226	497	833	1139	(9)
	CDD50	1494	0	0	0	8	67	253	425	445	238	57	1	0	(10)
	CDD65	95	0	0	0	0	0	5	36	47	7	0	0	0	(11)
	CDH74	271	0	0	0	0	0	14	105	130	22	0	0	0	(12)
	CDH80	27	0	0	0	0	0	0	14	12	1	0	0	0	(13)
	WSAvg	4.3	5.4	4.8	5.0	3.9	3.5	3.6	4.4	4.4	4.3	4.0	4.3	4.7	(14)
(15) Precipitation	PrecAvg	19.6	0.7	0.9	1.3	2.3	3.5	2.9	1.9	1.3	1.1	1.9	1.3	0.7	(15)
	PrecMax	27.7	2.0	2.3	2.8	4.6	6.8	6.5	4.5	3.7	3.9	3.3	3.2	2.0	(16)
	PrecMin	9.9	0.1	0.2	0.3	1.0	0.4	0.0	0.0	0.2	0.0	0.1	0.0	0.1	(17)
	PrecStd	3.9	0.5	0.5	0.6	0.9	1.5	1.3	1.2	0.8	1.0	0.9	0.8	0.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.6	42.3	54.8	64.2	68.3	75.9	82.0	81.4	77.2	67.7	55.0	47.9	(19)
		MCWB	33.1	35.6	43.1	48.5	52.8	59.4	62.9	62.6	59.3	52.9	44.6	39.5	(20)
	2%	DB	36.0	39.3	49.2	58.3	64.6	71.9	76.6	77.3	72.9	63.5	51.7	43.0	(21)
		MCWB	31.3	33.6	40.4	46.0	52.0	59.5	64.2	62.7	57.7	50.6	42.6	35.9	(22)
	5%	DB	34.0	37.1	45.7	54.4	61.6	69.1	73.5	74.5	69.7	60.5	48.9	39.8	(23)
		MCWB	30.0	32.1	38.4	44.4	50.6	58.7	63.0	62.1	57.0	49.5	41.1	34.1	(24)
	10%	DB	32.4	35.1	42.6	51.1	58.8	66.4	71.0	72.1	66.7	57.7	46.0	37.2	(25)
		MCWB	29.0	31.0	36.4	42.9	49.4	57.3	61.8	61.3	56.3	48.6	39.4	32.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.7	36.4	43.9	49.9	56.0	64.2	68.2	66.7	63.1	55.0	46.2	40.7	(27)
		MCDB	37.3	40.5	51.7	60.7	64.9	71.7	76.4	75.2	71.0	63.2	53.1	46.9	(28)
	2%	WB	32.4	34.8	41.2	46.8	53.4	61.6	65.5	64.6	60.8	52.2	43.7	36.9	(29)
		MCDB	34.8	38.5	48.1	55.5	60.8	68.5	73.3	73.5	69.1	60.2	49.7	41.5	(30)
	5%	WB	30.7	32.8	39.0	45.2	51.8	59.7	63.9	63.2	59.0	50.8	41.9	34.8	(31)
		MCDB	33.4	36.4	44.5	52.7	59.1	66.6	71.5	71.8	66.7	58.2	47.3	38.9	(32)
	10%	WB	29.1	31.1	37.0	43.7	50.4	58.2	62.5	62.0	57.4	49.3	40.3	33.0	(33)
		MCDB	32.1	34.5	41.9	50.2	57.2	65.0	69.7	70.2	64.7	56.2	45.2	36.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.2	10.6	11.7	13.5	14.0	13.7	12.7	13.4	14.0	13.5	11.3	9.4	(35)
		MCDBR	9.5	11.1	14.9	18.8	18.4	17.1	16.0	17.0	18.9	17.7	14.3	11.5	(36)
	5% WB	MCWBR	6.6	7.1	8.5	9.1	8.3	8.2	8.5	8.0	7.6	8.0	8.2	7.4	(37)
		MCWBR	8.5	10.5	13.7	16.8	15.8	14.9	14.8	15.2	15.7	16.1	13.4	10.1	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.268	0.300	0.350	0.406	0.384	0.374	0.412	0.400	0.349	0.337	0.290	0.266	(40)
		taud	2.366	2.300	2.234	2.106	2.251	2.332	2.227	2.262	2.402	2.373	2.466	2.421	(41)
	Ebn at Noon	Ebn at Noon	285	289	285	274	283	285	273	273	282	272	276	278	(42)
		Edh at Noon	26	33	40	49	43	40	44	41	33	30	24	23	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	676	963	1151	1403	1733	2045	2031	1885	1518	1012	699	538	(44)
	RadStd	RadStd	75	141	109	174	98	141	130	151	109	86	95	75	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page