

SEVAN OZERO, Armenia

WMO: 377170

Lat: 40.5653N

Lon: 45.0083E

Elev: 1917

StdP: 80.32

Time Zone: 4.00 (E04)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.5	-11.7	-18.6	0.9	-12.6	-16.9	1.1	-10.2	10.0	-4.2	9.0	-1.2	1.8	220	0.535

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.5	25.0	17.0	23.4	16.5	22.1	16.0	18.2	22.8	17.5	21.9	16.7	21.0	1.8	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.7	15.0	21.1	15.9	14.3	20.3	15.1	13.6	19.5	60.5	22.9	57.5	22.0	55.0	21.1	22.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.9	6.3	5.2	DB	-15.3	28.4	3.2	2.2	-17.7	29.9	-19.6	31.2	-21.4	32.4	-23.8	34.0	(4)
(5)			WB	-16.0	20.2	2.9	1.2	-18.0	21.0	-19.7	21.7	-21.3	22.4	-23.4	23.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.0	-4.4	-3.4	0.4	5.2	10.3	14.7	17.6	18.0	14.3	9.4	2.9	-2.1	(6)
(7)		DBStd	8.57	3.52	4.14	4.03	3.67	2.59	2.57	2.44	2.54	3.10	3.28	3.85	3.96	(7)
(8)		HDD10.0	1936	447	374	298	148	27	1	0	0	4	49	213	374	(8)
(9)		HDD18.3	4201	706	608	556	394	248	113	42	37	126	276	463	633	(9)
(10)		CDD10.0	830	0	0	0	4	37	141	236	247	132	32	1	0	(10)
(11)		CDD18.3	53	0	0	0	0	0	3	20	26	4	0	0	0	(11)
(12)		CDH23.3	151	0	0	0	0	0	8	58	72	12	0	0	0	(12)
(13)		CDH26.7	15	0	0	0	0	0	0	8	7	1	0	0	0	(13)
(14)	Wind	WSAvg	1.9	2.4	2.2	2.2	1.8	1.6	1.6	2.0	2.0	1.9	1.8	1.9	2.1	(14)
(15)	Precipitation	PrecAvg	498	18	23	33	59	89	74	49	33	27	47	32	17	(15)
(16)		PrecMax	703	52	58	72	116	173	165	114	93	98	85	82	52	(16)
(17)		PrecMin	252	2	4	8	25	10	1	1	4	0	3	1	2	(17)
(18)		PrecStd	98	13	13	16	23	39	33	30	21	25	23	21	11	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.7	5.7	12.7	17.9	20.2	24.4	27.8	27.4	25.1	19.8	12.8	8.8	(19)
(20)			MCWB	0.6	2.0	6.1	9.1	11.5	15.2	17.2	17.0	15.2	11.6	7.0	4.2	(20)
(21)		2%	DB	2.2	4.0	9.6	14.6	18.1	22.2	24.8	25.2	22.7	17.5	11.0	6.1	(21)
(22)			MCWB	-0.4	0.9	4.7	7.8	11.1	15.3	17.9	17.1	14.3	10.3	5.9	2.2	(22)
(23)		5%	DB	1.1	2.8	7.6	12.5	16.4	20.6	23.1	23.6	21.0	15.8	9.4	4.4	(23)
(24)			MCWB	-1.1	0.1	3.5	6.9	10.4	14.8	17.2	16.7	13.9	9.7	5.0	1.1	(24)
(25)		10%	DB	0.2	1.7	5.9	10.6	14.9	19.1	21.7	22.3	19.3	14.3	7.8	2.9	(25)
(26)			MCWB	-1.7	-0.5	2.4	6.1	9.7	14.0	16.6	16.3	13.5	9.2	4.1	0.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.5	2.4	6.6	10.0	13.3	17.9	20.1	19.3	17.3	12.8	7.9	4.8	(27)
(28)			MCDWB	3.0	4.7	10.9	15.9	18.3	22.1	24.7	24.0	21.7	17.3	11.7	8.3	(28)
(29)		2%	WB	0.2	1.6	5.1	8.2	11.9	16.4	18.6	18.1	16.0	11.2	6.5	2.7	(29)
(30)			MCDWB	1.6	3.6	8.9	13.0	16.0	20.3	22.9	23.0	20.6	15.7	9.8	5.3	(30)
(31)		5%	WB	-0.7	0.5	3.9	7.3	11.0	15.4	17.7	17.3	15.0	10.4	5.5	1.6	(31)
(32)			MCDWB	0.8	2.5	7.0	11.5	15.1	19.2	21.9	22.1	19.3	14.6	8.5	3.8	(32)
(33)		10%	WB	-1.6	-0.5	2.8	6.5	10.2	14.6	17.0	16.7	14.1	9.6	4.6	0.6	(33)
(34)			MCDWB	0.1	1.4	5.5	10.1	14.0	18.3	20.9	21.2	18.2	13.4	7.3	2.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.1	5.9	6.5	7.5	7.8	7.6	7.0	7.5	7.8	7.5	6.3	5.2	(35)
(36)			MCDBR	5.3	6.2	8.3	10.4	10.2	9.5	8.9	9.5	10.5	9.8	7.9	6.4	(36)
(37)			MCWBR	3.6	4.0	4.7	5.0	4.6	4.6	4.7	4.4	4.2	4.5	4.6	4.1	(37)
(38)		5% WB	MCDBR	4.7	5.8	7.6	9.3	8.8	8.3	8.2	8.4	8.7	9.0	7.5	5.6	(38)
(39)			MCWBR	3.6	4.0	4.6	4.9	4.6	4.9	4.8	4.6	4.3	4.5	4.6	4.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.268	0.300	0.350	0.406	0.384	0.374	0.412	0.400	0.349	0.337	0.290	0.266	(40)	
(41)		taud	2.366	2.300	2.234	2.106	2.251	2.332	2.227	2.262	2.402	2.373	2.466	2.421	(41)	
(42)		Ebn at Noon	900	912	897	865	892	900	860	861	890	858	869	876	(42)	
(43)		Edh at Noon	83	104	125	153	136	125	138	130	105	96	76	73	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.13	3.04	3.63	4.42	5.46	6.45	6.40	5.94	4.79	3.19	2.20	1.70	(44)	
(45)		RadStd	0.23	0.44	0.34	0.55	0.31	0.44	0.41	0.48	0.34	0.27	0.30	0.23	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (15 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page