

GANJA, Azerbaijan

WMO: 377350

Lat: 40.717N

Lon: 46.417E

Elev: 311

StdP: 97.64

Time Zone: 4.00 (E04)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.6	(c) -2.5	(d) -10.9	(e) 1.5	(f) 2.9	(g) -9.2	(h) 1.8	(i) 2.5	(j) 13.7	(k) 6.8	(l) 8.7	(m) 8.3	(n) 0.9	(o) 320	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	35.4	21.5	34.1	21.2	32.9	21.0	23.7	32.0	22.9	31.1	22.2	30.0	3.2	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.2	16.5	27.8	20.4	15.7	27.1	19.6	14.9	26.7	73.0	32.2	69.8	31.2	67.0	30.2	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 13.6	(b) 9.0	(c) 6.1	(e) -5.4	(f) 38.0	(g) 2.3	(h) 1.6	(i) -7.1	(j) 39.2	(k) -8.4	(l) 40.1	(m) -9.7	(n) 41.0	(o) -11.4	(p) 42.2		
(a) 13.6	(b) 9.0	(c) 6.1	(e) -6.4	(f) 25.2	(g) 2.1	(h) 0.9	(i) -7.9	(j) 25.9	(k) -9.2	(l) 26.4	(m) -10.4	(n) 27.0	(o) -11.9	(p) 27.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.3	4.3	4.8	9.4	13.6	19.9	24.9	27.2	26.3	21.6	15.6	9.5	5.6
	DBStd	8.84	3.27	3.94	3.36	3.69	2.91	2.72	2.39	2.77	3.04	3.48	3.46	3.21
	HDD10.0	584	179	149	51	10	1	0	0	0	0	4	49	141
	HDD18.3	2022	436	378	276	147	18	1	0	1	8	95	266	396
	CDD10.0	2513	2	4	33	118	306	448	533	507	348	178	33	3
	CDD18.3	908	0	0	0	6	65	198	274	248	106	11	0	0
	CDH23.3	8958	0	0	1	40	427	1907	3110	2711	727	35	1	0
	CDH26.7	3892	0	0	0	3	91	794	1515	1291	196	3	0	0
Wind	WSAvg	1.9	1.6	1.7	2.5	2.4	1.9	2.2	2.3	2.3	1.9	1.6	1.4	1.5
Precipitation	PrecAvg	274	10	15	18	32	42	58	25	18	18	28	15	12
	PrecMax	360	36	42	54	89	144	480	75	74	64	81	42	28
	PrecMin	162	0	2	0	4	9	0	0	0	1	0	0	0
	PrecStd	55	8	11	12	19	27	80	20	17	18	20	10	9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.6	17.5	22.0	26.7	31.0	35.7	37.3	36.7	32.4	26.5	20.3	16.5
		MCWB	7.5	8.9	12.4	16.4	18.4	20.5	22.1	20.9	20.6	18.1	12.0	8.6
	2%	DB	13.0	14.7	19.5	24.4	28.9	33.8	35.7	35.1	30.6	24.0	17.8	13.7
		MCWB	6.3	7.8	10.9	16.1	18.6	20.7	22.2	20.8	20.2	17.0	11.7	7.9
	5%	DB	10.8	12.3	17.6	22.3	27.3	32.4	34.5	33.9	29.1	22.4	16.0	11.7
		MCWB	5.2	6.7	10.0	15.1	18.1	20.3	21.9	20.7	19.8	16.2	11.1	7.1
	10%	DB	9.0	10.3	15.5	20.2	25.7	31.1	33.1	32.6	27.5	20.9	14.3	10.2
		MCWB	4.3	5.6	9.2	13.9	17.7	20.1	21.7	20.8	19.4	15.7	10.2	6.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	10.5	14.1	18.1	21.1	23.4	25.2	24.5	22.4	19.0	14.7	10.0
		MCDB	14.1	15.2	20.3	23.7	27.4	31.5	33.4	32.1	28.5	24.1	17.8	14.0
	2%	WB	6.7	8.6	12.0	16.6	20.1	22.2	24.2	23.3	21.3	18.0	12.7	8.7
		MCDB	11.8	13.0	17.4	23.0	26.4	30.0	32.6	31.3	27.9	22.5	15.2	11.9
	5%	WB	5.7	7.2	10.8	15.6	19.2	21.4	23.4	22.6	20.7	17.1	11.8	7.8
		MCDB	9.5	11.4	16.2	21.6	25.2	29.6	31.8	30.5	27.2	21.3	14.5	11.0
	10%	WB	4.9	6.1	9.9	14.4	18.2	20.8	22.6	22.0	20.0	16.3	10.9	6.7
		MCDB	8.1	9.0	14.3	19.3	23.9	29.1	30.9	29.5	26.5	20.0	14.0	9.7
Mean Daily Temperature Range	5% DB	MDBR	6.6	6.2	8.3	9.1	9.4	10.3	10.4	10.5	9.0	7.5	7.0	6.6
		MCDBR	10.0	10.4	11.5	12.4	12.0	11.9	12.1	12.6	11.1	9.8	10.1	9.1
		MCWBR	5.3	5.3	5.8	6.5	5.0	3.9	4.1	4.1	4.3	4.6	5.3	5.2
	5% WB	MCDBR	8.3	9.0	9.9	11.5	10.3	10.8	11.0	10.4	10.1	8.6	8.1	8.6
		MCWBR	4.8	5.0	5.6	6.4	5.2	4.4	4.6	4.3	4.4	4.4	4.5	5.2
Clear-Sky Solar Irradiance	taub	0.347	0.383	0.430	0.501	0.479	0.472	0.519	0.505	0.459	0.424	0.371	0.347	
	taud	2.298	2.180	2.079	1.937	2.066	2.133	2.016	2.050	2.156	2.192	2.288	2.310	
	Ebn at Noon	791	810	811	778	808	812	769	766	776	755	753	756	
	Edh at Noon	92	119	147	182	163	153	171	161	135	117	92	84	
All-Sky Solar Radiation	RadAvg	1.91	2.56	3.49	4.42	5.47	6.34	6.26	5.73	4.37	2.95	2.13	1.70	
	RadStd	0.19	0.34	0.34	0.60	0.30	0.47	0.47	0.57	0.35	0.32	0.23	0.21	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)		+0.48	N/A	+1.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page