

GOYCHAY, Azerbaijan

WMO: 377490

Lat: 40.650N

Lon: 47.750E

Elev: 312

StdP: 14.53

Time Zone: 4.00 (E04)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.2	29.3	20.2	15.4	31.3	23.6	18.0	32.5	26.7	43.6	18.9	48.4	4.5	0	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	99.3	72.2	97.0	71.6	94.8	71.0	75.4	93.9	73.9	91.8	72.7	89.8	4.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.8	110.8	83.5	68.4	105.6	82.6	67.1	100.8	81.5	39.1	93.8	37.6	91.7	36.5	90.2	90.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.6	11.0	9.0	DB	21.5	103.4	5.0	1.8	18.0	104.7	15.1	105.8	12.3	106.8	8.7	108.1
			WB	20.5	77.8	5.3	2.2	16.8	79.3	13.7	80.6	10.7	81.8	6.9	83.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	61.4	40.5	42.0	49.2	58.3	70.9	79.8	83.4	82.5	73.7	62.1	49.9	42.5	(6)
(7)		DBStd	16.66	4.99	6.08	5.40	6.41	4.80	5.07	4.18	4.85	5.35	6.67	6.09	5.28	(7)
(8)		HDD50	927	296	229	76	9	0	0	0	0	0	5	74	238	(8)
(9)		HDD65	3403	759	643	490	215	9	0	0	0	5	131	452	699	(9)
(10)		CDD50	5071	2	5	52	258	649	894	1037	1007	712	380	71	4	(10)
(11)		CDD65	2073	0	0	0	14	193	444	572	542	267	41	0	0	(11)
(12)		CDH74	22258	0	0	2	113	1541	4895	7017	6482	2073	135	0	0	(12)
(13)		CDH80	10928	0	0	0	11	479	2498	3734	3471	724	11	0	0	(13)
(14)	Wind	WSAvg	4.2	4.3	4.4	5.1	4.6	4.4	4.5	3.6	3.8	4.0	3.7	3.9	4.2	(14)
(15)	Precipitation	PrecAvg	22.2	1.8	2.0	2.3	2.0	2.0	1.7	1.1	0.9	2.0	2.4	2.1	1.7	(15)
(16)		PrecMax	29.4	3.3	3.5	3.9	4.3	3.7	3.9	3.5	2.1	4.9	5.5	4.3	3.7	(16)
(17)		PrecMin	14.8	0.9	0.7	1.0	0.9	0.4	0.2	0.2	0.0	0.4	0.0	0.2		(17)
(18)		PrecStd	2.9	0.6	0.7	0.8	0.7	0.8	0.8	0.7	0.6	1.1	1.1	1.0	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.4	64.0	71.9	81.7	91.8	100.8	102.6	101.5	93.4	81.9	68.8	58.4	(19)
(20)		0.4%	MCWB	46.8	50.6	56.7	64.0	66.8	70.0	75.8	73.6	72.0	67.1	58.0	49.2	(20)
(21)		2%	DB	53.7	56.9	66.6	77.0	88.1	97.2	99.3	99.1	90.1	78.0	64.2	55.1	(21)
(22)		2%	MCWB	45.0	47.3	54.4	61.6	66.1	70.0	73.5	71.7	69.6	65.9	55.2	47.7	(22)
(23)		5%	DB	50.1	52.4	62.6	74.0	85.2	94.4	97.1	96.7	87.3	74.8	61.1	52.5	(23)
(24)		5%	MCWB	43.4	46.5	52.6	60.5	66.3	69.6	72.9	70.8	68.4	64.1	53.8	46.7	(24)
(25)		10%	DB	47.0	49.6	58.8	70.1	82.2	92.0	94.6	94.5	84.3	72.0	58.2	49.9	(25)
(26)		10%	MCWB	42.1	44.7	50.0	58.8	65.2	69.1	71.9	70.6	67.9	62.5	52.3	45.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.8	53.1	59.1	66.0	70.6	74.5	78.8	76.1	74.3	69.9	60.3	51.0	(27)
(28)		0.4%	MCDB	58.1	60.8	67.5	77.5	85.0	92.9	96.7	94.9	90.1	76.9	66.9	55.7	(28)
(29)		2%	WB	45.8	49.2	55.7	63.2	68.8	72.7	76.4	74.5	71.7	67.3	56.7	49.1	(29)
(30)		2%	MCDB	51.7	54.9	65.3	74.9	82.8	91.0	94.6	93.8	85.9	75.9	62.1	53.3	(30)
(31)		5%	WB	44.2	46.5	52.9	61.5	67.5	71.3	74.9	73.2	70.3	65.4	54.8	47.3	(31)
(32)		5%	MCDB	48.8	51.8	61.6	71.3	81.3	89.1	92.9	91.8	83.5	73.0	59.4	51.1	(32)
(33)		10%	WB	42.8	45.0	50.8	59.8	66.3	70.1	73.4	72.1	68.9	63.6	53.1	45.8	(33)
(34)		10%	MCDB	46.3	48.9	57.6	68.1	79.2	88.0	90.2	89.5	81.1	70.5	57.5	49.1	(34)
(35)	Mean Daily Temperature Range		MDBR	11.6	10.9	14.9	17.3	19.3	20.6	19.6	20.4	17.3	13.6	12.4	11.1	(35)
(36)		5% DB	MCDBR	17.5	18.0	22.7	22.7	23.7	24.1	23.8	24.5	21.8	17.6	16.4	15.5	(36)
(37)			MCWBR	10.9	11.0	13.0	11.0	9.3	8.4	8.9	9.4	8.5	8.1	9.8	9.9	(37)
(38)			MCDBR	15.9	16.0	20.5	20.0	20.9	21.9	21.8	22.3	19.5	16.0	14.6	13.3	(38)
(39)		5% WB	MCWBR	10.2	9.9	12.2	10.3	8.9	8.8	8.9	9.0	8.9	8.1	9.3	9.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.370	0.408	0.459	0.535	0.510	0.505	0.552	0.533	0.492	0.445	0.395	0.371	(40)	
(41)		taud	2.218	2.104	1.999	1.858	1.977	2.028	1.923	1.967	2.049	2.130	2.208	2.226	(41)	
(42)		Ebn at Noon	240	247	248	238	248	249	235	236	236	232	228	228	(42)	
(43)		Edh at Noon	32	41	51	62	57	54	59	55	48	39	32	29	(43)	
(44)	All-Sky Solar Radiation	RadAvg	561	763	1098	1447	1852	2130	2059	1853	1405	915	651	508	(44)	
(45)		RadStd	67	112	126	194	103	121	134	158	117	113	63	62	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	N/A	N/A	N/A	+2.02	N/A	N/A	N/A	N/A	N/A	+207

Nomenclature: See separate page