

GANJA INTL, Azerbaijan

WMO: 378630

Lat: 40.738N

Lon: 46.318E

Elev: 1083

StdP: 14.13

Time Zone: 4.00 (E04)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.8	26.4	13.6	11.4	32.0	16.1	12.9	33.8	25.0	44.4	21.6	45.8	5.1	220	0.481

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.2	96.9	67.8	94.7	67.7	91.8	67.5	72.5	87.9	71.1	85.9	70.1	85.3	11.6	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.0	107.2	78.7	66.3	100.9	78.3	64.7	95.1	77.7	36.9	88.3	35.8	86.3	34.9	85.4	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.6	20.3	17.4	19.3	100.9	5.1	2.8	15.6	102.9	12.6	104.5	9.7	106.0	6.0	108.0		
			17.8	74.4	4.8	1.8	14.3	75.7	11.5	76.7	8.8	77.7	5.3	79.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	59.3	38.1	40.0	48.3	56.4	67.3	76.7	81.2	80.6	71.7	60.6	48.5	40.9
	DBStd	16.54	6.32	7.03	6.03	7.10	5.74	5.16	4.61	5.15	5.69	6.05	6.32	5.62
	HDD50	1172	369	286	105	22	0	0	0	0	0	5	99	286
	HDD65	3776	833	700	519	270	42	1	0	0	11	158	495	747
	CDD50	4567	1	6	51	213	538	801	966	949	651	334	54	3
	CDD65	1697	0	0	0	11	114	351	501	485	213	22	0	0
	CDH74	17659	0	0	5	101	873	3546	5907	5550	1574	102	1	0
	CDH80	7925	0	0	0	14	212	1519	2944	2743	482	11	0	0
Wind	WSAvg	7.3	6.5	6.3	8.3	8.1	7.9	8.4	8.8	8.1	7.3	5.9	5.7	6.2
Precipitation	PrecAvg	10.8	0.4	0.6	0.7	1.3	1.7	2.3	1.0	0.7	0.7	1.1	0.6	0.5
	PrecMax	14.2	1.4	1.7	2.1	3.5	5.7	18.9	3.0	2.9	2.5	3.2	1.7	1.1
	PrecMin	6.4	0.0	0.1	0.0	0.2	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.2	0.3	0.4	0.5	0.7	1.1	3.1	0.8	0.7	0.7	0.8	0.4	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.6	64.5	71.9	82.4	89.5	97.1	100.5	100.1	91.7	81.0	69.7	62.2
		MCWB	46.0	48.8	54.4	61.5	64.5	66.7	68.7	68.3	67.0	63.1	55.3	46.8
	2%	DB	55.3	59.1	67.7	76.9	84.6	93.4	97.0	96.8	88.2	76.8	64.6	57.0
		MCWB	43.9	46.6	51.4	59.4	63.5	67.1	68.6	67.3	67.0	61.7	53.2	46.9
	5%	DB	50.4	55.0	62.9	73.3	82.3	91.2	94.8	94.8	85.7	73.5	61.1	53.4
		MCWB	41.1	44.6	49.8	58.2	62.7	66.6	68.4	67.1	66.2	60.8	52.0	45.0
	10%	DB	47.8	50.2	59.2	69.6	78.9	88.0	91.8	91.7	82.4	70.2	58.6	50.0
		MCWB	40.0	42.5	48.4	57.0	62.4	66.1	68.0	67.5	65.5	59.3	50.9	43.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.8	50.3	57.1	63.8	68.4	71.7	75.5	73.8	72.1	65.2	58.2	50.2
		MCDB	57.3	60.0	68.4	77.5	81.2	86.6	91.4	89.5	84.2	75.7	65.2	57.1
	2%	WB	44.4	47.7	53.7	61.2	66.6	70.0	73.2	71.9	70.1	63.7	55.2	47.7
		MCDB	52.5	57.1	63.7	72.8	79.3	85.8	89.7	86.8	82.3	73.3	60.9	53.8
	5%	WB	42.5	45.2	51.3	59.3	65.1	68.8	71.5	70.8	68.1	62.2	53.5	45.9
		MCDB	48.2	52.5	60.5	70.5	77.2	84.6	86.7	85.8	81.2	70.5	58.9	52.0
	10%	WB	40.9	43.2	49.4	57.5	63.8	67.8	70.4	69.8	66.8	60.8	51.8	44.0
		MCDB	45.7	48.0	57.5	67.7	75.2	83.4	85.9	85.1	78.9	68.2	57.9	48.6
Mean Daily Temperature Range	5% DB	MDBR	13.7	13.5	16.4	17.0	18.4	19.5	19.2	19.1	16.7	14.4	14.1	14.0
		MCDBR	20.1	22.5	23.3	23.1	23.1	22.7	22.2	22.4	20.6	18.9	19.4	19.3
		MCWBR	11.8	12.4	11.9	10.5	8.5	7.2	7.0	7.4	7.2	8.5	10.9	11.6
	5% WB	MCDBR	16.8	19.2	20.2	20.7	19.8	20.3	19.1	19.2	18.0	16.1	15.2	17.1
		MCWBR	10.5	11.0	11.1	10.2	8.6	7.3	6.8	7.2	7.2	8.0	8.8	10.7
Clear-Sky Solar Irradiance	taub	0.343	0.379	0.426	0.495	0.473	0.466	0.512	0.499	0.452	0.419	0.367	0.343	
	taud	2.311	2.194	2.094	1.952	2.083	2.152	2.034	2.067	2.176	2.207	2.304	2.324	
	Ebn at Noon	252	259	259	248	258	259	246	245	248	241	241	242	
	Edh at Noon	29	37	46	57	51	48	53	50	42	36	29	26	
All-Sky Solar Radiation	RadAvg	606	817	1106	1402	1734	2014	1985	1821	1394	939	676	537	
	RadStd	60	110	106	189	96	149	147	181	111	100	75	67	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (14 neighbors)	+0.86	N/A	+2.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page