

GANJA INTL, Azerbaijan

WMO: 378630

Lat: 40.738N

Lon: 46.318E

Elev: 330

StdP: 97.42

Time Zone: 4.00 (E04)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.1	-3.1	-10.2	1.6	0.0	-8.9	1.8	1.0	11.2	6.9	9.7	7.7	2.3	220	0.481

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	36.0	19.9	34.9	19.8	33.2	19.7	22.5	31.0	21.7	30.0	21.2	29.6	5.2	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	15.3	26.0	19.1	14.4	25.7	18.1	13.6	25.4	67.9	31.3	65.3	30.1	63.2	29.7	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.5	9.1	7.8	-7.1	38.3	2.8	1.5	-9.1	39.4	-10.8	40.3	-12.4	41.1	-14.4	42.2		
(5)			-7.9	23.5	2.7	1.0	-9.8	24.3	-11.4	24.9	-12.9	25.4	-14.8	26.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.2	3.4	4.4	9.0	13.5	19.6	24.8	27.3	27.0	22.1	15.9	9.2	4.9	(6)
(7)		DBStd	9.19	3.51	3.91	3.35	3.95	3.19	2.86	2.56	2.86	3.16	3.36	3.51	3.12	(7)
(8)		HDD10.0	651	205	159	58	12	0	0	0	0	0	3	55	159	(8)
(9)		HDD18.3	2098	463	389	288	150	23	1	0	0	6	88	275	415	(9)
(10)		CDD10.0	2537	1	3	28	118	299	445	537	527	362	186	30	2	(10)
(11)		CDD18.3	943	0	0	0	6	63	195	278	269	118	12	0	0	(11)
(12)		CDH23.3	9811	0	0	3	56	485	1970	3282	3083	874	57	1	0	(12)
(13)		CDH26.7	4403	0	0	0	8	118	844	1636	1524	268	6	0	0	(13)
(14)	Wind	WSAvg	3.3	2.9	2.8	3.7	3.6	3.5	3.8	3.9	3.6	3.3	2.6	2.5	2.8	(14)
(15)	Precipitation	PrecAvg	274	10	15	18	32	42	58	25	18	18	28	15	12	(15)
(16)		PrecMax	360	36	42	54	89	144	480	75	74	64	81	42	28	(16)
(17)		PrecMin	162	0	2	0	4	9	0	0	0	1	0	0	0	(17)
(18)		PrecStd	55	8	11	12	19	27	80	20	17	18	20	10	9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.9	18.1	22.1	28.0	32.0	36.2	38.1	37.8	33.1	27.2	20.9	16.8	(19)
(20)			MCWB	7.8	9.3	12.4	16.4	18.1	19.3	20.4	20.2	19.4	17.3	13.0	8.2	(20)
(21)		2%	DB	13.0	15.0	19.8	25.0	29.2	34.1	36.1	36.0	31.2	24.9	18.1	13.9	(21)
(22)			MCWB	6.6	8.1	10.8	15.2	17.5	19.5	20.3	19.6	19.4	16.5	11.8	8.3	(22)
(23)		5%	DB	10.2	12.8	17.2	22.9	27.9	32.9	34.9	34.9	29.8	23.0	16.1	11.9	(23)
(24)			MCWB	5.0	7.0	9.9	14.6	17.0	19.2	20.2	19.5	19.0	16.0	11.1	7.2	(24)
(25)		10%	DB	8.8	10.1	15.1	20.9	26.1	31.1	33.2	33.2	28.0	21.2	14.8	10.0	(25)
(26)			MCWB	4.5	5.8	9.1	13.9	16.9	19.0	20.0	19.7	18.6	15.2	10.5	6.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	10.2	14.0	17.7	20.2	22.0	24.2	23.2	22.3	18.4	14.6	10.1	(27)
(28)			MCD B	14.1	15.6	20.2	25.3	27.4	30.3	33.0	32.0	29.0	24.3	18.4	13.9	(28)
(29)		2%	WB	6.9	8.7	12.1	16.2	19.2	21.1	22.9	22.2	21.2	17.6	12.9	8.7	(29)
(30)			MCD B	11.4	13.9	17.6	22.7	26.3	29.9	32.0	30.5	27.9	22.9	16.0	12.1	(30)
(31)		5%	WB	5.8	7.3	10.7	15.2	18.4	20.5	22.0	21.6	20.0	16.8	12.0	7.7	(31)
(32)			MCD B	9.0	11.4	15.8	21.4	25.1	29.2	30.4	29.9	27.3	21.4	14.9	11.1	(32)
(33)		10%	WB	4.9	6.2	9.7	14.1	17.7	19.9	21.3	21.0	19.3	16.0	11.0	6.7	(33)
(34)			MCD B	7.6	8.9	14.2	19.8	24.0	28.6	29.9	29.5	26.0	20.1	14.4	9.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.6	7.5	9.1	9.4	10.2	10.8	10.7	10.6	9.3	8.0	7.8	7.8	(35)
(36)			MCDBR	11.2	12.5	13.0	12.8	12.8	12.6	12.3	12.5	11.5	10.5	10.8	10.7	(36)
(37)			MCWBR	6.6	6.9	6.6	5.8	4.7	4.0	3.9	4.1	4.0	4.7	6.0	6.4	(37)
(38)		5% WB	MCD BR	9.3	10.7	11.2	11.5	11.0	11.3	10.6	10.7	10.0	8.9	8.4	9.5	(38)
(39)			MCWBR	5.8	6.1	6.2	5.7	4.8	4.1	3.8	4.0	4.0	4.4	4.9	5.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.343	0.379	0.426	0.495	0.473	0.466	0.512	0.499	0.452	0.419	0.367	0.343	(40)	
(41)		taud	2.311	2.194	2.094	1.952	2.083	2.152	2.034	2.067	2.176	2.207	2.304	2.324	(41)	
(42)		Ebn at Noon	796	815	815	783	813	817	774	771	782	761	759	762	(42)	
(43)		Edh at Noon	90	117	145	179	161	150	168	158	133	115	91	83	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.91	2.58	3.49	4.42	5.47	6.35	6.26	5.74	4.39	2.96	2.13	1.69	(44)	
(45)		RadStd	0.19	0.35	0.33	0.60	0.30	0.47	0.46	0.57	0.35	0.32	0.24	0.21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)		+0.48	N/A	+1.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page