

NAKHCHIVAN, Azerbaijan

WMO: 378635

Lat: 39.189N

Lon: 45.458E

Elev: 2863

StdP: 13.24

Time Zone: 4.00 (E04)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.2	6.8	-3.7	5.0	0.8	2.8	7.0	9.0	16.8	38.4	14.8	38.6	3.7	20	0.521

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.7	102.2	65.0	99.0	64.4	96.6	64.2	67.7	92.8	66.6	91.3	65.7	89.8	7.4	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.5	87.6	72.4	58.9	82.5	73.9	57.3	77.8	74.5	33.8	93.8	32.9	91.4	32.2	89.9	72.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	16.7	14.6	2.2	106.1	10.2	2.6	-5.1	108.0	-11.0	109.5	-16.7	111.0	-24.1	112.9
			1.5	69.8	9.8	1.0	-5.6	70.5	-11.3	71.1	-16.7	71.7	-23.8	72.5
			DB											
			WB											

Monthly Climatic Design Conditions

			Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(6)
(7)		DBStd	57.2	26.9	34.7	47.0	56.4	65.8	76.3	82.9	82.9	73.6	59.9	44.7	33.4	(7)
(8)		HDD50	20.30	11.66	10.05	7.49	6.30	4.83	5.23	5.31	5.18	6.58	6.49	6.84	8.86	(8)
(9)		HDD65	2011	717	430	145	14	0	0	0	0	0	7	183	515	(9)
(10)		CDD50	4687	1182	849	559	268	48	1	0	0	12	179	609	980	(10)
(11)		CDD65	4625	0	1	51	205	491	790	1020	1020	708	315	24	0	(11)
(12)		CDH74	1827	0	0	0	9	74	341	556	555	270	22	0	0	(12)
(13)		CDH80	23261	0	0	18	168	1002	4202	7405	7272	2909	285	0	0	(13)
(14)			12163	0	0	1	46	285	2110	4229	4113	1326	53	0	0	(14)
(14)	Wind	WSAvg	6.8	4.5	5.5	7.0	7.4	7.1	7.6	9.1	9.1	7.9	6.3	5.3	4.5	(14)
(15)	Precipitation	PrecAvg	9.8	1.3	0.6	1.2	1.6	1.5	0.9	0.3	0.2	0.3	0.9	0.7	0.8	(15)
(16)		PrecMax	14.3	20.2	1.8	2.9	5.2	3.4	3.3	2.3	1.5	2.0	2.8	2.0	2.3	(16)
(17)		PrecMin	5.4	0.0	0.0	0.2	0.4	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	2.5	3.3	0.4	0.6	0.9	0.8	0.8	0.4	0.4	0.5	0.7	0.6	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.3	61.1	76.8	86.0	91.1	100.6	106.0	105.7	100.4	84.6	68.4	57.6	(19)
MCWB			43.5	46.7	52.7	56.5	60.2	64.0	66.2	65.2	63.0	57.7	52.5	45.4	(20)	
2%		DB	50.2	57.0	69.4	78.7	86.2	97.0	102.5	102.2	95.1	80.7	64.1	52.0	(21)	
		MCWB	41.1	44.7	50.7	55.3	59.4	63.5	65.5	64.6	62.3	57.3	50.1	43.0	(22)	
5%		DB	46.2	53.5	64.7	73.6	82.7	93.6	100.0	99.0	91.3	77.0	60.4	48.2	(23)	
		MCWB	39.8	43.4	48.4	54.0	58.7	63.0	65.5	64.2	61.8	56.6	48.6	41.5	(24)	
10%		DB	42.4	49.8	61.0	69.9	80.2	91.2	96.6	96.6	87.8	73.3	56.9	44.8	(25)	
		MCWB	37.8	41.6	46.9	52.5	58.4	62.4	65.2	63.9	61.3	56.0	47.4	40.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.4	48.4	54.4	58.4	64.3	67.4	69.7	68.4	66.5	61.3	54.4	46.9	(27)
MCD B			53.4	56.7	70.1	75.8	80.7	89.4	96.4	94.6	89.0	74.7	64.5	54.0	(28)	
2%		WB	42.0	46.0	51.8	56.7	62.0	65.6	68.2	67.2	64.7	59.3	52.1	44.4	(29)	
		MCD B	47.4	54.7	67.6	73.5	78.6	88.9	94.1	92.5	87.3	73.9	60.7	50.2	(30)	
5%		WB	39.9	43.9	49.5	55.3	60.8	64.6	67.2	66.3	63.5	57.9	50.1	42.6	(31)	
		MCD B	45.1	51.9	62.3	70.0	77.1	87.6	92.5	90.7	85.3	73.1	57.4	46.3	(32)	
10%		WB	37.4	41.7	47.7	53.9	59.5	63.6	66.3	65.3	62.4	56.6	48.1	40.6	(33)	
		MCD B	42.1	49.0	59.7	67.1	75.2	85.8	91.0	89.9	83.2	71.2	55.4	44.6	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	15.5	18.7	21.7	22.7	25.6	27.4	25.7	25.6	25.5	23.3	20.1	14.6	(35)
MCD BR			20.1	24.1	26.9	28.1	30.2	30.3	28.5	28.3	29.1	28.4	24.6	20.4	(36)	
MCWBR			12.7	14.0	12.5	11.3	10.3	8.3	7.3	7.7	8.8	11.7	13.5	13.1	(37)	
5% WB		MCD BR	18.2	22.1	23.6	24.5	27.3	28.2	26.1	26.1	26.5	25.1	19.1	16.9	(38)	
		MCWBR	11.8	13.0	11.5	10.4	10.1	8.1	7.0	7.1	8.1	10.8	10.8	11.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.313	0.346	0.403	0.474	0.456	0.439	0.477	0.452	0.403	0.391	0.334	0.311	(40)	
(41)		taud	2.361	2.261	2.108	1.948	2.064	2.154	2.061	2.128	2.246	2.218	2.355	2.383	(41)	
(42)		Ebn at Noon	270	274	268	256	263	267	256	259	266	254	259	262	(42)	
(43)		Edh at Noon	28	35	46	57	52	48	52	47	40	36	28	25	(43)	
(44)	All-Sky Solar Radiation	RadAvg	756	1071	1277	1571	1977	2415	2391	2184	1776	1170	790	594	(44)	
(45)		RadStd	71	121	103	163	98	129	76	64	93	79	91	76	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (11 neighbors)	N/A	N/A	N/A	+1.98	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page