

JASLIQ, Uzbekistan

WMO: 381410

Lat: 43.971N

Lon: 57.500E

Elev: 417

StdP: 14.48

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.8	-4.9	-18.5	2.0	-10.4	-13.0	2.8	-4.4	49.4	6.3	45.4	18.1	6.2	90	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.0	104.1	67.3	101.1	66.4	98.2	65.7	70.0	96.0	68.4	95.0	67.0	93.7	8.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.8	80.9	79.3	58.0	72.9	79.5	55.7	67.1	79.6	34.1	95.5	32.8	94.9	31.7	93.5	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 44.8	36.4	32.8	-14.5	109.0	7.7	3.6	-20.0	111.6	-24.5	113.8	-28.8	115.8	-34.5	118.4		
(5)			-14.9	74.3	7.5	3.3	-20.3	76.7	-24.7	78.6	-29.0	80.4	-34.4	82.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.4	18.8	22.0	40.7	55.8	70.3	79.5	83.6	79.6	66.5	50.6	35.1	24.5		
	DBStd	24.55	12.29	11.99	9.35	9.29	6.86	6.28	6.16	6.97	7.65	8.77	10.66	10.03		
	HDD50	3453	968	785	311	45	0	0	0	0	1	98	454	791		
	HDD65	6403	1433	1205	754	303	28	2	0	2	71	451	898	1256		
	CDD50	4333	0	0	22	218	629	885	1042	918	496	117	6	0		
	CDD65	1806	0	0	0	26	192	437	577	454	116	4	0	0		
	CDH74	25371	0	0	8	368	2448	6268	8537	6244	1415	83	0	0		
	CDH80	14309	0	0	1	111	1065	3611	5277	3677	554	13	0	0		
	WSAvg	10.0	10.6	12.0	12.2	11.2	12.4	10.3	9.1	8.9	8.8	8.2	7.6	9.2		
	PrecAvg	4.7	0.4	0.3	0.6	0.7	0.6	0.4	0.2	0.2	0.1	0.3	0.5	0.5		
(15) Precipitation	PrecMax	9.5	1.5	1.6	1.6	1.8	2.4	1.6	0.5	0.9	0.7	1.3	1.2	1.5		
	PrecMin	1.8	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	1.8	0.3	0.3	0.4	0.4	0.6	0.4	0.2	0.2	0.2	0.3	0.4	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.5	49.1	72.8	88.4	97.0	105.5	109.6	106.1	96.4	81.4	65.0	49.4		
		MCWB	40.1	41.0	56.8	61.8	64.0	67.5	68.0	67.5	64.5	58.1	53.5	39.6		
	2%	DB	39.6	42.9	65.3	83.3	93.2	101.8	105.3	102.5	90.5	75.8	58.5	42.6		
		MCWB	35.2	36.7	51.9	60.5	62.9	66.7	67.5	66.9	63.0	56.0	47.6	37.4		
	5%	DB	35.9	38.4	59.9	78.0	89.8	98.7	102.0	99.6	86.2	70.9	53.6	39.1		
		MCWB	32.3	33.1	49.3	58.5	62.6	65.4	66.8	66.3	61.3	53.6	44.1	34.8		
	10%	DB	33.3	35.5	55.1	72.7	86.1	95.6	98.7	96.1	82.3	66.3	48.8	35.9		
		MCWB	30.1	31.2	45.9	55.8	61.1	64.5	65.8	65.3	59.4	51.5	41.4	32.2		
	0.4%	WB	40.9	41.4	58.5	65.2	68.0	71.0	72.6	71.4	66.6	60.2	54.4	41.3		
		MCDB	43.7	49.0	72.0	84.0	88.0	97.6	96.2	98.8	89.7	78.2	64.4	47.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	35.7	37.0	53.1	61.5	65.4	69.0	70.3	69.2	64.2	57.3	48.6	38.0		
		MCDB	38.4	42.3	64.0	80.7	87.0	95.4	96.2	96.6	88.1	73.0	56.0	42.2		
	5%	WB	32.6	33.8	49.3	59.0	63.8	67.3	68.5	67.5	62.1	54.9	45.0	35.2		
		MCDB	35.4	37.7	59.3	76.8	85.7	93.3	95.4	95.3	83.9	69.2	51.6	38.9		
	10%	WB	30.4	31.4	46.1	56.3	62.4	65.8	67.1	66.0	60.3	52.3	42.2	32.5		
		MCDB	33.1	35.2	54.9	71.4	83.8	91.3	94.6	93.4	80.6	65.0	48.0	35.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.0	15.3	18.7	22.5	24.3	25.8	25.0	26.1	25.2	23.5	16.7	12.2		
		MCDBR	12.3	16.1	26.9	29.3	29.0	28.8	28.1	30.5	29.5	29.5	25.0	16.1		
		MCWBR	10.2	12.7	18.1	15.0	12.3	10.9	9.6	11.3	13.1	16.1	17.2	12.8		
		MCDBR	11.6	15.4	26.3	27.9	26.1	26.2	26.0	28.5	27.3	27.1	21.4	14.7		
	5% WB	MCWBR	10.0	12.5	18.1	15.8	13.0	11.7	11.2	12.1	13.4	15.6	15.4	12.2		
(40) Clear-Sky Solar Irradiance	taub		0.368	0.393	0.464	0.518	0.516	0.497	0.483	0.462	0.431	0.427	0.391	0.369		
	taud		2.050	1.997	1.870	1.770	1.819	1.899	1.960	1.995	2.026	1.984	2.051	2.050		
	Ebn at Noon		223	242	239	238	244	249	251	251	248	226	212	207		
	Edh at Noon		34	43	56	67	65	61	56	53	47	43	34	31		
(44) All-Sky Solar Radiation	RadAvg		443	746	1192	1681	2087	2343	2242	2032	1588	1044	605	387		
	RadStd		69	101	115	131	114	96	80	91	75	62	69	63		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	+2.12	-0.85	-1.62	N/A	N/A	N/A	+176

Nomenclature: See separate page