

AK-BAJTAL, Uzbekistan

WMO: 381780

Lat: 43.1543N

Lon: 64.3212E

Elev: 776

StdP: 14.29

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.2	-0.2	-15.5	2.4	-4.3	-9.6	3.4	1.6	29.9	29.5	23.2	27.0	5.7	0	0.536

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.5	104.0	70.5	100.9	69.1	98.2	68.0	71.9	100.5	70.2	98.3	68.8	96.2	8.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.1	82.7	85.6	58.5	75.4	86.7	56.4	69.6	86.7	36.1	100.5	34.6	98.3	33.4	96.4	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
26.9	20.4	16.7	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-9.6	108.9	7.4	3.4	-14.9	111.3	-19.2	113.3	-23.3	115.3	-28.7	117.8		
			-10.0	75.2	7.2	3.1	-15.2	77.4	-19.4	79.2	-23.5	80.9	-28.8	83.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	55.4	23.9	28.0	43.8	58.5	71.5	81.2	84.8	82.0	69.2	54.5	38.8	27.3	(6)
(7)		DBStd	23.69	11.58	12.74	11.00	9.81	7.49	6.75	5.94	6.64	8.45	9.94	10.52	11.29	(7)
(8)		HDD50	2849	810	621	252	34	0	0	0	0	1	68	359	704	(8)
(9)		HDD65	5593	1275	1037	662	239	26	1	0	0	52	346	786	1169	(9)
(10)		CDD50	4831	0	4	59	288	667	937	1077	991	576	208	23	1	(10)
(11)		CDD65	2097	0	0	3	43	228	488	612	526	177	20	0	0	(11)
(12)		CDH74	28736	0	0	49	481	2706	6895	9089	7282	1987	242	5	0	(12)
(13)		CDH80	15963	0	0	13	149	1181	3953	5514	4232	862	59	0	0	(13)
(14)	Wind	WSAvg	7.6	6.6	7.4	8.3	8.4	8.3	8.0	7.9	8.1	7.1	6.8	6.7	7.2	(14)
(15)	Precipitation	PrecAvg	4.9	0.5	0.5	0.7	0.8	0.7	0.3	0.1	0.1	0.0	0.2	0.6	0.4	(15)
(16)		PrecMax	11.2	1.5	1.7	2.1	3.0	3.0	2.3	0.7	0.5	0.2	1.1	1.7	1.7	(16)
(17)		PrecMin	1.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	2.1	0.3	0.4	0.6	0.7	0.8	0.5	0.2	0.2	0.0	0.3	0.5	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.4	64.6	80.7	90.4	98.0	105.9	109.5	106.2	98.8	86.3	72.3	57.2	(19)
MCWB			44.6	50.0	59.2	64.5	67.6	71.6	73.4	70.4	67.9	61.7	54.6	43.9	(20)	
2%		DB	46.8	54.9	71.4	84.3	93.6	102.1	105.0	102.4	93.7	80.3	64.5	50.2	(21)	
		MCWB	40.5	45.8	54.4	60.8	66.0	69.8	71.2	69.2	65.7	58.3	50.7	42.0	(22)	
5%		DB	41.3	48.8	65.6	79.4	90.4	98.9	101.3	99.2	88.9	75.7	58.8	45.3	(23)	
		MCWB	35.9	41.4	51.1	58.6	64.4	68.0	69.5	68.5	63.1	56.4	47.6	38.5	(24)	
10%		DB	37.3	43.8	60.4	75.0	86.7	95.9	98.4	96.3	84.9	71.0	53.8	41.3	(25)	
		MCWB	33.2	37.8	48.5	56.4	62.7	66.8	68.2	67.4	61.2	53.8	44.9	36.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.1	52.6	59.7	65.6	69.6	73.8	74.1	73.0	68.7	62.3	56.0	46.8	(27)
MDCB			51.9	62.9	75.9	85.7	94.1	101.2	104.6	101.1	97.1	83.5	67.9	54.6	(28)	
2%		WB	40.6	46.4	55.5	62.2	66.7	70.8	72.3	70.7	65.9	59.3	51.9	42.2	(29)	
		MDCB	46.2	53.8	69.6	81.1	90.5	98.8	101.8	99.1	92.4	78.4	62.3	49.2	(30)	
5%		WB	36.6	41.9	52.1	59.5	65.2	69.1	70.7	69.3	63.7	56.8	48.6	39.2	(31)	
		MDCB	40.8	48.0	64.0	77.3	88.3	96.9	99.0	97.3	88.2	74.1	57.5	44.6	(32)	
10%		WB	33.4	38.2	49.1	56.9	63.4	67.5	69.0	67.7	61.4	54.2	45.4	36.2	(33)	
		MDCB	36.8	43.6	60.0	73.8	85.2	94.1	96.4	95.0	84.0	70.3	52.8	40.9	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.5	16.3	20.0	21.5	23.3	23.1	22.5	23.0	23.2	21.8	16.6	14.2	(35)
MCDBR			16.7	22.3	26.8	26.3	26.9	26.0	25.2	25.1	26.4	26.6	22.6	19.2	(36)	
MCWBR			12.4	15.1	15.4	13.5	13.0	11.9	11.2	11.7	13.1	14.6	13.8	13.3	(37)	
5% WB		MCDBR	16.0	21.3	25.1	25.5	25.5	25.0	24.6	24.6	25.6	25.9	20.8	17.7	(38)	
		MCWBR	12.1	14.8	15.4	13.8	13.2	12.5	11.6	12.2	13.1	14.9	13.2	12.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.352	0.381	0.436	0.480	0.478	0.464	0.444	0.420	0.391	0.394	0.376	0.348	(40)	
(41)		taud	2.121	2.063	1.964	1.898	1.945	2.015	2.091	2.136	2.168	2.098	2.112	2.138	(41)	
(42)		Ebn at Noon	235	249	250	250	254	258	262	265	263	241	223	223	(42)	
(43)		Edh at Noon	32	41	51	59	58	54	50	46	41	39	33	29	(43)	
(44)	All-Sky Solar Radiation	RadAvg	503	828	1282	1764	2208	2451	2402	2184	1749	1157	685	455	(44)	
(45)		RadStd	71	111	115	141	134	92	87	62	57	65	71	61	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	-2.79	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	-1.13	-3.24	N/A	N/A	N/A	N/A

Nomenclature: See separate page