

TALAS, Kyrgyzstan

WMO: 383450

Lat: 42.517N

Lon: 72.217E

Elev: 1218

StdP: 87.52

Time Zone: 6.00 (E06)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.5	-15.3	-22.3	0.6	-17.4	-19.4	0.8	-14.1	4.9	-3.3	3.9	-1.9	0.7	90	0.453

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	31.7	18.3	30.2	17.5	28.9	16.9	19.5	29.6	18.5	28.3	17.6	27.1	1.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.8	13.0	24.8	14.7	12.1	23.7	13.7	11.4	23.0	61.3	29.5	57.5	28.3	54.6	27.1	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.1	3.9	3.0	-21.4	34.5	4.9	1.3	-25.0	35.4	-27.9	36.2	-30.6	36.9	-34.2	37.9		
(5)			-21.7	21.2	4.7	1.8	-25.1	22.5	-27.9	23.5	-30.5	24.5	-33.9	25.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.5	-3.6	-1.8	5.1	10.3	15.4	19.5	21.2	20.0	15.2	9.8	3.6	-1.9
	DBStd	9.68	5.23	5.42	5.17	4.76	3.46	2.92	2.58	2.79	3.68	4.47	5.17	5.18
	HDD10.0	1602	420	330	164	54	3	0	0	0	4	58	201	368
	HDD18.3	3477	678	563	410	243	102	20	6	15	106	264	443	626
	CDD10.0	1409	0	0	13	61	170	287	347	312	159	52	8	0
	CDD18.3	242	0	0	0	1	11	56	94	68	11	1	0	0
	CDH23.3	2993	0	0	1	37	183	659	1034	827	222	28	1	0
CDH26.7	912	0	0	0	4	33	197	360	269	44	4	0	0	
Wind	WSAvg	1.2	1.0	1.1	1.3	1.4	1.4	1.3	1.2	1.2	1.2	1.1	1.0	1.0
Precipitation	PrecAvg	327	16	20	37	54	53	34	19	9	13	25	28	22
	PrecMax	532	38	48	77	161	117	125	102	31	44	67	80	90
	PrecMin	228	0	4	18	7	15	4	0	0	0	1	2	3
	PrecStd	66	9	11	16	29	26	23	21	9	11	16	18	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.1	13.7	22.6	27.3	29.6	32.7	33.7	33.2	30.1	26.5	21.4	12.8
		MCWB	5.5	6.8	10.7	15.0	15.4	17.7	20.1	18.8	16.5	13.4	10.8	5.6
	2%	DB	7.8	10.1	19.5	24.2	27.3	30.8	32.0	31.1	27.8	23.1	17.1	9.6
		MCWB	2.6	4.8	9.7	12.7	14.9	17.1	19.2	18.0	15.5	12.0	8.3	3.7
	5%	DB	5.3	7.7	16.5	21.6	25.3	29.0	30.2	29.7	26.1	20.8	13.8	7.2
		MCWB	1.3	3.1	8.7	11.6	14.4	16.5	18.0	17.5	14.8	11.0	7.1	2.5
	10%	DB	3.2	5.4	13.6	19.0	23.4	27.2	28.7	28.0	23.9	18.1	10.8	4.9
		MCWB	0.0	1.8	7.4	10.7	13.7	16.0	17.4	16.8	13.7	9.9	5.7	1.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.5	7.4	12.0	16.3	17.2	19.5	21.5	20.2	18.0	14.4	11.5	6.3
		MCDB	11.5	12.7	20.2	24.0	26.0	29.3	31.2	30.7	27.6	24.6	19.3	11.6
	2%	WB	3.0	5.2	10.3	14.1	15.8	18.1	20.1	18.9	16.4	12.8	9.2	4.2
		MCDB	7.3	9.6	17.9	21.9	24.6	27.8	30.1	29.3	26.3	22.0	15.8	8.9
	5%	WB	1.5	3.5	9.1	12.5	15.0	17.2	18.9	17.9	15.1	11.6	7.5	2.7
		MCDB	4.9	7.0	15.8	19.6	23.6	26.9	28.8	28.3	24.9	19.3	12.9	6.6
	10%	WB	0.2	2.0	7.6	11.3	14.2	16.5	18.0	17.1	14.0	10.4	6.0	1.4
		MCDB	2.9	5.2	13.1	17.8	22.3	25.7	27.1	26.9	23.3	17.0	10.4	4.7
Mean Daily Temperature Range	5% DB	MDBR	11.0	10.5	11.5	12.0	13.1	13.5	13.9	14.7	15.1	13.9	11.4	10.9
		MCDBR	13.0	13.1	16.2	16.6	16.0	16.0	15.7	16.4	17.7	17.9	15.7	13.9
		MCWBR	9.1	8.8	8.9	8.2	7.4	7.1	7.5	7.7	8.4	9.0	8.6	9.0
	5% WB	MCDBR	12.2	12.1	14.8	14.5	14.7	14.4	14.7	15.6	16.7	16.1	14.2	12.8
		MCWBR	8.6	8.5	8.7	8.2	7.5	7.2	7.7	8.0	8.5	8.8	8.2	8.7
Clear-Sky Solar Irradiance	taub	0.364	0.423	0.524	0.555	0.526	0.516	0.506	0.462	0.439	0.477	0.435	0.356	
	taud	1.918	1.809	1.696	1.690	1.815	1.865	1.900	2.008	2.007	1.839	1.869	1.969	
	Ebn at Noon	714	732	703	724	764	772	775	797	780	667	623	683	
	Edh at Noon	126	168	213	230	209	199	190	165	153	161	133	110	
All-Sky Solar Radiation	RadAvg	2.06	2.95	3.79	4.82	6.10	6.79	6.91	6.51	5.20	3.22	2.00	1.71	
	RadStd	0.14	0.26	0.27	0.46	0.48	0.41	0.44	0.37	0.29	0.43	0.26	0.15	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	+0.67	+0.73	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	-0.76	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page