

EKEDGE, Turkmenistan

WMO: 383880

Lat: 41.033N

Lon: 57.767E

Elev: 203

StdP: 14.59

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.4	7.5	-6.0	4.0	3.3	-0.1	5.5	12.3	18.4	35.1	17.2	35.8	2.7	50	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.9	107.8	71.4	105.0	70.1	102.4	69.1	76.4	99.9	73.9	98.5	71.7	96.7	6.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.5	105.3	92.8	65.2	93.9	88.4	62.3	84.6	86.5	40.0	100.0	37.6	98.6	35.5	96.7	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.5	17.0	14.1	DB	-5.5	111.9	10.8	2.3	-13.3	113.5	-19.6	114.9	-25.7	116.2	-33.6	117.9	
			WB	-6.1	77.4	10.5	4.2	-13.6	80.4	-19.8	82.9	-25.6	85.3	-33.3	88.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	58.9	29.4	34.3	47.8	61.4	74.1	83.4	87.6	84.1	71.5	56.8	42.5	32.8	
	DBStd	22.16	10.91	10.83	9.51	9.27	7.30	5.99	5.76	6.50	7.52	9.26	9.54	8.78	
	HDD50	2087	640	445	155	15	0	0	0	0	0	40	258	534	
	HDD65	4673	1104	860	539	174	15	0	0	0	25	281	677	998	
	CDD50	5346	0	5	86	357	747	1001	1165	1056	645	252	31	1	
	CDD65	2460	0	0	5	66	297	552	700	591	220	28	1	0	
	CDH74	37086	0	0	69	826	3858	8518	11423	9052	2923	404	13	0	
	CDH80	22623	0	0	17	322	1955	5365	7621	5812	1412	117	2	0	
Wind	WSAvg	5.4	4.7	5.5	6.2	6.2	5.9	6.0	5.5	5.4	5.2	4.8	4.7	4.8	
Precipitation	PrecAvg	4.4	0.4	0.5	0.7	0.7	0.6	0.2	0.1	0.0	0.1	0.3	0.4	0.3	
	PrecMax	8.1	1.1	1.1	2.1	2.6	2.7	1.2	0.3	0.7	1.0	1.1	1.8	1.4	
	PrecMin	1.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	PrecStd	1.8	0.3	0.3	0.5	0.6	0.6	0.4	0.1	0.2	0.2	0.3	0.5	0.4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.2	66.8	82.0	95.0	101.4	108.4	113.1	110.7	101.4	88.9	75.0	59.7	
		MCWB	47.6	49.5	59.0	63.8	68.8	72.0	73.8	70.9	67.8	63.4	58.1	48.1	
	2%	DB	49.9	58.6	74.2	88.4	97.2	105.1	108.9	106.8	96.4	83.3	66.6	53.2	
		MCWB	42.8	46.7	55.2	60.9	66.7	70.3	71.9	70.8	65.9	60.4	53.7	44.1	
	5%	DB	45.8	53.2	68.4	82.8	93.7	102.6	105.7	103.7	92.3	78.4	61.9	48.6	
		MCWB	40.0	43.9	52.5	59.5	65.0	69.1	70.3	69.6	63.9	57.3	50.5	42.4	
	10%	DB	42.1	48.2	63.0	78.0	90.4	99.5	102.9	100.6	88.6	74.0	57.3	44.9	
		MCWB	37.9	41.1	49.9	57.6	64.0	67.6	69.6	68.3	62.7	55.7	48.1	39.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.9	50.8	60.0	65.7	74.7	80.7	80.4	77.2	72.9	66.2	59.9	48.8
			MCDB	55.1	64.0	79.0	87.5	95.2	103.3	105.0	98.4	96.6	84.3	72.5	57.1
2%		WB	43.4	47.2	56.3	62.8	69.8	75.4	77.1	73.8	68.7	61.7	55.0	45.6	
		MCDB	48.9	57.1	71.6	83.7	90.9	97.4	101.8	100.0	88.4	79.3	65.2	52.0	
5%		WB	40.6	44.5	53.4	60.8	67.2	72.7	74.5	71.5	65.8	59.1	51.8	42.8	
		MCDB	44.9	52.3	66.8	79.7	87.8	96.0	99.7	98.9	88.9	75.2	59.7	47.8	
10%		WB	38.2	41.8	50.7	58.4	65.2	70.3	72.0	69.6	63.7	56.7	48.8	40.3	
		MCDB	41.7	47.4	62.0	75.7	85.7	94.2	97.3	97.3	86.4	71.6	56.3	44.8	
Mean Daily Temperature Range	5% DB	MDBR	15.7	17.9	21.2	22.7	24.9	26.4	25.9	27.9	28.1	26.1	20.8	15.7	
		MCDBR	20.1	25.6	27.9	29.7	29.5	30.9	28.9	31.6	32.0	31.5	27.1	21.6	
		MCWBR	13.6	15.7	14.3	12.7	12.5	12.0	11.5	12.8	14.2	16.2	16.7	15.0	
	5% WB	MCDDBR	18.5	23.3	25.8	27.2	27.1	27.0	27.0	28.5	29.7	27.9	25.1	19.9	
		MCWBR	13.1	14.9	13.8	12.9	13.8	14.5	14.0	13.7	15.5	15.7	16.0	14.3	
Clear-Sky Solar Irradiance	taub	0.402	0.438	0.495	0.553	0.550	0.552	0.548	0.511	0.479	0.471	0.426	0.398		
	taud	2.001	1.912	1.818	1.728	1.772	1.776	1.800	1.864	1.904	1.896	1.983	2.013		
	Ebn at Noon	221	233	235	232	237	237	236	240	237	219	210	210		
	Edh at Noon	39	49	61	71	69	69	67	61	55	49	39	36		
All-Sky Solar Radiation	RadAvg	567	854	1328	1735	2136	2429	2315	2143	1735	1187	743	510		
	RadStd	69	114	91	129	103	93	84	80	68	74	66	66		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+151

Nomenclature: See separate page