

DASHOGUZ, TurkmenistanWMO: **383920**Lat: **41.761N**Lon: **59.827E**Elev: **82**StdP: **100.34**Time Zone: **5.00 (E05)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.9	-13.2	-21.2	0.6	-15.5	-18.0	0.8	-11.5	9.4	-0.8	8.8	0.1	3.6	0	0.561

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.0	40.0	22.7	38.3	22.1	37.0	21.8	24.5	36.9	23.5	35.9	22.7	35.0	4.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.2	15.0	32.8	19.0	13.9	32.1	17.9	13.0	31.1	74.6	36.6	70.4	36.0	67.2	35.0	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 9.1	8.2	7.5		-17.9	43.0	4.8	1.7	-21.3	44.2	-24.2	45.2	-26.9	46.1	-30.4	47.3	
(5)				-18.3	25.8	4.8	1.6	-21.7	26.9	-24.5	27.8	-27.2	28.7	-30.6	29.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.3	-1.8	0.4	8.0	15.9	23.0	27.8	29.4	27.4	21.0	13.5	5.6	0.0
	DBStd	11.99	5.70	5.69	5.16	5.09	3.81	3.15	2.85	3.35	3.85	4.73	5.21	4.70
	HDD10.0	1224	365	270	99	10	0	0	0	0	0	22	148	311
	HDD18.3	2689	623	502	321	104	8	0	0	0	17	161	383	569
	CDD10.0	2778	0	2	38	187	402	533	602	541	331	128	14	0
	CDD18.3	1201	0	0	2	32	152	283	344	282	98	9	0	0
	CDH23.3	16248	0	0	26	362	1763	3970	5055	3806	1124	139	2	0
	CDH26.7	9076	0	0	6	125	806	2316	3093	2227	470	34	0	0
Wind	WSAvg	4.0	4.0	4.3	4.5	4.6	4.3	4.1	3.9	3.8	3.7	3.6	3.7	4.0
Precipitation	PrecAvg	99	10	10	15	14	13	4	1	2	3	6	10	10
	PrecMax	173	29	29	32	42	48	20	7	8	19	22	33	37
	PrecMin	45	0	1	1	2	1	0	0	0	0	0	0	0
	PrecStd	30	7	8	10	11	12	5	2	2	4	6	10	10
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.9	17.7	27.0	33.5	37.1	41.0	42.9	41.5	37.3	30.2	22.0	14.0
		MCWB	6.8	10.4	15.8	20.0	20.7	23.0	23.2	23.1	21.3	17.0	13.5	8.9
	2%	DB	9.2	13.1	22.2	30.1	34.8	39.0	40.5	39.1	33.7	27.0	18.1	10.6
		MCWB	5.7	7.9	13.5	17.6	19.9	22.3	22.8	22.2	19.7	15.7	11.3	6.7
	5%	DB	6.9	10.3	19.1	27.4	33.0	37.2	38.8	37.6	31.2	24.3	15.9	8.1
		MCWB	4.4	6.2	11.9	15.8	19.2	21.7	22.5	21.9	18.2	14.4	9.9	5.2
	10%	DB	4.9	7.9	16.2	24.9	31.1	35.9	37.0	35.8	29.2	22.0	13.2	6.1
		MCWB	2.8	4.5	10.1	14.8	18.2	21.2	22.1	21.3	17.3	13.2	8.6	3.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	10.7	16.6	20.9	22.8	25.4	26.1	25.1	22.5	18.1	14.5	9.2
		MCDB	11.4	16.8	25.5	31.3	34.0	38.1	38.7	38.6	34.1	26.8	20.3	13.1
	2%	WB	6.1	8.3	14.0	18.4	21.2	23.9	24.8	23.7	20.6	16.3	12.1	7.1
		MCDB	8.9	12.4	21.5	28.6	32.5	36.5	36.7	36.4	32.0	25.5	17.2	9.8
	5%	WB	4.5	6.5	12.3	16.7	19.9	23.0	23.7	22.7	19.2	14.9	10.5	5.5
		MCDB	6.5	9.8	18.5	25.6	30.9	35.4	36.0	35.3	30.0	23.4	14.9	7.9
	10%	WB	2.8	4.8	10.5	15.2	18.9	22.0	22.8	21.7	17.9	13.6	8.9	3.9
		MCDB	4.6	7.6	15.8	23.4	29.4	34.2	35.2	34.1	28.1	21.2	13.0	5.8
Mean Daily Temperature Range	5% DB	MDBR	8.2	9.4	10.9	11.6	12.4	13.0	13.0	14.0	13.7	12.9	10.1	8.3
		MCDBR	10.8	13.1	15.2	14.8	14.7	15.1	15.1	15.8	16.0	16.2	13.4	11.2
		MCWBR	7.7	8.7	8.6	6.8	6.6	6.3	6.0	6.6	7.5	8.4	8.5	8.2
	5% WB	MCDBR	9.9	12.2	14.3	13.4	13.2	13.7	13.6	14.8	15.0	15.1	12.3	10.4
MCWBR		7.3	8.4	8.4	6.9	6.5	6.9	6.4	6.9	7.6	8.3	8.2	7.9	
Clear-Sky Solar Irradiance	taub	0.386	0.418	0.478	0.538	0.544	0.538	0.524	0.487	0.452	0.463	0.425	0.391	
	taud	2.035	1.970	1.873	1.777	1.805	1.834	1.889	1.956	1.999	1.933	1.995	2.032	
	Ebn at Noon	709	753	754	742	751	756	761	776	772	693	655	661	
	Edh at Noon	116	145	179	212	211	206	193	175	156	148	120	108	
All-Sky Solar Radiation	RadAvg	1.70	2.70	4.11	5.47	6.74	7.63	7.43	6.84	5.47	3.67	2.27	1.55	
	RadStd	0.20	0.29	0.30	0.39	0.36	0.32	0.25	0.21	0.19	0.21	0.25	0.22	