

URGENCH, Uzbekistan

WMO: 383960

Lat: 41.584N

Lon: 60.642E

Elev: 331

StdP: 14.52

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.6	8.2	-5.8	4.1	3.4	-0.3	5.5	10.9	21.3	30.2	19.2	30.0	7.3	30	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.8	102.3	70.1	99.7	69.5	97.0	68.5	74.3	94.4	72.5	93.1	70.9	91.4	8.3	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.9	103.8	84.9	65.6	95.7	83.5	63.2	87.9	82.4	38.1	94.4	36.4	92.9	34.9	91.3	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.9	17.5	15.5	-0.1	107.0	7.7	2.5	-5.6	108.8	-10.1	110.3	-14.4	111.7	-19.9	113.5		
(5)			-0.9	78.1	7.4	2.6	-6.2	80.0	-10.6	81.5	-14.8	83.0	-20.2	84.9		

Monthly Climatic Design Conditions

		Annual														
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	56.6	28.8	32.7	46.5	59.8	71.9	80.3	82.9	79.2	67.9	55.0	41.3	31.7	(6)
(7)		DBStd	20.80	10.02	10.31	9.25	8.93	6.31	5.30	4.77	5.57	6.54	8.31	9.31	8.53	(7)
(8)		HDD50	2242	657	488	178	20	0	0	0	0	1	46	285	567	(8)
(9)		HDD65	4929	1122	905	577	201	17	0	0	1	43	321	711	1031	(9)
(10)		CDD50	4660	0	3	69	316	678	908	1019	905	537	201	24	0	(10)
(11)		CDD65	1874	0	0	3	47	230	458	554	441	130	11	0	0	(11)
(12)		CDH74	24633	0	0	48	580	2759	6241	7586	5561	1637	217	4	0	(12)
(13)		CDH80	13436	0	0	10	194	1241	3618	4511	3158	654	50	0	0	(13)
(14)	Wind	WSAvg	7.5	7.7	8.6	8.9	8.6	7.9	7.5	6.9	6.6	6.5	6.1	6.6	7.5	(14)
(15)	Precipitation	PrecAvg	3.6	0.3	0.3	0.7	0.7	0.5	0.2	0.1	0.0	0.0	0.2	0.3	0.5	(15)
(16)		PrecMax	8.7	1.2	1.3	3.1	2.7	2.8	1.1	0.8	0.5	0.4	1.0	1.1	2.0	(16)
(17)		PrecMin	1.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	1.5	0.3	0.3	0.7	0.7	0.6	0.3	0.2	0.1	0.1	0.3	0.3	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.0	64.1	80.5	91.5	97.5	104.4	107.3	104.1	96.7	85.6	71.5	57.6	(19)
(20)		MCWB	45.8	50.4	58.7	65.3	64.9	68.5	71.4	72.0	68.1	61.9	57.3	47.5	47.5	(20)
(21)		2%	DB	48.6	56.2	71.7	85.6	93.5	101.6	102.8	100.3	91.0	79.7	64.6	51.6	(21)
(22)		MCWB	42.6	46.4	54.8	61.3	64.4	68.1	70.9	70.7	65.0	58.3	52.6	44.4	44.4	(22)
(23)		5%	DB	44.5	51.1	66.3	80.6	90.6	98.6	100.1	97.2	87.4	75.2	59.7	46.7	(23)
(24)		MCWB	40.2	43.2	52.5	58.8	63.7	67.3	70.4	69.7	63.2	56.3	49.1	41.9	41.9	(24)
(25)		10%	DB	40.9	46.5	61.2	76.0	87.4	95.4	97.0	94.6	83.4	71.0	55.4	43.0	(25)
(26)		MCWB	37.1	40.8	49.9	57.3	62.6	66.9	69.4	68.7	61.3	54.5	47.4	39.0	39.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.8	51.3	59.5	66.7	70.9	75.0	77.2	76.5	70.2	63.4	58.6	48.9	(27)
(28)		MDCB	53.1	61.4	77.5	87.2	86.6	93.9	95.7	96.4	90.9	79.7	69.6	56.3	56.3	(28)
(29)		2%	WB	43.3	47.0	56.1	63.0	67.4	72.1	74.7	73.9	66.9	60.2	53.9	44.9	(29)
(30)		MDCB	48.0	54.7	69.2	81.7	87.0	92.1	94.9	94.3	86.4	75.8	62.2	50.0	50.0	(30)
(31)		5%	WB	40.2	44.0	53.4	60.5	65.6	70.2	72.9	71.9	64.6	57.7	50.8	42.2	(31)
(32)		MDCB	44.1	50.3	64.9	77.2	84.9	91.3	94.0	92.4	83.6	72.3	57.8	46.5	46.5	(32)
(33)		10%	WB	37.2	40.8	50.6	58.2	64.0	68.5	71.2	70.1	62.6	55.5	47.7	39.2	(33)
(34)		MDCB	40.2	45.9	60.5	73.8	82.9	90.2	92.2	89.8	80.6	68.4	54.3	42.7	42.7	(34)
(35)	Mean Daily Temperature Range	MDBR	14.5	17.0	19.8	22.2	24.8	26.3	25.8	27.3	27.3	24.9	18.9	14.7	14.7	(35)
(36)		5% DB	MCDBR	18.7	24.1	27.3	28.6	29.8	30.7	29.6	30.6	31.7	31.1	25.0	20.7	(36)
(37)		MCWBR	13.4	15.3	14.3	11.9	11.2	10.3	11.3	12.5	13.5	14.6	14.7	14.9	14.9	(37)
(38)		5% WB	MCDBR	17.8	22.6	25.3	25.5	26.1	26.6	27.0	28.8	29.0	27.8	22.1	19.7	(38)
(39)		MCWBR	13.0	14.9	13.8	11.7	10.8	10.1	11.0	12.3	13.1	13.9	13.8	14.4	14.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.389	0.422	0.484	0.536	0.540	0.535	0.521	0.480	0.444	0.458	0.425	0.391	0.391	(40)
(41)		taud	2.041	1.969	1.871	1.793	1.825	1.854	1.909	1.989	2.029	1.952	2.003	2.040	2.040	(41)
(42)		Ebn at Noon	225	238	238	236	239	241	242	249	248	222	209	211	211	(42)
(43)		Edh at Noon	37	46	57	66	66	64	60	54	48	46	38	34	34	(43)
(44)	All-Sky Solar Radiation	RadAvg	550	876	1325	1762	2160	2457	2406	2205	1763	1188	738	506	506	(44)
(45)		RadStd	66	93	90	131	111	106	77	66	56	69	81	68	68	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) +1.31	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46) N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	+1.31	N/A	N/A	N/A	N/A	N/A	(47) +94

Nomenclature: See separate page