

TAMDYBULAQ, Uzbekistan

WMO: 384130

Lat: 41.733N

Lon: 64.617E

Elev: 236

StdP: 98.52

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.7	-13.0	-21.3	0.6	-15.4	-18.6	0.7	-10.8	12.7	1.7	10.2	1.8	2.4	90	0.490

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.4	40.7	20.0	39.2	19.5	37.8	19.1	21.7	36.6	20.7	36.1	19.9	35.6	3.3	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.2	11.8	27.8	14.5	10.6	29.1	13.0	9.6	28.7	64.3	36.7	60.7	35.9	57.8	35.7	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.9	8.1	6.8	DB	-17.9	43.6	4.4	1.6	-21.0	44.7	-23.6	45.7	-26.1	46.6	-29.3	47.8
			WB	-18.2	23.2	4.3	2.2	-21.3	24.8	-23.8	26.0	-26.2	27.2	-29.3	28.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.2	-0.8	1.0	9.0	16.3	23.5	28.8	30.7	29.0	22.4	14.6	6.2	0.3		
	DBStd	12.36	5.82	6.67	5.45	5.32	3.94	3.33	3.14	3.49	4.35	5.26	5.84	5.76		
	HDD10.0	1149	336	256	84	11	0	0	0	0	0	19	139	303		
	HDD18.3	2549	593	484	291	99	7	0	0	0	13	137	366	559		
	CDD10.0	3034	1	5	54	198	419	564	641	590	372	162	26	2		
	CDD18.3	1391	0	0	2	37	168	314	382	332	134	21	1	0		
	CDH23.3	19436	0	1	37	383	1962	4612	5929	4774	1505	223	9	0		
	CDH26.7	11230	0	0	8	128	917	2769	3772	2885	686	63	1	0		
(14) Wind	WSAvg	2.9	3.1	3.2	3.3	3.1	2.9	2.8	2.8	2.7	2.6	2.6	2.8	3.1		
(15) Precipitation	PrecAvg	123	12	15	19	21	14	3	3	1	1	5	11	15		
	PrecMax	278	72	52	63	103	83	19	34	29	11	35	47	53		
	PrecMin	58	0	0	0	0	0	0	0	0	0	0	0	0		
	PrecStd	46	11	13	14	19	18	5	6	5	2	7	10	12		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.3	20.0	27.7	33.2	37.5	41.4	43.8	42.2	38.1	31.9	24.5	16.8		
		MCWB	8.6	10.8	15.4	18.2	19.3	20.5	20.3	20.6	19.2	17.0	13.8	9.3		
	2%	DB	11.5	15.3	23.4	30.1	35.3	39.5	41.5	40.0	35.2	28.2	20.2	13.4		
		MCWB	6.7	8.7	13.1	16.3	18.4	20.1	19.9	19.7	18.0	15.0	11.5	7.1		
	5%	DB	8.5	12.6	20.5	27.6	33.5	38.1	39.5	38.3	32.9	25.6	17.2	10.6		
		MCWB	4.6	6.9	11.7	15.0	17.6	19.4	19.3	19.2	17.0	13.8	10.0	5.5		
	10%	DB	6.0	9.8	17.8	25.2	31.6	36.6	38.0	36.8	30.6	23.3	14.6	8.0		
		MCWB	2.9	5.4	10.5	13.8	16.8	18.7	19.1	18.6	16.0	12.7	8.5	4.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.4	11.7	16.5	19.3	21.5	23.1	23.0	22.7	20.1	17.7	14.5	9.9		
		MCDB	15.3	17.6	25.0	28.7	32.6	36.9	39.7	38.8	35.5	30.9	22.9	15.3		
	2%	WB	6.9	9.2	14.1	17.5	19.6	21.6	21.5	20.9	18.6	15.6	12.3	7.5		
		MCDB	11.2	14.8	21.4	27.5	32.4	35.7	38.0	37.0	34.3	26.9	18.7	12.7		
	5%	WB	4.9	7.3	12.3	15.9	18.5	20.6	20.5	19.9	17.4	14.2	10.5	5.8		
		MCDB	8.2	12.0	19.6	25.8	31.4	35.2	36.9	36.7	32.2	24.6	16.3	10.1		
	10%	WB	3.1	5.5	10.8	14.6	17.5	19.6	19.6	19.0	16.2	13.0	8.9	4.2		
		MCDB	5.8	9.6	17.5	24.0	30.0	34.7	36.2	35.8	30.2	22.6	13.8	7.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.2	8.8	10.7	11.6	12.4	12.7	12.4	12.8	12.9	11.9	9.1	7.4		
		MCDBR	10.2	12.2	14.3	14.0	14.1	14.0	13.6	14.2	14.5	14.3	12.2	10.8		
	5% WB	MCWBR	7.1	7.9	8.4	7.0	6.8	6.3	5.5	6.2	7.3	7.9	7.5	7.3		
		MCWBR	9.7	11.6	13.6	13.2	13.1	13.3	12.8	13.3	14.2	13.5	11.2	10.1		
(40) Clear-Sky Solar Irradiance	taub		0.371	0.407	0.464	0.506	0.496	0.478	0.450	0.423	0.396	0.423	0.405	0.362		
	taud		2.103	2.025	1.910	1.851	1.910	1.972	2.068	2.122	2.153	2.023	2.045	2.124		
	Ebn at Noon		734	768	768	769	791	805	824	835	830	738	681	704		
	Edh at Noon		108	137	173	197	190	179	161	148	133	135	114	98		
(44) All-Sky Solar Radiation	RadAvg		1.77	2.75	4.10	5.59	6.91	7.75	7.64	6.95	5.61	3.77	2.29	1.54		
	RadStd		0.20	0.33	0.33	0.47	0.41	0.25	0.27	0.18	0.17	0.20	0.23	0.19		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	-1.19	-1.94	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		N/A	N/A	N/A	+0.42	N/A	N/A	N/A	N/A	+105	+72

Nomenclature: See separate page