

TASHKENT INTL, Uzbekistan

WMO: 384570

Lat: 41.258N

Lon: 69.281E

Elev: 432

StdP: 96.24

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.9	-7.2	-13.4	1.2	-6.1	-11.2	1.5	-2.3	6.3	8.2	5.5	7.4	1.6	70	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.6	39.0	19.7	37.8	19.3	36.2	18.9	22.3	34.0	21.2	33.3	20.3	32.6	2.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.3	13.9	28.6	17.1	12.9	26.9	16.0	12.0	25.8	68.0	34.1	63.6	33.4	60.4	32.4	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.3	5.4	4.7	-11.4	41.8	3.6	1.2	-14.0	42.7	-16.2	43.4	-18.2	44.1	-20.8	44.9		
(5)			-11.9	23.7	3.5	1.9	-14.5	25.0	-16.5	26.1	-18.5	27.2	-21.1	28.5	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.8	2.7	4.5	10.9	16.3	21.7	26.5	28.4	27.1	21.8	15.4	9.0	4.0		
	DBStd	9.99	4.92	5.54	5.12	4.59	3.57	2.82	2.39	2.70	3.57	4.57	4.95	4.81		
	HDD10.0	729	228	165	51	8	0	0	0	0	0	11	74	193		
	HDD18.3	2056	484	388	233	89	11	0	0	0	11	111	283	446		
	CDD10.0	2831	3	10	80	196	364	496	569	530	354	179	44	6		
	CDD18.3	1117	0	0	4	28	117	247	311	272	115	21	3	0		
	CDH23.3	15148	0	1	47	317	1406	3409	4561	3714	1416	258	21	0		
	CDH26.7	8232	0	0	9	94	602	1914	2739	2151	647	71	4	0		
(14) Wind	WSAvg	2.2	1.9	2.1	2.4	2.4	2.5	2.6	2.5	2.3	2.2	1.9	1.7	1.8		
(15) Precipitation	PrecAvg	435	54	54	71	62	37	10	3	1	5	30	51	56		
	PrecMax	957	146	182	186	179	100	42	41	9	106	112	318	138		
	PrecMin	282	8	1	15	2	1	0	0	0	0	0	6	6		
	PrecStd	119	26	32	36	33	25	9	7	2	15	28	48	31		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.2	21.0	27.9	31.9	36.1	39.9	41.1	39.8	36.6	32.0	26.4	18.8		
		MCWB	8.5	10.7	13.8	17.0	18.2	19.2	20.6	20.1	18.3	16.5	14.4	9.2		
	2%	DB	13.9	17.0	24.1	29.2	33.9	38.0	39.2	38.1	34.2	28.4	21.7	15.8		
		MCWB	7.3	8.8	12.7	16.2	17.7	18.8	20.0	19.7	17.5	14.8	12.4	8.2		
	5%	DB	11.6	14.3	21.5	27.0	32.1	36.2	38.0	37.0	32.5	26.1	18.9	13.2		
		MCWB	6.3	7.7	11.7	15.6	17.5	18.8	19.6	19.2	17.0	14.1	11.1	7.3		
	10%	DB	9.2	12.1	19.0	24.8	30.1	34.9	36.3	35.6	30.8	23.9	16.4	10.8		
		MCWB	5.3	6.7	11.0	14.7	17.0	18.6	19.2	18.9	16.3	13.3	10.0	6.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	12.0	15.1	19.0	21.0	23.1	24.5	23.5	20.0	17.2	15.1	10.6		
		MCDB	14.4	18.3	23.1	27.7	31.3	34.1	35.5	35.2	32.4	28.2	23.7	15.9		
	2%	WB	8.1	10.1	13.8	17.6	19.4	21.7	22.5	21.8	18.8	15.8	13.6	9.2		
		MCDB	12.6	14.9	21.6	25.9	29.7	32.8	34.3	34.1	31.5	25.8	19.7	13.6		
	5%	WB	6.9	8.8	12.7	16.7	18.5	20.5	21.2	20.7	17.8	14.9	12.0	7.9		
		MCDB	10.1	12.9	19.3	24.3	28.8	31.9	33.9	33.1	30.3	24.2	17.3	12.1		
	10%	WB	5.7	7.4	11.7	15.6	17.7	19.6	20.3	19.8	16.8	14.0	10.6	6.6		
		MCDB	8.8	11.2	17.7	22.7	27.5	31.4	33.2	32.3	28.8	22.0	15.4	10.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.5	9.3	10.5	12.0	13.9	15.1	15.6	16.0	15.5	13.0	10.2	8.7		
		MCDBR	11.7	12.5	13.9	15.7	16.4	16.9	17.3	17.5	17.4	16.2	13.6	12.5		
		MCWBR	6.9	7.1	6.8	6.9	5.8	5.6	5.8	5.8	6.4	6.7	6.6	7.3		
		MCDBR	9.8	10.7	12.0	13.4	14.2	15.0	15.4	16.2	16.4	14.2	11.4	10.9		
	5% WB	MCWBR	6.1	6.6	6.4	6.4	5.9	6.2	6.4	6.3	6.7	6.4	6.0	6.7		
(40) Clear-Sky Solar Irradiance	taub		0.376	0.419	0.479	0.488	0.467	0.458	0.437	0.415	0.410	0.466	0.441	0.378		
	taud		2.108	2.013	1.909	1.933	2.040	2.072	2.136	2.187	2.135	1.926	1.971	2.086		
	Ebn at Noon		733	758	757	787	817	823	837	845	818	694	643	688		
	Edh at Noon		109	140	174	182	167	162	151	139	136	150	125	103		
(44) All-Sky Solar Radiation	RadAvg		1.79	2.63	3.79	5.22	6.66	7.58	7.57	6.79	5.38	3.48	2.11	1.52		
	RadStd		0.21	0.32	0.32	0.54	0.38	0.27	0.26	0.24	0.17	0.30	0.28	0.18		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (10 neighbors)		N/A	N/A	N/A	+0.60	-0.84	-1.02	N/A	N/A	N/A
		N/A	N/A	N/A	+0.58	N/A	N/A	N/A	+94	+68

Nomenclature: See separate page