

DARGAN-ATA, TurkmenistanWMO: **385450**Lat: **40.467N**Lon: **62.283E**Elev: **466**StdP: **14.45**Time Zone: **5.00 (E05)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.7	12.9	-3.3	4.7	9.4	4.0	6.9	15.0	19.9	39.0	17.7	37.8	6.2	0	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.7	102.6	72.0	99.9	71.4	97.4	70.7	77.6	95.1	75.4	92.5	73.3	91.0	6.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.5	122.7	87.8	69.9	112.0	86.0	67.4	102.3	84.5	41.5	94.8	39.3	92.7	37.3	90.9	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.3	15.2	13.5	DB	4.0	107.3	7.9	2.5	-1.7	109.1	-6.3	110.6	-10.7	111.9	-16.4	113.7	(4)
(5)			WB	3.2	79.2	7.5	4.3	-2.2	82.2	-6.5	84.7	-10.7	87.1	-16.2	90.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	58.8	32.9	36.8	49.6	61.9	73.0	80.8	83.5	80.1	69.5	57.0	44.1	34.8
	DBStd	19.63	9.32	10.42	9.04	8.69	5.96	4.81	4.56	5.09	6.26	8.12	9.17	8.45
	HDD50	1760	531	378	118	12	0	0	0	0	0	31	217	473
	HDD65	4291	995	789	481	156	11	0	0	0	27	267	629	936
	CDD50	4965	1	8	107	369	714	924	1038	932	585	247	39	1
	CDD65	2021	0	0	4	63	260	475	573	467	161	17	1	0
	CDH74	26929	0	0	77	752	3104	6571	8105	5990	1979	335	16	0
	CDH80	14875	0	0	18	263	1441	3831	4911	3462	856	91	2	0
Wind	WSAvg	6.0	6.2	6.9	7.0	7.0	6.3	6.3	6.1	5.5	5.2	4.9	5.3	5.7
Precipitation	PrecAvg	4.8	0.5	0.7	0.8	0.7	0.7	0.2	0.1	0.0	0.1	0.2	0.5	0.4
	PrecMax	8.9	1.9	2.1	2.9	2.2	3.6	1.0	1.2	0.3	0.5	0.7	2.0	1.4
	PrecMin	2.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	1.7	0.4	0.5	0.7	0.6	0.8	0.2	0.3	0.1	0.1	0.2	0.5	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.8	67.5	82.3	93.1	98.7	104.6	107.5	104.3	97.6	88.5	75.8	60.9
		MCWB	48.1	53.6	61.1	67.3	69.6	71.8	74.4	72.9	70.6	64.7	58.8	48.4
	2%	DB	53.6	60.8	74.7	87.0	94.6	101.3	103.7	100.7	92.5	81.5	67.5	55.2
		MCWB	44.9	50.1	57.6	64.2	67.9	70.8	72.6	73.1	68.4	61.7	54.9	46.2
	5%	DB	48.8	55.6	69.4	82.1	91.6	98.4	100.5	97.8	88.9	77.2	63.0	50.9
		MCWB	42.4	46.7	54.7	62.2	66.7	69.9	71.4	71.6	66.8	59.2	51.7	44.1
	10%	DB	44.7	51.0	64.6	77.9	88.2	95.8	97.7	95.1	85.0	73.0	58.5	46.6
		MCWB	39.6	43.8	52.9	60.1	65.6	69.2	71.2	69.7	64.6	57.1	49.3	41.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.5	54.8	61.8	68.6	73.7	77.8	81.6	80.9	73.5	65.9	60.2	49.9
		MCDB	57.2	66.4	79.1	89.9	92.7	96.1	98.7	97.7	91.1	84.6	74.2	57.7
	2%	WB	45.7	50.8	58.7	65.9	70.8	75.2	78.0	77.6	70.4	62.9	55.8	47.0
		MCDB	52.4	59.1	72.8	83.7	89.0	94.2	95.6	94.5	88.9	79.5	66.1	54.0
	5%	WB	42.8	47.3	56.0	63.3	68.3	73.2	75.6	74.7	67.9	60.2	52.6	44.4
		MCDB	48.4	54.8	67.4	79.6	86.9	91.5	92.7	90.6	86.7	75.5	61.4	50.4
	10%	WB	39.8	44.2	53.5	60.9	66.5	71.2	73.5	72.0	65.5	57.7	49.7	41.7
		MCDB	44.3	50.8	63.6	76.2	84.9	90.5	91.3	89.7	83.0	71.4	57.6	46.2
Mean Daily Temperature Range	5% DB	MDBR	15.4	17.8	21.0	22.7	25.4	26.4	25.7	27.3	28.1	26.5	20.2	15.6
		MCDBR	21.5	25.3	28.6	29.2	31.1	31.2	30.0	30.8	32.7	32.5	26.8	22.0
		MCWBR	14.5	15.9	15.3	13.5	12.9	11.9	11.2	13.0	15.7	17.0	16.4	14.7
	5% WB	MCDBR	20.1	23.9	26.4	26.8	27.9	26.9	26.0	28.4	31.6	31.2	25.4	20.4
		MCWBR	14.1	15.4	15.1	13.4	13.1	12.0	11.7	13.9	16.5	17.1	15.8	14.0
Clear-Sky Solar Irradiance	taub	0.384	0.426	0.489	0.533	0.534	0.538	0.516	0.471	0.438	0.449	0.420	0.378	
	taud	2.048	1.943	1.828	1.774	1.800	1.793	1.858	1.951	1.994	1.935	1.981	2.060	
	Ebn at Noon	231	239	238	238	241	240	245	252	251	228	214	221	
	Edh at Noon	37	48	60	68	68	68	63	56	50	48	40	34	
All-Sky Solar Radiation	RadAvg	618	939	1356	1800	2202	2488	2454	2244	1825	1254	801	558	
	RadStd	61	105	93	135	99	88	76	65	49	70	71	66	