

DARGAN-ATA, TurkmenistanWMO: **385450**Lat: **40.467N**Lon: **62.283E**Elev: **142**StdP: **99.63**Time Zone: **5.00 (E05)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.0	-10.6	-19.6	0.7	-12.6	-15.6	1.0	-9.4	8.9	3.9	7.9	3.2	2.8	0	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	39.2	22.2	37.7	21.9	36.4	21.5	25.3	35.0	24.1	33.6	22.9	32.8	2.8	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.5	17.5	31.0	21.1	16.0	30.0	19.6	14.6	29.2	78.7	34.9	73.5	33.7	68.8	32.7	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.7	6.8	6.0	-15.6	41.9	4.4	1.4	-18.7	42.8	-21.3	43.6	-23.7	44.4	-26.9	45.4		
(5)			-16.0	26.2	4.2	2.4	-19.0	27.9	-21.4	29.3	-23.7	30.6	-26.8	32.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.9	0.5	2.7	9.8	16.6	22.8	27.1	28.6	26.7	20.8	13.9	6.7	1.6	(6)
(7)		DBStd	10.90	5.18	5.79	5.02	4.83	3.31	2.67	2.53	2.83	3.48	4.51	5.09	4.69	(7)
(8)		HDD10.0	978	295	210	66	7	0	0	0	0	0	17	121	263	(8)
(9)		HDD18.3	2384	553	438	267	87	6	0	0	0	15	148	349	520	(9)
(10)		CDD10.0	2758	1	4	59	205	397	513	577	518	325	137	22	1	(10)
(11)		CDD18.3	1123	0	0	2	35	144	264	318	259	89	9	1	0	(11)
(12)		CDH23.3	14961	0	0	43	418	1724	3651	4503	3328	1099	186	9	0	(12)
(13)		CDH26.7	8264	0	0	10	146	801	2128	2728	1923	476	51	1	0	(13)
(14)	Wind	WSAvg	2.7	2.8	3.1	3.1	3.1	2.8	2.8	2.7	2.4	2.3	2.2	2.4	2.6	(14)
(15)	Precipitation	PrecAvg	121	12	17	21	18	19	4	3	1	2	6	12	10	(15)
(16)		PrecMax	226	47	54	73	57	92	26	30	8	13	18	52	35	(16)
(17)		PrecMin	61	0	0	1	0	1	0	0	0	0	0	0	0	(17)
(18)		PrecStd	44	10	13	17	14	21	6	7	2	3	5	12	10	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.4	19.7	28.0	34.0	37.1	40.3	42.0	40.2	36.4	31.4	24.3	16.1	(19)
(20)			MCWB	8.9	12.0	16.2	19.6	20.9	22.1	23.5	22.7	21.5	18.1	14.9	9.1	(20)
(21)		2%	DB	12.0	16.0	23.7	30.6	34.8	38.5	39.8	38.2	33.6	27.5	19.7	12.9	(21)
(22)			MCWB	7.2	10.0	14.2	17.9	20.0	21.6	22.6	22.9	20.2	16.5	12.7	7.9	(22)
(23)		5%	DB	9.3	13.1	20.8	27.9	33.1	36.9	38.0	36.6	31.6	25.1	17.2	10.5	(23)
(24)			MCWB	5.8	8.2	12.6	16.8	19.3	21.1	21.9	22.0	19.3	15.1	10.9	6.7	(24)
(25)		10%	DB	7.0	10.6	18.1	25.5	31.2	35.4	36.5	35.0	29.4	22.8	14.7	8.1	(25)
(26)			MCWB	4.2	6.6	11.6	15.6	18.6	20.7	21.8	20.9	18.1	14.0	9.6	5.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.7	12.7	16.6	20.4	23.2	25.4	27.6	27.2	23.0	18.9	15.7	10.0	(27)
(28)			MCDWB	14.0	19.1	26.2	32.2	33.7	35.6	37.1	36.5	32.8	29.2	23.4	14.3	(28)
(29)		2%	WB	7.6	10.4	14.8	18.8	21.6	24.0	25.5	25.3	21.3	17.2	13.2	8.3	(29)
(30)			MCDWB	11.3	15.1	22.6	28.7	31.6	34.5	35.3	34.7	31.6	26.4	19.0	12.2	(30)
(31)		5%	WB	6.0	8.5	13.3	17.4	20.2	22.9	24.2	23.7	19.9	15.7	11.5	6.9	(31)
(32)			MCDWB	9.1	12.7	19.7	26.5	30.5	33.1	33.7	32.5	30.4	24.2	16.3	10.2	(32)
(33)		10%	WB	4.3	6.8	11.9	16.0	19.1	21.8	23.1	22.2	18.6	14.3	9.8	5.4	(33)
(34)			MCDWB	6.8	10.4	17.6	24.6	29.4	32.5	32.9	32.0	28.3	21.9	14.2	7.9	(34)
(35)	Mean Daily Temperature Range	MDBR		8.5	9.9	11.6	12.6	14.1	14.7	14.3	15.2	15.6	14.7	11.2	8.7	(35)
(36)		5% DB	MCDBR	11.9	14.1	15.9	16.2	17.3	17.3	16.7	17.1	18.2	18.0	14.9	12.2	(36)
(37)			MCWBR	8.1	8.8	8.5	7.5	7.2	6.6	6.2	7.2	8.7	9.4	9.1	8.2	(37)
(38)		5% WB	MCDWB	11.2	13.3	14.7	14.9	15.5	14.9	14.5	15.8	17.6	17.3	14.1	11.3	(38)
(39)			MCWBR	7.8	8.5	8.4	7.4	7.3	6.7	6.5	7.7	9.1	9.5	8.8	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.384	0.426	0.489	0.533	0.534	0.538	0.516	0.471	0.438	0.449	0.420	0.378	(40)
(41)		taud		2.048	1.943	1.828	1.774	1.800	1.793	1.858	1.951	1.994	1.935	1.981	2.060	(41)
(42)		Ebn at Noon		729	754	750	749	761	758	771	795	791	718	675	696	(42)
(43)		Edh at Noon		118	151	190	214	213	215	200	177	158	150	125	108	(43)
(44)	All-Sky Solar Radiation	RadAvg		1.95	2.96	4.27	5.67	6.94	7.84	7.74	7.07	5.75	3.95	2.52	1.76	(44)
(45)		RadStd		0.19	0.33	0.29	0.43	0.31	0.28	0.24	0.20	0.15	0.22	0.22	0.21	(45)