

NAVOI, Uzbekistan

WMO: 385670

Lat: 40.133N

Lon: 65.350E

Elev: 340

StdP: 97.31

Time Zone: 5.00 (E05)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-10.2	-7.1	-14.8	1.1	-7.0	-11.9	1.4	-2.2	10.6	9.5	9.6	8.7	2.7	130	0.541

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.1	40.9	18.9	39.2	18.3	38.0	17.9	19.6	37.4	19.0	36.4	18.5	35.4	5.6	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.9	11.1	20.3	13.9	10.3	20.4	12.9	9.7	20.8	56.9	37.6	55.0	36.8	53.2	35.6	21.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	9.1	8.1	-13.7	42.7	3.6	1.3	-16.3	43.6	-18.5	44.4	-20.5	45.1	-23.2	46.0		
(5)			-14.1	21.0	3.6	0.6	-16.8	21.4	-18.9	21.7	-20.9	22.1	-23.6	22.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.1	3.7	4.2	10.8	16.3	23.3	27.9	30.0	27.5	22.0	15.1	7.8	3.7		
	DBStd	10.45	4.45	5.96	5.18	4.29	3.04	2.79	2.64	3.17	3.49	4.83	5.22	4.78		
	HDD10.0	741	199	173	53	4	0	0	0	0	0	14	96	201		
	HDD18.3	2076	453	397	239	88	2	0	0	0	7	121	317	453		
	CDD10.0	2964	4	9	78	192	412	536	619	543	360	172	32	7		
	CDD18.3	1256	0	0	5	27	155	286	361	284	117	19	2	0		
	CDH23.3	18746	0	3	59	372	2034	4339	5741	4271	1605	300	22	1		
	CDH26.7	10962	0	0	16	116	982	2661	3724	2612	756	90	5	0		
(14) Wind	WSAvg	3.8	3.8	3.9	4.2	4.0	3.9	3.9	4.4	3.7	3.4	3.2	3.2	3.6		
(15) Precipitation	PrecAvg	203	28	34	37	29	18	2	1	1	2	4	20	27		
	PrecMax	305	60	80	66	101	56	15	10	5	14	15	57	67		
	PrecMin	120	8	14	13	0	0	0	0	0	0	1	2	3		
	PrecStd	60	14	16	15	25	16	4	2	2	4	4	16	18		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.9	22.1	28.8	33.2	37.1	41.1	43.1	41.2	37.8	32.2	26.1	19.2		
		MCWB	8.9	11.5	13.8	16.1	17.1	18.7	19.5	19.2	17.3	15.3	13.8	8.9		
	2%	DB	15.1	17.0	24.8	30.0	35.8	39.2	41.2	39.9	35.1	29.1	21.1	16.1		
		MCWB	8.5	9.9	13.4	15.3	16.9	18.3	19.0	18.7	16.3	14.1	11.9	8.0		
	5%	DB	13.0	14.1	22.0	27.2	34.0	38.0	40.0	38.1	33.1	26.2	18.2	13.2		
		MCWB	7.2	8.3	12.4	14.3	16.3	17.9	18.8	17.9	15.9	13.4	10.3	7.1		
	10%	DB	11.0	12.0	19.2	25.1	32.1	36.8	38.2	36.8	31.1	24.2	16.0	11.0		
		MCWB	6.3	7.8	11.4	13.9	16.0	17.5	18.1	17.4	15.3	12.6	9.5	6.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	12.5	16.0	17.7	19.1	20.0	20.5	19.9	17.9	16.0	14.6	10.2		
		MCDB	14.7	19.9	22.8	26.6	29.8	36.9	39.1	38.2	33.4	29.1	22.4	15.9		
	2%	WB	9.3	11.0	14.5	16.7	18.2	19.2	19.7	19.3	17.0	15.1	12.7	8.9		
		MCDB	14.1	15.7	21.6	25.4	29.5	35.6	38.5	37.2	32.8	26.3	19.1	14.3		
	5%	WB	7.9	9.5	13.1	15.9	17.6	18.6	19.1	18.5	16.4	14.1	11.3	7.8		
		MCDB	11.9	13.1	20.2	24.4	29.0	34.6	38.0	36.0	31.9	24.5	17.5	12.7		
	10%	WB	6.8	8.1	12.1	14.9	17.0	18.1	18.5	17.9	15.6	13.2	9.8	6.6		
		MCDB	10.1	11.4	18.6	23.1	28.4	34.0	37.0	34.9	30.2	23.0	15.2	10.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.3	9.8	11.4	12.7	14.5	15.3	15.1	16.0	16.1	14.4	11.6	9.7		
		MCDBR	12.7	13.0	14.5	16.2	17.6	17.0	17.0	17.4	18.2	17.0	14.9	12.8		
		MCWBR	7.3	7.1	6.2	6.2	5.7	5.6	6.2	6.5	7.0	7.2	7.5	7.0		
	5% WB	MCDBR	11.2	11.2	13.2	13.1	14.2	15.1	15.6	16.3	16.8	14.8	12.8	11.6		
		MCWBR	7.0	6.4	6.3	5.5	5.1	5.1	5.9	6.1	6.8	6.6	6.8	6.9		
(40) Clear-Sky Solar Irradiance	taub		0.373	0.413	0.481	0.508	0.502	0.490	0.457	0.431	0.414	0.455	0.432	0.373		
	taud		2.136	2.033	1.900	1.869	1.908	1.943	2.037	2.091	2.094	1.943	1.992	2.120		
	Ebn at Noon		753	774	761	773	788	798	821	832	818	715	667	712		
	Edh at Noon		109	139	177	195	192	185	167	154	144	150	125	103		
(44) All-Sky Solar Radiation	RadAvg		1.88	2.74	4.01	5.53	6.87	7.80	7.75	7.00	5.64	3.85	2.37	1.69		
	RadStd		0.20	0.29	0.30	0.48	0.33	0.25	0.20	0.15	0.17	0.21	0.24	0.18		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	+0.35	-0.52	-1.00	N/A	N/A	N/A	+64	

Nomenclature: See separate page