

JIZZAKH, Uzbekistan

WMO: 385790

Lat: 40.117N

Lon: 67.833E

Elev: 345

StdP: 97.25

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.6	-7.7	-12.9	1.3	-10.0	-10.2	1.6	-6.8	10.0	6.4	8.0	6.5	0.8	180	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	37.9	23.0	36.6	22.4	35.3	21.7	24.8	36.0	23.6	34.7	22.7	33.5	2.3	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.9	16.2	34.1	19.7	15.0	31.7	18.7	14.1	30.4	77.7	35.9	72.8	34.8	69.0	33.5	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.0	5.4	4.3	DB	-11.8	40.4	4.0	1.0	-14.7	41.1	-17.0	41.6	-19.2	42.2	-22.1	42.9	(4)
(5)			WB	-12.0	26.0	4.0	1.0	-14.9	26.7	-17.2	27.3	-19.5	27.9	-22.4	28.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.2	2.4	4.0	10.3	15.8	21.7	26.4	27.7	26.2	20.9	14.9	8.3	3.4	(6)
(7)		DBStd	9.98	5.11	5.65	4.96	4.53	3.48	2.68	2.31	2.64	3.56	4.52	4.95	4.94	(7)
(8)		HDD10.0	792	240	177	58	9	0	0	0	0	0	12	86	209	(8)
(9)		HDD18.3	2161	495	403	252	98	11	0	0	0	16	122	301	463	(9)
(10)		CDD10.0	2701	3	8	67	184	363	493	548	502	327	164	37	5	(10)
(11)		CDD18.3	1027	0	0	2	23	116	243	290	243	93	16	1	0	(11)
(12)		CDH23.3	13353	0	1	27	237	1286	3271	4068	3125	1111	214	15	0	(12)
(13)		CDH26.7	7014	0	0	2	66	528	1809	2372	1708	470	58	2	0	(13)
(14)	Wind	WSAvg	1.6	1.6	1.7	1.8	1.8	1.7	1.6	1.6	1.4	1.4	1.4	1.5	(14)	
(15)	Precipitation	PrecAvg	385	47	48	68	65	34	7	6	4	29	34	46	(15)	
(16)		PrecMax	817	144	124	198	188	119	42	111	8	30	133	110	124	(16)
(17)		PrecMin	252	8	3	9	1	0	0	0	0	0	0	1	1	(17)
(18)		PrecStd	108	28	28	43	40	28	10	18	1	7	33	29	33	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.6	19.7	26.2	31.9	35.5	39.3	40.1	38.6	35.5	31.4	25.8	18.5	(19)
(20)			MCWB	10.0	11.6	15.4	18.5	21.2	23.1	24.8	23.5	20.9	17.8	15.0	9.9	(20)
(21)		2%	DB	13.9	16.5	23.3	28.6	33.5	37.3	38.1	37.0	33.6	28.0	21.5	15.3	(21)
(22)			MCWB	8.1	9.9	14.2	17.7	20.0	22.2	23.5	22.8	20.0	16.6	12.7	8.9	(22)
(23)		5%	DB	11.6	14.0	20.6	26.1	31.7	35.9	36.7	35.6	31.6	25.7	18.5	13.0	(23)
(24)			MCWB	7.2	8.8	13.1	16.6	19.5	21.6	22.9	22.0	18.9	15.3	11.6	7.8	(24)
(25)		10%	DB	9.4	11.9	18.0	23.8	29.8	34.4	35.4	34.2	29.5	23.3	16.2	10.7	(25)
(26)			MCWB	5.9	7.8	12.0	15.8	18.8	20.8	22.1	21.5	18.2	14.3	10.6	6.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.4	12.1	16.4	20.2	22.5	25.0	26.5	25.6	22.2	19.2	15.5	11.1	(27)
(28)			MADB	16.1	17.9	24.6	28.1	33.1	36.7	38.5	36.6	33.8	29.4	22.8	16.2	(28)
(29)		2%	WB	8.7	10.7	14.7	18.7	21.2	23.6	25.3	24.1	20.9	17.1	13.6	9.5	(29)
(30)			MADB	13.2	15.5	21.8	25.9	31.7	35.6	36.7	35.1	31.5	26.8	19.5	14.2	(30)
(31)		5%	WB	7.3	9.2	13.5	17.5	20.1	22.6	24.1	23.1	19.7	15.8	12.3	8.1	(31)
(32)			MADB	11.0	13.1	19.6	24.6	29.9	34.1	35.1	33.7	29.8	24.2	17.4	12.4	(32)
(33)		10%	WB	6.0	8.0	12.3	16.4	19.2	21.6	23.0	22.1	18.6	14.7	11.0	6.9	(33)
(34)			MADB	9.1	11.5	17.4	22.8	28.4	32.8	33.8	32.7	28.2	22.1	15.4	10.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.3	8.3	9.5	10.8	12.9	14.2	14.4	14.6	14.7	12.8	9.7	7.7	(35)
(36)			MCDBR	11.3	12.1	13.8	14.7	15.9	16.4	16.2	16.4	17.0	16.3	13.9	12.4	(36)
(37)			MCWBR	6.7	6.7	6.6	6.2	6.4	6.7	7.0	6.7	6.9	7.2	6.7	7.2	(37)
(38)		5% WB	MCDDBR	10.2	10.7	12.4	13.2	14.8	15.4	15.7	15.5	16.2	14.7	11.7	11.0	(38)
(39)			MCWBR	6.3	6.3	6.4	6.2	6.6	7.2	7.6	7.5	7.5	6.9	6.1	6.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.383	0.430	0.496	0.512	0.501	0.494	0.476	0.452	0.439	0.487	0.450	0.388	(40)	
(41)		taud	2.106	1.996	1.876	1.878	1.947	1.965	2.012	2.060	2.038	1.878	1.949	2.071	(41)	
(42)		Ebn at Noon	738	755	747	770	790	794	805	813	793	682	645	691	(42)	
(43)		Edh at Noon	112	145	182	193	184	181	172	159	152	161	131	108	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.81	2.56	3.71	5.16	6.60	7.59	7.59	6.85	5.55	3.68	2.19	1.61	(44)	
(45)		RadStd	0.23	0.35	0.35	0.55	0.37	0.25	0.27	0.25	0.18	0.30	0.30	0.21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+0.53	+1.42	+1.24	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)		N/A	N/A	N/A	+0.48	N/A	N/A	N/A	N/A	+90	+64

Nomenclature: See separate page