

SYRDARYA, Uzbekistan

WMO: 385830

Lat: 40.817N

Lon: 68.683E

Elev: 863

StdP: 14.24

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.7	16.0	7.2	8.2	10.3	13.4	11.2	16.8	11.4	41.1	9.7	40.6	2.2	270	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.7	100.9	75.2	98.5	74.2	96.2	73.3	79.0	95.5	77.2	94.1	75.5	92.2	3.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.3	132.1	89.1	72.0	122.1	87.8	70.1	114.5	86.3	43.4	95.6	41.4	94.3	39.7	92.3	92.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.3	8.6	7.3	7.0	105.8	9.2	1.9	0.4	107.1	-5.0	108.3	-10.2	109.3	-16.8	110.7
			7.2	81.4	8.7	4.1	0.9	84.3	-4.2	86.7	-9.0	89.0	-15.3	91.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.8	34.0	37.9	50.5	61.1	71.4	79.6	81.9	78.9	69.4	58.1	45.7	35.8	(6)
	DBStd	18.50	8.91	9.82	8.49	7.88	6.08	4.59	4.00	4.66	6.03	7.62	8.65	8.20	(7)
	HDD50	1595	495	346	99	13	0	0	0	0	0	21	179	442	(8)
	HDD65	4099	960	759	451	161	18	0	0	1	27	236	581	905	(9)
	CDD50	4807	0	6	116	345	663	889	987	897	582	271	49	2	(10)
	CDD65	1836	0	0	2	44	215	439	522	433	159	20	2	0	(11)
	CDH74	24169	0	0	41	501	2534	5974	7216	5480	2069	339	15	0	(12)
	CDH80	12984	0	0	3	143	1092	3411	4277	3082	893	82	1	0	(13)
(14) Wind	WSAvg	3.3	3.1	3.5	3.7	3.6	3.5	3.6	3.4	3.2	3.0	2.9	2.9	3.0	(14)
(15) Precipitation	PrecAvg	12.5	1.6	1.9	2.1	1.6	1.1	0.3	0.1	0.0	0.1	0.7	1.3	1.8	(15)
	PrecMax	20.0	3.0	4.3	4.6	2.9	2.8	1.6	0.4	0.3	0.8	3.0	5.3	5.1	(16)
	PrecMin	6.3	0.5	0.0	0.5	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	(17)
	PrecStd	2.9	0.7	1.0	0.9	0.9	0.7	0.4	0.1	0.1	0.2	0.7	1.2	1.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.9	65.8	79.5	89.3	96.8	103.5	104.8	101.9	95.9	87.4	75.7	59.6	(19)
		MCWB	47.5	53.3	61.1	67.4	71.6	76.3	77.3	75.4	71.7	66.7	59.6	49.6	(20)
	2%	DB	51.9	59.3	73.6	84.1	92.9	100.1	101.4	99.1	92.3	81.8	68.5	54.5	(21)
		MCWB	45.1	49.4	58.8	65.8	69.7	74.3	75.7	74.4	69.5	63.1	56.6	46.8	(22)
	5%	DB	48.5	54.9	68.6	79.8	89.8	97.4	98.8	96.7	89.0	77.5	63.2	50.6	(23)
		MCWB	43.3	47.6	56.5	63.9	68.8	73.5	74.9	73.7	68.0	60.4	53.8	45.1	(24)
	10%	DB	45.2	51.1	64.2	75.6	86.4	94.7	96.2	94.0	85.4	73.3	59.0	47.1	(25)
		MCWB	41.4	45.6	54.5	61.9	67.7	72.3	73.9	72.6	65.9	58.6	51.4	43.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.6	54.2	63.7	71.1	74.5	82.0	83.9	79.4	75.9	67.5	61.6	51.0	(27)
		MCDB	54.5	62.9	73.9	83.7	92.1	97.7	98.4	96.9	90.7	84.2	71.7	56.7	(28)
	2%	WB	46.1	50.8	60.1	68.0	72.3	78.2	79.9	77.7	71.7	64.4	57.9	48.0	(29)
		MCDB	50.6	57.5	70.5	79.0	88.2	94.6	95.8	94.7	87.7	79.2	66.4	52.7	(30)
	5%	WB	43.8	48.4	57.6	65.6	70.4	76.0	77.6	76.0	69.2	61.9	55.0	45.5	(31)
		MCDB	47.7	53.8	66.6	76.1	85.5	93.0	94.2	92.7	85.9	74.5	61.8	50.1	(32)
	10%	WB	41.7	46.2	55.4	63.4	68.6	74.1	75.8	74.2	67.1	59.7	52.3	43.2	(33)
		MCDB	44.9	50.7	63.1	73.2	82.9	90.7	92.5	90.4	83.0	71.1	58.0	46.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.9	15.5	18.4	21.0	25.0	27.9	28.7	29.5	29.6	24.9	18.5	13.2	(35)
		MCDBR	17.9	22.1	25.8	28.5	30.0	32.2	31.9	32.0	33.1	31.2	25.0	19.7	(36)
	5% WB	MCWBR	12.0	13.2	13.0	11.8	11.0	12.2	12.1	12.0	13.1	14.2	13.7	12.8	(37)
		MCWBR	16.4	19.0	22.5	25.1	27.7	30.4	30.1	30.9	32.1	28.5	22.2	18.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.404	0.448	0.504	0.511	0.491	0.484	0.462	0.441	0.435	0.497	0.474	0.412	(40)
		taud	2.044	1.947	1.863	1.888	1.980	2.001	2.065	2.108	2.061	1.863	1.904	2.002	(41)
	Ebn at Noon		223	231	233	244	253	254	259	261	252	211	193	206	(42)
		Edh at Noon	37	48	58	61	56	56	51	48	47	51	43	36	(43)
(44) All-Sky Solar Radiation	RadAvg		552	814	1207	1672	2132	2428	2412	2155	1723	1126	684	488	(44)
	RadStd		64	97	103	169	102	80	75	70	48	88	87	62	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.90	N/A	N/A	+0.58	-1.98	-2.48	N/A	N/A	+225	+149	(46)
(47)	Regional (11 neighbors)	N/A	N/A	N/A	+0.94	N/A	N/A	N/A	N/A	+185	+139	(47)

Nomenclature: See separate page