

JALAL-ABAD, Kyrgyzstan

WMO: 386130

Lat: 40.9337N

Lon: 72.9696E

Elev: 2510

StdP: 13.41

Time Zone: 6.00 (E06)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.6	16.1	2.3	6.8	13.8	7.7	8.9	17.2	7.8	32.0	7.2	31.1	3.3	20	0.391

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.7	97.0	67.8	94.6	67.0	92.4	66.2	70.2	92.0	68.8	90.3	67.5	88.6	2.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.8	93.8	80.8	61.0	87.9	79.6	59.4	83.0	78.8	35.8	92.1	34.5	90.4	33.5	88.9	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.5	7.1	5.8	7.6	101.3	8.0	1.9	1.9	102.7	-2.8	103.8	-7.3	104.8	-13.1	106.2		
			6.8	72.7	7.0	1.4	1.7	73.7	-2.4	74.5	-6.3	75.3	-11.4	76.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.7	31.5	36.5	49.4	59.4	68.1	76.1	80.4	78.7	71.4	58.9	46.3	34.3	
	DBStd	18.26	7.59	8.51	8.05	7.52	5.32	4.73	3.95	4.34	5.51	7.44	7.65	7.07	
	HDD50	1739	573	381	109	16	0	0	0	0	0	17	157	486	
	HDD65	4282	1038	797	483	194	30	1	0	0	13	214	562	950	
	CDD50	4549	0	4	91	297	563	783	942	889	642	291	46	1	
	CDD65	1618	0	0	1	25	128	334	477	424	205	23	1	0	
	CDH74	17980	0	0	14	302	1313	3771	5725	4688	1936	225	6	0	
	CDH80	8445	0	0	0	68	423	1795	3035	2347	735	41	1	0	
Wind	WSAvg	3.1	2.7	2.9	3.2	3.3	3.3	3.5	3.3	3.3	3.4	3.1	2.9	2.7	
Precipitation	PrecAvg	18.8	1.6	2.0	2.4	2.3	2.1	0.9	0.4	0.2	0.3	1.3	2.1	1.9	
	PrecMax	29.1	4.8	4.1	4.8	6.3	5.9	3.0	1.3	1.2	0.9	4.8	6.8	4.1	
	PrecMin	11.7	0.2	0.4	0.4	0.6	0.2	0.0	0.0	0.0	0.0	0.0	0.4	0.5	
	PrecStd	4.4	0.9	0.9	1.2	1.2	1.5	0.9	0.4	0.3	0.3	1.1	1.7	0.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.1	63.3	76.1	86.0	91.2	98.2	101.3	98.1	92.4	84.5	73.0	56.1	
		MCWB	43.8	48.4	55.4	62.2	64.4	67.1	70.2	68.6	64.5	59.8	54.3	45.2	
	2%	DB	48.1	56.3	70.8	81.2	87.9	95.0	98.1	95.5	89.8	79.8	66.7	50.6	
		MCWB	40.8	45.8	53.7	60.9	63.7	66.3	68.8	67.2	64.1	58.4	51.3	42.7	
	5%	DB	44.6	51.6	66.6	77.0	84.7	92.3	95.5	93.3	87.4	75.8	61.2	47.2	
		MCWB	38.9	43.5	52.1	58.7	63.0	65.5	67.7	66.7	63.3	57.0	49.1	40.4	
	10%	DB	41.6	47.9	62.4	73.1	81.6	89.5	93.0	91.1	84.5	71.7	57.4	44.0	
		MCWB	36.9	41.4	50.5	57.2	61.9	64.4	66.8	66.0	61.7	54.9	47.5	38.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.8	49.6	57.3	65.9	68.3	70.1	72.8	71.6	67.3	62.1	55.8	46.7
			MCDB	51.5	60.4	71.5	80.0	85.0	93.1	94.7	92.6	88.0	79.8	69.5	53.5
2%		WB	41.6	46.7	54.7	62.4	65.6	68.0	70.8	69.7	65.5	59.8	52.7	43.4	
		MCDB	47.0	55.0	67.8	77.2	82.3	90.4	93.2	90.6	86.8	76.6	62.7	49.5	
5%		WB	39.4	44.1	52.9	60.2	64.1	66.5	69.2	68.3	64.1	57.9	50.3	41.2	
		MCDB	43.9	51.0	64.5	74.1	80.8	87.9	91.4	89.5	85.0	73.1	59.5	46.5	
10%		WB	37.2	41.8	51.0	58.1	62.8	65.5	68.0	67.0	62.5	56.2	48.3	38.9	
		MCDB	41.3	47.3	61.3	70.8	79.2	86.2	89.6	87.9	82.2	69.5	56.3	43.4	
Mean Daily Temperature Range	5% DB	MDBR	14.3	15.2	17.5	19.7	21.8	23.8	23.7	23.1	23.3	21.0	17.2	14.2	
		MCDBR	17.4	20.3	24.3	26.6	27.4	27.6	26.7	25.4	26.2	26.3	23.0	18.7	
		MCWBR	11.8	12.6	12.4	12.6	11.4	10.0	10.2	10.1	11.5	12.0	12.1	12.1	
	5% WB	MCDBR	15.8	19.2	21.8	23.8	24.4	25.3	24.9	24.0	24.9	23.7	20.9	17.5	
		MCWBR	11.2	12.3	12.0	12.8	11.7	10.0	10.6	10.5	11.6	11.7	11.4	11.9	
Clear-Sky Solar Irradiance	taub	0.351	0.400	0.475	0.499	0.484	0.485	0.468	0.434	0.426	0.458	0.416	0.350		
	taud	2.160	2.048	1.900	1.882	1.976	1.997	2.045	2.140	2.092	1.932	2.002	2.157		
	Ebn at Noon	245	248	242	247	254	254	257	263	255	224	214	233		
	Edh at Noon	33	43	56	61	56	56	52	46	45	48	38	30		
All-Sky Solar Radiation	RadAvg	713	999	1334	1638	1970	2246	2292	2108	1726	1114	734	600		
	RadStd	51	77	100	125	130	105	101	95	72	124	95	53		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (5 neighbors)	N/A	N/A	N/A	+0.95	N/A	N/A	N/A	N/A	+135	+115	

Nomenclature: See separate page