

OSH, Kyrgyzstan

WMO: 386150

Lat: 40.609N

Lon: 72.793E

Elev: 2871

StdP: 13.23

Time Zone: 6.00 (E06)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.0	14.4	3.6	7.3	10.8	8.6	9.5	16.2	13.7	35.8	11.7	34.4	5.0	180	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.1	95.6	67.4	93.5	66.6	91.5	65.9	71.5	89.3	69.7	88.1	68.2	86.2	6.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.8	106.0	82.5	62.9	95.6	80.2	61.1	89.4	78.5	37.3	89.7	35.6	88.8	34.3	86.3	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.8	12.8	11.0	7.4	100.0	6.5	1.4	2.7	101.0	-1.1	101.8	-4.7	102.5	-9.5	103.5		
(5)			5.9	74.0	6.1	2.9	1.5	76.1	-2.0	77.8	-5.5	79.5	-9.9	81.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.1	30.8	33.9	47.5	57.5	66.9	75.0	79.5	77.3	69.2	56.4	44.1	33.4		
	DBStd	18.35	7.69	8.72	8.18	7.52	5.49	4.90	3.96	4.46	6.04	7.40	7.06	7.03		
	HDD50	1963	596	453	145	24	1	0	0	0	29	201	514			
	HDD65	4672	1061	871	543	240	43	3	0	1	29	277	626	978		
	CDD50	4183	0	3	67	249	524	750	915	847	576	227	25	0		
	CDD65	1414	0	0	0	15	100	302	450	382	155	10	0	0		
	CDH74	16033	0	0	4	163	1086	3458	5436	4250	1511	124	1	0		
	CDH80	7342	0	0	0	25	305	1574	2841	2060	515	22	0	0		
(14) Wind	WSAvg	5.7	4.6	5.0	5.9	6.3	6.6	6.6	6.3	6.2	6.1	5.0	4.6	4.6		
(15) Precipitation	PrecAvg	13.1	1.5	1.7	2.0	1.7	1.6	0.5	0.3	0.2	0.3	1.2	1.2	1.1		
	PrecMax	26.1	6.7	4.3	5.0	5.0	5.8	1.6	3.0	1.1	1.3	8.4	6.7	3.1		
	PrecMin	7.9	0.2	0.2	0.1	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.0		
	PrecStd	3.9	1.2	0.8	1.1	1.1	1.3	0.4	0.6	0.3	0.4	1.6	1.2	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.4	62.8	73.5	83.1	89.7	96.8	99.0	96.8	90.0	82.7	70.1	55.2		
		MCWB	42.0	48.0	54.9	59.8	61.4	65.7	68.1	69.2	64.0	57.1	52.2	44.3		
	2%	DB	46.4	52.3	68.4	78.8	86.1	93.5	96.9	94.6	88.0	77.1	64.4	50.4		
		MCWB	39.7	43.7	53.5	58.8	62.0	65.8	67.9	67.4	63.1	56.5	50.3	42.3		
	5%	DB	43.1	48.3	64.6	74.8	83.8	91.3	94.8	92.4	85.9	73.3	59.1	46.5		
		MCWB	37.5	41.1	52.2	57.6	61.3	64.8	67.3	66.3	61.8	54.6	47.4	40.4		
	10%	DB	40.7	44.8	60.7	71.2	80.4	88.2	91.8	89.9	82.7	69.6	55.3	43.1		
		MCWB	36.7	39.9	50.3	56.6	60.5	64.3	66.3	65.9	60.7	53.4	45.5	38.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.2	48.8	57.4	63.2	66.6	72.7	73.7	75.2	69.4	60.2	54.8	47.3		
		MCDB	48.2	61.0	67.6	77.0	82.7	90.7	91.1	91.0	85.1	73.8	66.2	52.0		
	2%	WB	40.4	45.2	54.7	61.1	64.5	69.2	71.5	71.5	65.7	58.0	51.9	43.3		
		MCDB	44.4	51.5	65.6	73.9	80.2	86.7	90.2	88.1	83.1	72.8	61.5	48.2		
	5%	WB	38.5	42.3	52.8	59.4	63.2	67.4	69.9	69.2	63.6	56.5	49.3	40.8		
		MCDB	41.9	46.5	62.9	71.3	78.6	85.1	89.5	86.5	81.5	70.2	57.0	46.0		
	10%	WB	36.5	40.0	51.0	57.6	61.8	65.6	68.5	67.7	61.8	54.9	47.0	38.4		
		MCDB	39.6	44.0	59.9	68.1	76.5	84.1	87.7	85.0	79.2	66.5	53.3	42.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.2	14.3	16.7	18.2	21.6	23.9	24.1	23.4	22.9	20.7	16.6	13.8		
		MCDBR	16.5	18.9	23.0	24.5	27.2	27.6	27.0	25.6	25.3	24.8	22.6	18.7		
		MCWBR	11.5	12.3	12.1	11.2	10.8	10.7	11.1	10.9	10.7	10.9	12.8	12.7		
	5% WB	MCDBR	14.8	16.6	20.5	20.3	23.0	24.7	24.7	23.7	24.2	22.3	19.6	17.5		
		MCWBR	10.7	11.3	11.4	10.4	10.8	10.6	11.4	11.2	11.1	10.6	12.0	12.3		
(40) Clear-Sky Solar Irradiance	taub		0.337	0.384	0.454	0.479	0.472	0.472	0.459	0.426	0.414	0.441	0.399	0.337		
	taud		2.231	2.111	1.959	1.936	2.017	2.032	2.072	2.168	2.134	1.980	2.057	2.219		
	Ebn at Noon		253	256	249	252	258	258	259	265	259	231	223	241		
	Edh at Noon		31	40	53	58	55	54	51	45	44	45	36	29		
(44) All-Sky Solar Radiation	RadAvg		697	969	1322	1651	2002	2289	2323	2131	1751	1145	750	598		
	RadStd		53	77	97	129	128	98	93	88	66	111	96	57		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	N/A	+0.92	N/A	N/A	N/A	N/A	+135	+115

Nomenclature: See separate page