

OSH, Kyrgyzstan

WMO: 386150

Lat: 40.609N

Lon: 72.793E

Elev: 875

StdP: 91.25

Time Zone: 6.00 (E06)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.8	-9.8	-15.8	1.0	-11.8	-13.0	1.4	-8.8	6.1	2.1	5.2	1.4	2.2	180	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.4	35.3	19.6	34.1	19.2	33.0	18.8	22.0	31.8	20.9	31.2	20.1	30.1	2.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	15.1	28.0	17.2	13.7	26.8	16.2	12.8	25.8	68.8	32.1	65.0	31.5	61.9	30.2	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	5.7	4.9	DB	-13.6	37.8	3.6	0.8	-16.3	38.3	-18.4	38.8	-20.4	39.2	-23.0	39.7	(4)
(5)			WB	-14.5	23.4	3.4	1.6	-16.9	24.5	-18.9	25.5	-20.8	26.4	-23.3	27.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.4	-0.7	1.1	8.6	14.2	19.4	23.9	26.4	25.2	20.7	13.5	6.7	0.8		
	DBStd	10.20	4.27	4.84	4.55	4.18	3.05	2.72	2.20	2.48	3.36	4.11	3.92	3.90		
	HDD10.0	1091	331	252	81	13	1	0	0	0	0	16	112	286		
	HDD18.3	2596	589	484	302	133	24	2	0	1	16	154	348	543		
	CDD10.0	2324	0	2	37	138	291	417	508	471	320	126	14	0		
	CDD18.3	786	0	0	0	8	56	168	250	212	86	6	0	0		
	CDH23.3	8907	0	0	2	91	603	1921	3020	2361	839	69	1	0		
	CDH26.7	4079	0	0	0	14	169	874	1578	1144	286	12	0	0		
(14) Wind	WSAvg	2.5	2.1	2.3	2.6	2.8	3.0	3.0	2.8	2.8	2.7	2.2	2.1	2.1		
(15) Precipitation	PrecAvg	333	38	44	52	43	41	13	8	5	7	31	31	29		
	PrecMax	662	169	110	127	127	147	40	76	28	32	214	169	80		
	PrecMin	201	4	6	3	6	3	0	0	0	0	0	2	0		
	PrecStd	98	31	21	27	27	33	10	14	7	9	40	31	22		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.2	17.1	23.1	28.4	32.1	36.0	37.2	36.0	32.2	28.2	21.1	12.9		
		MCWB	5.5	8.9	12.7	15.5	16.3	18.7	20.0	20.7	17.8	13.9	11.2	6.8		
	2%	DB	8.0	11.3	20.2	26.0	30.1	34.2	36.1	34.8	31.1	25.0	18.0	10.2		
		MCWB	4.3	6.5	11.9	14.9	16.7	18.8	20.0	19.7	17.3	13.6	10.1	5.7		
	5%	DB	6.1	9.0	18.1	23.8	28.8	32.9	34.9	33.5	30.0	22.9	15.1	8.1		
		MCWB	3.1	5.1	11.2	14.2	16.3	18.2	19.6	19.1	16.5	12.6	8.6	4.7		
	10%	DB	4.8	7.1	16.0	21.8	26.9	31.2	33.2	32.2	28.2	20.9	12.9	6.2		
		MCWB	2.6	4.4	10.2	13.7	15.8	17.9	19.1	18.8	15.9	11.9	7.5	3.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.2	9.3	14.1	17.3	19.2	22.6	23.2	24.0	20.8	15.6	12.7	8.5		
		MCDB	9.0	16.1	19.8	25.0	28.2	32.6	32.9	32.8	29.5	23.2	19.0	11.1		
	2%	WB	4.7	7.3	12.6	16.2	18.1	20.7	22.0	21.9	18.7	14.4	11.0	6.3		
		MCDB	6.9	10.8	18.6	23.3	26.8	30.4	32.3	31.2	28.4	22.7	16.4	9.0		
	5%	WB	3.6	5.7	11.6	15.2	17.3	19.7	21.1	20.7	17.6	13.6	9.6	4.9		
		MCDB	5.5	8.1	17.2	21.8	25.9	29.5	31.9	30.3	27.5	21.2	13.9	7.8		
	10%	WB	2.5	4.5	10.5	14.2	16.5	18.7	20.3	19.8	16.6	12.7	8.3	3.6		
		MCDB	4.2	6.7	15.5	20.1	24.7	28.9	30.9	29.4	26.2	19.1	11.8	5.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.9	7.9	9.3	10.1	12.0	13.3	13.4	13.0	12.7	11.5	9.2	7.7		
		MCDBR	9.2	10.5	12.8	13.6	15.1	15.3	15.0	14.2	14.1	13.8	12.6	10.4		
	5% WB	MCWBR	6.4	6.8	6.7	6.2	6.0	5.9	6.2	6.0	5.9	6.1	7.1	7.1		
		MCWBR	8.2	9.2	11.4	11.3	12.8	13.7	13.7	13.2	13.4	12.4	10.9	9.7		
(40) Clear-Sky Solar Irradiance	taub	taub	0.337	0.384	0.454	0.479	0.472	0.472	0.459	0.426	0.414	0.441	0.399	0.337		
		taud	2.231	2.111	1.959	1.936	2.017	2.032	2.072	2.168	2.134	1.980	2.057	2.219		
	Ebn at Noon	Ebn at Noon	798	806	785	796	814	812	818	836	817	727	702	760		
		Edh at Noon	97	127	166	182	172	169	161	142	138	143	115	91		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.20	3.06	4.17	5.21	6.31	7.21	7.32	6.72	5.52	3.61	2.36	1.89		
	RadStd	RadStd	0.17	0.24	0.31	0.41	0.41	0.31	0.29	0.28	0.21	0.35	0.30	0.18		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		N/A	N/A	N/A	+0.51	N/A	N/A	N/A	N/A	+75	+64

Nomenclature: See separate page