

DEHAVZ, Tajikistan

WMO: 387340

Lat: 39.450N

Lon: 70.200E

Elev: 2561

StdP: 74.11

Time Zone: 5.00 (E05)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.7	-15.8	-24.0	0.6	-17.0	-21.9	0.7	-14.9	10.3	-5.2	8.5	-6.0	2.6	90	0.662

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.5	24.8	15.4	23.4	14.7	21.9	13.7	16.1	24.1	15.0	22.6	14.0	21.4	3.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.6	12.5	22.8	11.6	11.6	21.3	10.6	10.9	19.6	55.8	24.2	52.0	22.8	48.6	21.4	20.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
9.6	8.2	7.7	-19.9	27.6	1.6	1.3	-21.1	28.5	-22.1	29.3	-23.0	30.0	-24.1	31.0		
			-20.6	18.1	1.6	0.9	-21.8	18.7	-22.7	19.3	-23.6	19.8	-24.7	20.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.7	-7.2	-6.1	-0.3	5.5	9.4	12.4	15.0	11.7	6.1	0.1	-5.1
		DBStd	8.47	3.65	3.84	3.82	3.60	2.62	2.42	2.52	2.49	2.62	3.60	3.93
		HDD10.0	2397	532	449	321	139	42	6	2	14	127	296	468
		HDD18.3	4970	790	683	579	386	276	179	104	121	201	379	546
		CDD10.0	473	0	0	0	3	24	77	157	141	64	7	0
		CDD18.3	4	0	0	0	0	0	3	2	0	0	0	0
		CDH23.3	141	0	0	0	0	0	8	78	52	3	0	0
		CDH26.7	11	0	0	0	0	0	7	4	0	0	0	0
(14)	Wind	WSAvg	3.3	3.6	3.8	3.7	3.5	3.2	3.0	2.9	2.6	3.0	3.1	3.4
(15)	Precipitation	PrecAvg	527	51	64	76	68	59	33	27	16	10	31	43
(16)		PrecMax	659	103	108	119	110	120	60	72	28	19	80	111
(17)		PrecMin	389	23	25	27	28	30	16	10	7	1	11	14
(18)		PrecStd	74	20	17	23	20	24	12	12	6	5	16	24
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	2.3	5.8	10.9	18.9	21.3	24.4	27.4	27.0	23.7	19.0	12.2	6.0
(20)		0.4% MCWB	-1.7	0.6	4.5	8.4	11.6	15.6	16.7	16.2	14.5	10.2	5.4	0.1
(21)		2% DB	0.1	2.4	8.5	16.0	19.1	22.2	25.4	24.6	21.7	16.4	9.5	3.2
(22)		2% MCWB	-2.9	-0.8	3.0	7.9	10.7	13.8	15.7	15.3	12.8	8.4	3.6	-1.0
(23)		5% DB	-1.2	0.9	6.8	14.0	17.5	20.5	23.7	23.1	20.0	14.4	7.5	1.6
(24)		5% MCWB	-3.5	-1.9	2.0	6.9	9.7	12.7	14.9	14.6	11.9	7.4	2.1	-1.7
(25)		10% DB	-2.3	-0.6	5.1	12.1	15.7	19.0	22.1	21.6	18.4	12.4	5.5	0.0
(26)		10% MCWB	-4.4	-2.9	0.9	5.9	8.8	11.6	14.1	13.6	10.7	6.2	0.9	-2.5
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	-1.1	1.8	4.8	9.8	12.6	16.3	17.7	17.2	15.0	10.5	5.9	1.0
(28)		0.4% MCDB	0.6	4.3	10.0	17.0	19.9	23.9	26.2	25.8	22.8	18.4	11.6	4.4
(29)		2% WB	-2.3	0.0	3.5	8.2	11.1	14.4	16.4	15.8	13.5	8.8	3.9	-0.3
(30)		2% MCDB	-0.4	2.1	7.6	14.7	18.3	21.6	24.7	23.8	21.0	15.6	8.7	2.2
(31)		5% WB	-3.3	-1.5	2.5	7.2	10.0	13.1	15.2	14.7	12.2	7.6	2.5	-1.2
(32)		5% MCDB	-1.5	0.4	5.9	13.2	16.9	20.0	22.9	22.4	19.2	13.7	6.6	1.1
(33)		10% WB	-4.2	-2.8	1.4	6.2	9.0	11.9	14.2	13.8	11.1	6.5	1.4	-2.3
(34)		10% MCDB	-2.5	-0.8	4.4	11.4	15.2	18.3	21.5	21.1	17.8	11.7	4.9	0.0
(35)	Mean Daily Temperature Range	MDBR	7.6	8.1	8.2	9.7	10.4	11.7	12.5	12.6	11.7	9.7	7.9	7.4
(36)		5% DB MCDBR	7.7	9.0	10.2	12.2	13.4	14.5	15.6	15.4	14.7	13.1	11.1	9.1
(37)		5% WB MCWBR	5.9	6.7	6.8	7.0	7.7	8.5	9.0	9.0	9.0	8.0	7.4	6.7
(38)		5% WB MCDBR	6.4	7.9	9.1	11.0	12.6	13.9	15.0	14.6	14.0	12.0	9.9	7.6
(39)	Clear-Sky Solar Irradiance	taub	0.266	0.301	0.365	0.395	0.410	0.421	0.419	0.383	0.353	0.363	0.315	0.262
(40)		taud	2.253	2.144	2.041	2.046	2.069	2.057	2.079	2.204	2.248	2.119	2.201	2.303
(41)		Ebn at Noon	904	911	881	878	870	858	855	879	886	824	826	883
(42)		Edh at Noon	95	123	153	163	163	166	161	138	123	125	100	84
(44)	All-Sky Solar Radiation	RadAvg	2.28	3.09	4.09	4.95	5.77	6.79	7.08	6.79	5.62	3.59	2.24	1.89
(45)		RadStd	0.16	0.33	0.42	0.69	0.49	0.44	0.34	0.42	0.30	0.47	0.35	0.24

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (11 neighbors)	+0.38	N/A	N/A	+0.48	N/A	N/A	N/A	N/A	+114	+83

Nomenclature: See separate page