

QARSHI, Uzbekistan

WMO: 388120

Lat: 38.750N

Lon: 65.717E

Elev: 1230

StdP: 14.05

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.2	21.6	11.3	10.2	19.4	16.8	13.4	29.2	19.9	55.2	16.8	50.9	4.9	70	0.468

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.4	104.6	70.5	102.1	69.5	99.7	69.1	76.4	96.7	73.9	95.2	71.9	93.8	12.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.8	114.7	90.8	66.4	101.9	88.3	63.9	93.2	85.6	40.9	96.9	38.4	95.5	36.5	94.2	93.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.4	16.6	14.3	DB	12.6	109.6	8.4	2.6	6.6	111.4	1.7	112.9	-3.0	114.4	-9.1	116.2	(4)
(5)			WB	12.0	78.0	8.3	4.9	6.1	81.5	1.3	84.3	-3.4	87.1	-9.4	90.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.6	39.0	42.6	52.7	63.5	74.7	83.1	86.3	82.8	72.9	61.5	49.7	40.9	(6)
(7)		DBStd	18.33	9.48	9.94	8.87	8.36	6.27	4.80	4.49	5.14	5.93	7.66	8.99	8.43	(7)
(8)		HDD50	1094	353	238	74	7	0	0	0	0	0	10	112	300	(8)
(9)		HDD65	3331	806	628	389	125	8	0	0	9	154	465	747		(9)
(10)		CDD50	5689	12	30	159	411	766	994	1125	1017	687	368	102	18	(10)
(11)		CDD65	2453	0	0	9	80	309	544	660	552	246	47	6	0	(11)
(12)		CDH74	33688	1	3	127	911	3765	7781	9841	7542	2974	668	74	1	(12)
(13)		CDH80	19420	0	0	26	319	1867	4734	6271	4575	1415	194	19	0	(13)
(14)	Wind	WSAvg	6.4	5.7	6.3	6.6	6.4	6.6	7.5	8.4	7.2	5.9	5.5	5.2	5.3	(14)
(15)	Precipitation	PrecAvg	10.2	1.5	1.7	2.1	1.5	0.7	0.1	0.0	0.0	0.0	0.2	1.1	1.3	(15)
(16)		PrecMax	15.1	2.4	5.3	3.7	4.2	3.3	0.7	0.5	0.1	0.3	1.3	2.5	3.6	(16)
(17)		PrecMin	5.9	0.6	0.5	0.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	(17)
(18)		PrecStd	2.8	0.6	1.0	0.8	0.9	0.8	0.2	0.1	0.0	0.1	0.3	0.7	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.1	72.3	84.0	93.4	100.2	106.2	109.1	106.5	98.7	90.6	82.6	69.8	(19)
MCWB			52.5	54.2	59.9	65.8	68.3	70.3	70.9	72.5	68.0	62.1	60.8	52.0	(20)	
2%		DB	61.4	66.2	77.7	87.8	96.0	103.0	105.5	103.1	95.1	85.1	74.0	63.1	(21)	
		MCWB	49.0	52.1	58.4	66.1	67.3	69.4	71.2	69.9	66.7	61.2	57.3	50.0	(22)	
5%		DB	56.7	61.7	72.9	83.4	93.3	100.2	102.8	100.3	91.8	81.3	68.9	58.3	(23)	
		MCWB	47.1	50.7	56.5	63.8	66.5	69.2	70.0	69.1	65.5	60.0	54.9	48.5	(24)	
10%		DB	51.9	57.5	68.1	79.3	90.1	97.7	100.2	97.5	88.3	77.3	64.5	53.7	(25)	
		MCWB	45.0	48.5	55.0	62.2	66.0	68.0	69.4	68.7	64.2	58.3	52.6	46.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.7	56.7	63.3	71.2	76.6	79.2	79.9	78.9	72.8	66.6	62.1	55.1	(27)
MCD B			65.6	66.0	77.8	85.5	87.2	96.6	99.2	100.2	93.3	83.0	77.1	65.2	(28)	
2%		WB	50.3	53.8	60.3	68.1	71.8	74.6	76.4	75.3	69.7	63.9	59.1	51.2	(29)	
		MCD B	59.0	64.1	73.3	82.4	89.9	96.1	97.7	96.2	90.1	80.6	71.6	60.0	(30)	
5%		WB	47.8	51.5	57.9	65.4	69.4	72.0	73.9	72.6	67.4	61.3	56.4	48.9	(31)	
		MCD B	55.1	60.1	70.0	79.1	88.2	94.4	96.2	94.1	87.6	77.5	66.9	57.2	(32)	
10%		WB	45.4	49.2	55.8	63.3	67.3	70.1	71.7	70.5	65.3	59.1	53.6	46.5	(33)	
		MCD B	51.7	56.9	66.3	76.6	85.5	93.3	95.1	92.8	85.2	74.9	62.8	53.5	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	16.1	18.3	20.0	21.9	25.0	26.7	26.4	27.8	28.4	26.1	20.8	16.8	(35)
MCDBR			23.9	25.6	27.6	28.3	29.6	30.0	29.0	29.6	30.9	30.6	27.7	24.6	(36)	
MCWBR			14.3	14.6	13.3	12.4	11.1	11.5	11.0	11.5	12.7	14.1	14.8	14.9	(37)	
5% WB		MCDBR	21.6	23.1	24.4	25.0	27.7	28.4	27.5	28.4	30.4	28.6	24.9	22.2	(38)	
		MCWBR	14.0	14.3	13.5	13.2	13.6	13.3	13.5	13.8	15.2	15.4	14.8	14.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.378	0.420	0.485	0.505	0.499	0.496	0.473	0.447	0.430	0.468	0.437	0.384	(40)	
taud		2.131	2.027	1.887	1.876	1.914	1.914	1.966	2.022	2.027	1.899	1.979	2.100	(41)		
Ebn at Noon		241	247	242	247	252	252	257	260	256	226	214	227	(42)		
Edh at Noon		36	45	58	62	61	61	57	53	49	51	41	34	(43)		
(44)	All-Sky Solar Radiation	RadAvg	636	894	1274	1735	2183	2491	2443	2227	1818	1259	785	576	(44)	
(45)		RadStd	67	92	105	157	97	59	44	45	48	68	76	64	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	-2.79	-3.85	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		N/A	N/A	N/A	+0.58	-0.68	-0.94	N/A	N/A	N/A	+110

Nomenclature: See separate page