

ISAMBAJ, Tajikistan

WMO: 388380

Lat: 38.050N

Lon: 68.350E

Elev: 1847

StdP: 13.74

Time Zone: 5.00 (E05)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.3	21.2	11.6	10.6	16.1	17.5	14.2	26.2	22.5	49.6	20.5	51.1	1.5	50	0.452

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.6	105.7	68.4	103.2	67.6	100.9	66.9	70.2	99.5	69.1	98.2	68.1	96.8	5.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.4	87.2	75.3	60.0	82.6	75.1	58.6	78.6	74.8	35.4	100.0	34.4	98.0	33.5	97.1	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
20.0	16.6	15.0	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			9.2	111.5	11.4	2.1	1.0	113.0	-5.7	114.2	-12.1	115.4	-20.3	116.9		
			9.8	73.2	11.4	1.5	1.6	74.3	-5.1	75.2	-11.4	76.0	-19.7	77.2		

Monthly Climatic Design Conditions

		Annual															
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.0	39.6	44.0	55.4	64.5	74.3	83.9	88.2	84.7	76.5	64.2	50.5	41.4	(6)	
(7)		DBStd	18.29	9.10	9.33	7.54	7.60	6.66	5.19	3.79	4.25	4.84	6.89	8.33	7.60	(7)	
(8)		HDD50	922	327	197	34	5	0	0	0	0	0	1	82	276	(8)	
(9)		HDD65	3060	787	589	305	96	9	0	0	0	1	101	442	730	(9)	
(10)		CDD50	6050	5	28	203	440	753	1017	1184	1076	794	441	98	11	(10)	
(11)		CDD65	2711	0	0	9	80	297	567	719	611	345	76	7	0	(11)	
(12)		CDH74	35304	0	3	100	828	3219	7587	10508	8163	3950	883	63	0	(12)	
(13)		CDH80	20707	0	0	18	287	1594	4596	6769	5061	2080	289	13	0	(13)	
(14)	Wind	WSAvg	5.5	5.0	6.4	6.7	5.6	6.6	6.4	5.4	5.2	5.2	5.0	4.5	4.6	(14)	
(15)	Precipitation	PrecAvg	25.7	3.0	3.7	4.5	4.1	2.4	0.7	0.3	0.2	0.3	1.0	2.2	3.1	(15)	
(16)		PrecMax	39.3	5.6	5.8	7.8	12.8	5.1	1.9	0.7	0.3	1.1	2.0	6.3	6.0	(16)	
(17)		PrecMin	16.1	1.4	0.9	1.9	1.3	0.3	0.2	0.1	0.1	0.0	0.4	0.6	0.9	(17)	
(18)		PrecStd	5.6	1.1	1.3	1.4	2.1	1.4	0.5	0.1	0.1	0.2	0.5	1.3	1.5	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.3	70.5	82.2	93.9	100.6	107.0	110.5	107.3	99.6	91.6	81.7	65.1	(19)	
(20)		MCWB	48.4	53.1	58.2	63.2	66.3	68.5	69.6	68.5	65.0	61.5	58.6	50.4		(20)	
(21)		2%	DB	57.7	63.9	76.8	87.1	96.3	103.5	106.9	103.9	97.0	86.7	73.4	60.7	(21)	
(22)		MCWB	47.0	50.6	57.4	62.3	65.3	67.2	68.5	67.9	64.0	60.1	54.4	48.3		(22)	
(23)		5%	DB	54.4	59.7	72.7	82.6	92.7	101.1	104.2	101.4	94.3	83.1	68.5	56.9	(23)	
(24)		MCWB	45.6	48.7	56.0	61.7	64.6	66.8	68.1	66.9	63.5	59.0	52.4	47.1		(24)	
(25)		10%	DB	51.2	56.4	68.3	78.4	89.0	98.2	101.7	98.8	91.0	79.0	64.0	53.3	(25)	
(26)		MCWB	44.5	47.5	54.6	60.7	63.7	66.4	67.5	66.2	62.4	57.5	50.8	45.6		(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.4	55.1	61.5	67.5	69.4	70.9	72.2	71.0	67.7	63.1	59.0	52.8	(27)	
(28)		MCDWB	58.1	66.0	76.1	84.0	88.4	98.4	103.4	100.2	94.8	85.2	76.7	61.8		(28)	
(29)		2%	WB	48.4	52.3	59.1	65.3	67.5	69.4	70.5	69.3	65.6	61.2	56.5	50.0	(29)	
(30)		MCDWB	55.1	60.6	72.4	80.5	89.2	97.8	101.5	100.0	92.6	82.6	69.8	57.0		(30)	
(31)		5%	WB	46.6	50.2	57.2	63.6	66.3	68.3	69.4	68.2	64.1	59.8	54.0	47.9	(31)	
(32)		MCDWB	52.7	57.3	70.0	78.3	87.4	96.2	99.7	98.5	90.9	80.3	64.9	55.0		(32)	
(33)		10%	WB	44.9	48.4	55.4	61.9	65.1	67.2	68.3	67.0	62.9	58.3	51.9	46.1	(33)	
(34)		MCDWB	50.1	54.9	65.7	75.4	84.6	94.3	98.2	96.1	88.9	77.5	61.7	52.5		(34)	
(35)	Mean Daily Temperature Range	MDBR	15.5	16.9	19.7	21.7	24.8	26.7	27.6	28.2	29.0	26.5	20.5	17.9		(35)	
(36)		5% DB	MCDBR	20.8	23.2	25.7	28.7	29.7	29.6	30.0	30.1	31.2	31.0	28.5	24.9		(36)
(37)		MCWBR	11.8	11.5	11.1	10.5	8.3	8.5	8.1	8.3	9.8	11.7	13.4	14.4		(37)	
(38)		5% WB	MCDBR	17.9	19.4	22.6	24.8	26.2	27.6	27.7	28.9	29.9	28.3	23.7	20.7		(38)
(39)		MCWBR	10.8	10.5	10.8	10.7	9.0	8.9	9.0	9.0	10.3	11.4	12.0	12.6		(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.387	0.440	0.501	0.506	0.512	0.541	0.535	0.502	0.467	0.495	0.452	0.400		(40)	
(41)		taud	2.095	1.966	1.850	1.875	1.890	1.815	1.821	1.888	1.932	1.837	1.926	2.039		(41)	
(42)		Ebn at Noon	239	241	239	248	249	241	241	246	246	219	211	222		(42)	
(43)		Edh at Noon	37	49	60	62	62	67	66	61	55	55	44	37		(43)	
(44)	All-Sky Solar Radiation	RadAvg	653	870	1269	1710	2119	2455	2467	2276	1893	1309	797	590		(44)	
(45)		RadStd	79	125	118	168	140	99	68	75	55	109	94	82		(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	-0.65	-1.22	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page