

TEJEN, Turkmenistan

WMO: 388860

Lat: 37.383N

Lon: 60.517E

Elev: 186

StdP: 99.11

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.4	-4.8	-13.1	1.2	-4.9	-9.1	1.8	0.7	8.3	7.8	7.2	6.5	2.0	90	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.9	40.7	21.6	39.4	21.4	38.1	21.1	26.8	35.2	24.5	34.6	22.9	34.2	2.5	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.3	19.7	33.5	21.2	16.2	31.7	19.0	14.1	30.2	85.4	35.2	75.1	34.8	68.8	34.0	36.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.9	6.4	5.4	DB	-10.6	43.2	5.0	1.4	-14.2	44.2	-17.1	45.0	-19.9	45.8	-23.6	46.9	(4)
(5)			WB	-10.5	26.5	4.8	3.3	-14.0	28.9	-16.8	30.8	-19.4	32.6	-22.9	35.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.9	4.7	6.9	13.0	18.6	25.0	29.1	30.8	28.9	23.8	17.4	10.4	5.5	(6)
(7)		DBStd	10.10	5.00	5.23	4.88	4.65	3.25	2.55	2.28	2.52	3.21	4.24	4.76	4.16	(7)
(8)		HDD10.0	509	172	108	25	2	0	0	0	0	0	3	49	149	(8)
(9)		HDD18.3	1683	422	320	177	51	2	0	0	0	2	69	240	399	(9)
(10)		CDD10.0	3393	8	22	117	261	465	573	645	587	414	231	62	8	(10)
(11)		CDD18.3	1526	0	1	11	61	208	323	387	328	166	39	3	0	(11)
(12)		CDH23.3	20403	2	9	151	635	2404	4566	5766	4464	1897	468	41	0	(12)
(13)		CDH26.7	11914	0	2	50	255	1219	2784	3728	2772	937	156	11	0	(13)
(14)	Wind	WSAvg	2.2	2.0	2.4	2.4	2.6	2.4	2.4	2.1	2.0	1.8	1.9	1.9	2.0	(14)
(15)	Precipitation	PrecAvg	159	20	19	31	20	13	1	1	0	1	12	14	15	(15)
(16)		PrecMax	287	60	61	124	78	52	8	3	4	10	101	48	36	(16)
(17)		PrecMin	54	1	2	2	0	0	0	0	0	0	0	1	0	(17)
(18)		PrecStd	57	13	16	26	20	12	2	1	1	2	21	10	12	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.9	24.6	31.8	35.6	38.7	41.6	43.0	41.7	38.1	33.6	28.1	21.3	(19)
(20)			MCWB	11.6	13.1	15.9	18.7	19.5	21.2	22.5	22.1	19.9	17.9	16.1	11.9	(20)
(21)		2%	DB	17.7	20.6	27.2	32.1	36.3	39.8	41.1	39.7	35.6	30.4	23.3	17.7	(21)
(22)			MCWB	9.9	11.8	14.6	18.2	20.0	20.9	21.9	21.4	19.4	17.4	14.1	10.6	(22)
(23)		5%	DB	14.3	17.5	24.2	29.8	34.5	38.3	39.7	38.4	33.8	28.1	20.7	14.7	(23)
(24)			MCWB	8.4	10.5	13.8	17.5	19.4	20.9	22.0	21.1	18.9	16.4	12.8	9.4	(24)
(25)		10%	DB	11.6	14.7	21.3	27.1	32.8	36.9	38.4	36.9	31.9	25.9	18.2	12.0	(25)
(26)			MCWB	7.2	9.2	12.9	16.2	18.9	20.6	21.6	20.5	18.2	15.3	11.7	8.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	14.3	17.0	23.5	26.6	30.1	29.2	29.8	23.6	20.3	17.0	12.9	(27)
(28)			MADB	20.0	21.4	28.4	28.8	31.5	34.9	38.0	36.0	34.1	30.0	25.8	19.4	(28)
(29)		2%	WB	10.4	12.5	15.4	19.7	21.6	24.6	26.5	25.9	21.4	18.3	15.0	11.2	(29)
(30)			MADB	16.5	19.5	24.9	29.0	31.8	33.9	36.9	34.5	31.7	28.5	21.8	16.7	(30)
(31)		5%	WB	9.0	10.9	14.4	18.1	20.3	22.7	24.5	23.5	20.0	17.1	13.6	9.6	(31)
(32)			MADB	13.6	16.3	22.7	27.4	31.7	34.8	35.5	34.0	31.1	26.4	19.2	14.2	(32)
(33)		10%	WB	7.5	9.6	13.3	16.8	19.5	21.5	23.0	21.8	18.8	16.0	12.1	8.2	(33)
(34)			MADB	11.2	14.3	20.6	25.3	30.6	34.3	34.8	33.9	30.0	24.3	17.5	11.7	(34)
(35)	Mean Daily Temperature Range	MDBR		9.8	10.4	11.2	11.7	13.3	14.3	14.9	15.6	15.2	13.8	11.5	9.8	(35)
(36)		5% DB	MCDBR	15.0	15.8	17.0	16.2	16.0	16.8	16.5	17.3	17.0	17.1	16.0	14.9	(36)
(37)			MCWBR	8.5	8.5	6.9	6.2	5.6	6.2	5.9	6.6	6.6	7.9	8.2	9.2	(37)
(38)		5% WB	MCDBR	13.7	14.3	14.9	14.5	14.5	15.2	15.1	15.7	15.2	15.4	14.0	13.6	(38)
(39)			MCWBR	8.1	8.2	6.6	6.4	5.9	7.4	7.6	8.0	7.0	7.8	7.7	8.6	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.395	0.442	0.514	0.555	0.558	0.560	0.551	0.504	0.474	0.498	0.455	0.404	(40)
(41)		taud		2.090	1.966	1.821	1.777	1.794	1.782	1.809	1.894	1.936	1.865	1.948	2.056	(41)
(42)		Ebn at Noon		752	762	744	742	749	746	749	775	771	692	671	705	(42)
(43)		Edh at Noon		120	154	196	217	217	219	212	190	172	169	138	117	(43)
(44)	All-Sky Solar Radiation	RadAvg		2.26	3.16	4.26	5.65	6.97	7.96	7.87	7.29	5.98	4.20	2.75	2.07	(44)
(45)		RadStd		0.20	0.33	0.33	0.52	0.27	0.25	0.16	0.20	0.15	0.24	0.23	0.23	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	-1.46	N/A	N/A	N/A	N/A	(46)
(47) Regional (6 neighbors)	N/A	N/A	N/A	+0.41	-0.55	N/A	N/A	N/A	N/A	+88	(47)

Nomenclature: See separate page