

TERMEZ, Uzbekistan

WMO: 389270

Lat: 37.287N

Lon: 67.310E

Elev: 1027

StdP: 14.16

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.1	25.0	12.5	10.8	31.3	17.5	13.8	35.2	28.9	38.3	24.1	38.7	6.1	250	0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.8	106.4	68.5	104.2	68.0	102.0	67.5	72.1	98.4	70.5	97.1	69.2	95.8	6.4	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.8	92.0	82.1	61.8	85.6	79.9	60.2	80.9	78.8	36.6	98.6	35.1	97.1	34.0	96.0	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.4	20.1	16.3	14.9	111.6	8.8	1.4	8.6	112.7	3.4	113.5	-1.5	114.3	-8.0	115.4
			14.5	75.9	8.8	2.4	8.1	77.6	3.0	79.0	-2.0	80.4	-8.4	82.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.9	41.5	45.2	56.1	67.3	77.4	84.7	87.4	83.6	74.6	64.0	52.1	43.2	(6)
		DBStd	17.56	7.88	8.87	8.53	7.89	6.10	4.17	3.55	4.21	5.16	6.85	8.05	7.35	(7)
		HDD50	791	273	176	41	2	0	0	0	0	3	66	230		(8)
		HDD65	2821	727	553	295	68	4	0	0	3	101	393	677		(9)
		CDD50	6216	11	42	230	520	848	1040	1159	1042	739	437	130	18	(10)
		CDD65	2772	0	0	19	136	387	590	694	577	292	70	7	0	(11)
		CDH74	38417	0	8	256	1572	4951	8613	10345	8000	3621	957	94	0	(12)
		CDH80	23003	0	1	68	655	2732	5496	6790	4997	1911	328	25	0	(13)
(14)	Wind	WSAvg	6.4	6.0	7.4	7.9	7.5	6.9	6.6	6.1	5.4	5.3	5.4	5.5		(14)
(15)	Precipitation	PrecAvg	5.8	0.9	0.8	1.4	1.0	0.4	0.0	0.0	0.0	0.1	0.4	0.7		(15)
(16)		PrecMax	10.5	3.2	2.2	4.3	2.3	1.5	0.4	0.0	0.4	1.2	1.8	3.9		(16)
(17)		PrecMin	3.1	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		(17)
(18)		PrecStd	1.7	0.7	0.5	0.8	0.6	0.4	0.1	0.0	0.1	0.2	0.4	0.7		(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	66.6	73.3	86.7	96.0	103.7	108.8	110.7	107.5	100.5	91.8	84.0	68.4		(19)
(20)		0.4% MCWB	49.7	54.2	59.4	64.7	66.2	68.6	69.9	69.6	66.1	62.7	60.3	51.0		(20)
(21)		2% DB	62.0	67.4	80.6	91.3	99.9	105.5	107.6	104.2	97.2	87.6	75.5	64.1		(21)
(22)		2% MCWB	48.0	51.4	57.8	63.4	65.5	67.8	68.9	68.6	65.2	61.2	56.3	49.6		(22)
(23)		5% DB	57.4	63.0	75.6	87.6	96.6	102.6	105.4	101.9	94.4	83.9	70.6	59.6		(23)
(24)		5% MCWB	46.7	50.1	55.9	62.3	65.0	67.1	68.4	68.0	64.4	60.0	54.3	48.0		(24)
(25)		10% DB	53.4	59.1	71.0	83.6	93.3	100.3	102.4	99.0	91.0	79.4	66.0	55.2		(25)
(26)		10% MCWB	45.6	49.0	54.9	61.2	64.2	66.4	67.9	66.8	63.1	58.5	52.8	46.4		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	52.1	56.5	62.0	68.4	70.6	72.9	74.3	74.5	70.1	65.1	60.8	54.0		(27)
(28)		0.4% MCDB	61.4	66.6	76.9	86.8	95.1	99.2	100.9	98.1	93.0	85.9	79.0	63.0		(28)
(29)		2% WB	49.9	53.7	59.7	66.3	68.2	70.5	72.3	71.7	67.5	62.7	57.9	51.2		(29)
(30)		2% MCDB	58.4	62.7	75.3	82.9	91.3	98.0	99.2	96.9	91.3	83.1	71.4	60.1		(30)
(31)		5% WB	48.0	51.7	57.8	64.4	66.8	69.0	70.7	69.9	65.7	61.0	55.9	49.0		(31)
(32)		5% MCDB	55.4	60.7	71.4	81.0	89.2	96.4	98.1	95.7	89.5	79.8	67.5	57.5		(32)
(33)		10% WB	46.0	49.8	56.2	62.9	65.6	67.9	69.3	68.3	64.1	59.4	53.9	47.0		(33)
(34)		10% MCDB	52.3	57.1	68.1	78.7	87.2	95.1	96.9	94.6	87.3	76.8	64.1	54.3		(34)
(35)	Mean Daily Temperature Range	MDBR	18.1	19.1	21.3	24.3	27.5	30.4	30.8	31.6	31.7	27.8	21.7	19.0		(35)
(36)		5% DB MCDBR	25.5	25.3	28.6	30.7	32.2	34.0	34.1	34.0	35.3	33.1	29.5	26.3		(36)
(37)		5% WB MCWBR	13.9	12.4	10.9	9.7	9.6	10.2	10.2	11.0	12.1	13.1	13.5	14.1		(37)
(38)		5% WB MCDBR	21.5	20.9	24.4	26.4	28.0	31.3	32.0	32.0	33.2	29.6	25.2	22.6		(38)
(39)		5% WB MCWBR	12.5	11.3	10.7	9.7	9.1	10.3	11.1	11.5	12.6	12.8	12.3	13.0		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.390	0.441	0.497	0.506	0.506	0.517	0.506	0.482	0.454	0.484	0.455	0.402		(40)
(41)		taud	2.087	1.964	1.852	1.867	1.890	1.855	1.875	1.930	1.959	1.860	1.921	2.043		(41)
(42)		Ebn at Noon	240	242	241	248	251	247	249	252	250	224	213	224		(42)
(43)		Edh at Noon	38	49	60	63	62	65	63	58	53	54	45	38		(43)
(44)	All-Sky Solar Radiation	RadAvg	704	946	1385	1821	2254	2538	2486	2259	1905	1366	864	651		(44)
(45)		RadStd	68	108	109	157	104	61	46	67	40	84	81	72		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	-0.74	-1.22	N/A	N/A	N/A	N/A
Regional (10 neighbors)		N/A	N/A	N/A	N/A	N/A	-0.86	N/A	N/A	N/A	N/A

Nomenclature: See separate page