

TERMEZ, Uzbekistan

WMO: 389270

Lat: 37.287N

Lon: 67.310E

Elev: 313

StdP: 97.62

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.2	-3.9	-10.8	1.5	-0.4	-8.0	2.0	1.8	12.9	3.5	10.8	3.7	2.7	250	0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.1	41.3	20.3	40.1	20.0	38.9	19.7	22.3	36.9	21.4	36.2	20.7	35.4	2.8	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	13.1	27.8	16.5	12.2	26.6	15.7	11.6	26.0	67.3	37.0	63.8	36.2	61.2	35.5	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.9	9.0	7.3	-9.5	44.2	4.9	0.8	-13.0	44.8	-15.9	45.3	-18.6	45.7	-22.2	46.3		
(5)			-9.7	24.4	4.9	1.3	-13.3	25.3	-16.1	26.1	-18.9	26.9	-22.4	27.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	5.3	7.4	13.4	19.6	25.2	29.3	30.8	28.7	23.7	17.8	11.2	6.2
	DBStd	9.76	4.38	4.93	4.74	4.38	3.39	2.32	1.97	2.34	2.86	3.81	4.47	4.08
	HDD10.0	439	152	98	23	1	0	0	0	0	0	2	37	128
	HDD18.3	1567	404	307	164	38	2	0	0	0	2	56	218	376
	CDD10.0	3453	6	23	128	289	471	578	644	579	411	243	72	10
	CDD18.3	1540	0	0	11	76	215	328	386	321	162	39	4	0
	CDH23.3	21343	0	4	142	873	2751	4785	5747	4444	2012	532	52	0
	CDH26.7	12779	0	1	38	364	1518	3053	3772	2776	1062	182	14	0
Wind	WSAvg	2.9	2.7	3.3	3.5	3.4	3.1	3.0	2.9	2.7	2.4	2.4	2.4	2.5
Precipitation	PrecAvg	148	22	20	36	26	10	1	0	0	0	2	9	19
	PrecMax	266	82	55	109	59	37	10	1	0	10	30	46	98
	PrecMin	78	0	1	5	0	0	0	0	0	0	0	0	0
	PrecStd	42	18	12	21	15	11	2	0	0	2	6	10	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.2	23.0	30.4	35.6	39.9	42.7	43.7	42.0	38.1	33.2	28.9	20.2
		MCWB	9.8	12.3	15.2	18.2	19.0	20.4	21.0	20.9	18.9	17.1	15.7	10.6
	2%	DB	16.7	19.6	27.0	33.0	37.7	40.8	42.0	40.1	36.2	30.9	24.2	17.8
		MCWB	8.9	10.8	14.3	17.4	18.6	19.9	20.5	20.3	18.4	16.2	13.5	9.8
	5%	DB	14.1	17.2	24.2	30.9	35.9	39.2	40.8	38.9	34.7	28.8	21.5	15.3
		MCWB	8.2	10.1	13.3	16.8	18.3	19.5	20.2	20.0	18.0	15.6	12.4	8.9
	10%	DB	11.9	15.1	21.7	28.6	34.1	37.9	39.1	37.2	32.8	26.3	18.9	12.9
		MCWB	7.5	9.5	12.7	16.2	17.9	19.1	19.9	19.3	17.3	14.7	11.6	8.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	13.6	16.7	20.2	21.5	22.7	23.5	23.6	21.2	18.4	16.0	12.2
		MCDB	16.3	19.2	24.9	30.5	35.1	37.3	38.3	36.7	33.9	29.9	26.1	17.2
	2%	WB	9.9	12.1	15.4	19.0	20.1	21.4	22.4	22.0	19.7	17.1	14.4	10.7
		MCDB	14.7	17.1	24.0	28.3	32.9	36.7	37.4	36.0	33.0	28.4	21.9	15.6
	5%	WB	8.9	10.9	14.3	18.0	19.4	20.6	21.5	21.0	18.7	16.1	13.3	9.5
		MCDB	13.0	16.0	21.9	27.2	31.8	35.8	36.7	35.4	32.0	26.6	19.7	14.1
	10%	WB	7.8	9.9	13.5	17.2	18.7	19.9	20.7	20.2	17.8	15.2	12.2	8.3
		MCDB	11.3	14.0	20.1	26.0	30.7	35.0	36.0	34.8	30.7	24.9	17.8	12.4
Mean Daily Temperature Range	5% DB	MDBR	10.1	10.6	11.8	13.5	15.3	16.9	17.1	17.6	17.6	15.4	12.1	10.6
		MCDBR	14.2	14.1	15.9	17.1	17.9	18.9	19.0	18.9	19.6	18.4	16.4	14.6
		MCWBR	7.7	6.9	6.1	5.4	5.3	5.7	5.7	6.1	6.7	7.3	7.5	7.8
	5% WB	MCDBR	11.9	11.6	13.6	14.7	15.6	17.4	17.8	17.8	18.4	16.4	14.0	12.6
		MCWBR	6.9	6.3	6.0	5.4	5.1	5.7	6.2	6.4	7.0	7.1	6.9	7.2
Clear-Sky Solar Irradiance	taub	0.390	0.441	0.497	0.506	0.506	0.517	0.506	0.482	0.454	0.484	0.455	0.402	
	taud	2.087	1.964	1.852	1.867	1.890	1.855	1.875	1.930	1.959	1.860	1.921	2.043	
	Ebn at Noon	758	764	760	783	790	779	784	794	789	705	670	707	
	Edh at Noon	121	155	190	198	197	204	198	184	168	169	142	119	
All-Sky Solar Radiation	RadAvg	2.22	2.98	4.37	5.74	7.11	8.00	7.84	7.12	6.00	4.31	2.73	2.05	
	RadStd	0.21	0.34	0.34	0.49	0.33	0.19	0.15	0.21	0.13	0.27	0.26	0.23	

Historical Trends

		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(m)
(47) Regional (10 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page